

P001 樹林焚化廠CEMS系統日報表-A

報表日期: 115年08月14日

項目 單位 小時\限標	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.97	12.28	62.99	2.43	17.83	11.54	1.18	70997.43
1	10.38	13.09	57.63	2.44	19.15	11.26	1.18	72386.46
2	9.02	13.17	48.91	3.51	16.58	11.60	1.18	72029.15
3	9.10	12.87	57.37	2.66	18.51	11.22	1.18	73690.40
4	7.90	13.01	54.76	2.41	17.64	11.36	1.18	72824.80
5	10.46	11.66	53.67	2.65	18.28	11.23	1.23	69010.75
6	11.27	11.50	53.45	2.48	18.81	10.99	1.25	74053.45
7	9.73	11.80	58.48	2.90	17.47	11.41	1.25	71490.56
8	8.31	11.60	48.75	2.50	18.76	11.13	1.24	73243.76
9	7.17	11.57	44.76	2.82	17.40	11.32	1.25	73852.86
10	11.90	12.07	47.74	2.81	17.56	11.22	1.24	73613.81
11	10.22	11.85	46.75	2.43	18.72	10.95	1.23	74517.81
12	6.58	11.99	49.29	1.38	19.98	10.73	1.23	74584.82
13	8.52	11.84	50.44	1.76	19.04	11.09	1.23	72606.48
14	8.98	11.50	38.72	1.95	19.30	10.63	1.25	75817.34
15	9.83	11.48	46.85	2.03	18.98	11.03	1.24	73762.74
16	9.44	12.89	44.30	2.33	16.60	11.50	1.24	72133.07
17	9.22	12.03	50.46	1.46	16.73	11.72	1.24	70245.23
18	9.54	11.68	50.67	1.33	17.51	11.40	1.23	72316.66
19	10.53	11.52	55.88	1.54	17.77	11.23	1.24	72525.61
20	8.85	12.09	52.52	1.43	17.46	11.15	1.25	72875.54
21	10.19	11.78	52.05	1.23	18.31	10.92	1.25	74104.69
22	7.15	11.97	58.54	1.11	17.66	11.61	1.25	70022.11
23	10.28	11.74	54.10	1.83	18.68	11.14	1.24	72333.34
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	9.31	12.04	51.63	2.14	18.11	11.22	1.23	72709.95
最 大 值	11.90	13.17	62.99	3.51	19.98	11.72	1.25	75817.34
發生時間	10	2	0	2	12	17		14
最 小 值	6.58	11.48	38.72	1.11	16.58	10.63	1.18	69010.75
發生時間	12	15	14	22	2	14		5
零點偏移(率)	0.00 %	0.01 %	0.00 %	0.00 %		-0.01	-0.01	0.20 %
全幅偏移(率)	0.98 %	0.09 %	-0.13 %	0.53 %		-0.32	-0.06	0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A 報表日期: 115年08月14日

報表日期: 115年08月14日

項目 單位 小時\限標	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	5.64	11.72	57.45	2.24	18.16	10.20	1.31	73110.47
1	6.00	12.88	60.50	2.45	19.86	10.10	1.31	73273.60
2	4.14	12.56	52.35	2.29	19.79	9.78	1.31	73745.39
3	6.27	12.40	47.05	2.24	18.70	9.76	1.31	74092.30
4	5.29	12.68	51.34	2.32	19.49	9.94	1.29	72447.49
5	6.86	12.84	45.34	2.26	18.33	9.84	1.27	73774.41
6	5.27	12.53	49.02	2.19	18.17	9.99	1.28	72569.16
7	3.64	12.11	49.77	2.72	17.56	10.55	1.32	73202.61
8	6.27	11.16	51.48	1.97	22.08	8.72	1.29	75711.92
9	5.04	11.34	40.40	2.67	21.11	8.60	1.30	74913.13
10	5.35	11.83	33.75	1.64	19.78	9.10	1.27	73178.68
11	5.98	12.76	27.53	1.89	19.74	8.96	1.30	71933.91
12	3.12	11.91	27.93	1.71	18.44	9.23	1.28	70582.67
13	3.16	11.86	33.87	1.87	19.28	9.05	1.26	70322.75
14	2.53	16.79	44.21	4.29	20.45	8.41	1.26	72315.89
15	9.79	10.54	29.51	2.95	24.34	5.63	1.26	83432.36
16	1.47	10.12	60.43	1.53	15.24	10.42	1.26	69732.09
17	1.68	12.28	64.72	2.34	15.38	11.23	1.28	73838.15
18	3.34	11.99	62.53	2.27	16.94	10.87	1.27	74812.80
19	2.79	12.00	64.20	2.37	17.95	10.61	1.27	78472.35
20	3.09	11.68	62.18	2.23	17.22	10.57	1.28	76881.68
21	8.44	11.60	59.07	2.63	18.16	10.35	1.28	78283.91
22	9.47	12.14	60.35	2.60	16.96	10.97	1.27	76774.83
23	5.21	12.18	67.19	2.72	17.35	10.82	1.27	76569.18
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	4.99	12.16	50.09	2.35	18.77	9.74	1.28	74332.16
最 大 值	9.79	16.79	67.19	4.29	24.34	11.23	1.36	83432.36
發生時間	15	14	23	14	15	17		15
最 小 值	1.47	10.12	27.53	1.53	15.24	5.63	1.23	69732.09
發生時間	16	16	11	16	16	15		16
零點偏移(率)	-0.07 %	-0.11 %	-0.00 %	-0.01 %		-0.08	-0.01	0.20 %
全幅偏移(率)	0.02 %	0.02 %	-0.00 %	0.51 %		0.00	0.00	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								