

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 115年04月08日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	15.71	11.54	58.34	3.99	18.72	10.99	1.25	74898.00
1	15.08	11.65	60.03	2.30	19.02	11.09	1.25	73940.27
2	8.14	11.67	65.34	1.82	19.57	11.05	1.25	74080.25
3	7.83	11.84	57.19	2.18	18.80	11.20	1.25	73700.69
4	9.01	11.48	58.85	2.10	20.29	10.74	1.25	75885.62
5	7.85	11.44	47.88	1.86	19.35	10.70	1.21	75744.05
6	11.92	11.67	56.40	1.67	19.73	10.64	1.23	76591.54
7	13.61	11.50	56.34	1.85	19.01	10.94	1.23	74778.35
8	9.52	11.91	65.17	1.41	19.01	11.32	1.23	72025.76
9	10.38	11.73	46.68	2.94	18.61	11.11	1.24	73348.14
10	8.74	11.70	53.52	2.16	18.43	11.15	1.23	73136.62
11	12.04	11.98	51.74	2.15	17.41	11.42	1.22	72041.87
12	16.13	12.40	56.79	3.31	16.91	11.42	1.22	72006.22
13	11.98	11.61	55.49	2.06	17.54	11.08	1.23	73689.24
14	9.30	11.55	58.88	1.78	18.54	10.91	1.24	73973.70
15	10.32	11.77	55.49	1.97	17.91	11.30	1.20	71926.22
16	16.68	11.36	55.58	2.93	18.24	10.90	1.19	74524.56
17	8.40	11.48	52.06	2.26	17.75	11.08	1.19	73655.02
18	14.72	11.90	51.88	3.05	17.78	11.04	1.23	73842.34
19	8.38	11.87	55.81	2.79	17.23	11.32	1.23	72138.01
20	4.48	11.86	51.38	1.79	17.40	11.43	1.23	71558.23
21	9.44	12.01	48.13	2.34	17.61	11.15	1.23	73271.20
22	11.82	11.76	53.70	3.15	17.38	11.25	1.23	72741.93
23	11.63	11.75	53.15	2.73	17.36	11.31	1.23	72139.79
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	10.96	11.73	55.24	2.36	18.32	11.11	1.23	73568.23
最大值	16.68	12.40	65.34	3.99	20.29	11.43	1.27	76591.54
發生時間	16	12	2	0	4	20		6
最小值	4.48	11.36	46.68	1.41	16.91	10.64	1.18	71558.23
發生時間	20	16	9	8	12	6		20
零點偏移(率)	-0.01 %	0.01 %	-0.07 %	0.00 %		-0.07	-0.01	0.30 %
全幅偏移(率)	0.45 %	0.48 %	0.44 %	-0.01 %		-0.04	-0.06	0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 115年04月08日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	10.92	11.32	54.97	0.85	19.38	9.90	1.02	80025.38
1	10.96	11.69	46.44	1.13	20.56	9.72	1.02	79445.37
2	11.22	11.31	51.35	0.54	20.34	9.66	1.02	77291.18
3	7.97	13.13	59.42	0.96	17.75	11.58	1.02	65785.65
4	9.00	11.36	37.03	0.91	19.11	9.82	1.02	78394.09
5	9.72	11.75	45.31	0.47	20.85	9.39	1.02	80514.95
6	7.57	11.89	36.43	1.31	19.88	9.53	1.04	78221.13
7	11.46	11.65	48.45	1.19	19.24	10.06	1.04	80685.45
8	11.30	12.34	63.20	0.82	18.70	10.83	1.04	80254.87
9	10.47	12.17	59.53	0.69	19.56	10.55	1.04	79672.74
10	9.57	12.39	45.00	0.94	18.66	10.53	1.02	78176.91
11	10.48	12.29	44.93	1.26	19.20	10.23	1.02	82219.16
12	10.55	12.04	56.70	1.07	19.11	10.48	1.03	81120.99
13	13.80	12.14	61.17	1.07	18.80	10.65	1.05	80889.86
14	8.85	12.26	63.14	1.09	18.26	10.80	1.04	79250.91
15	11.51	13.05	54.25	1.91	16.79	10.81	1.05	78753.75
16	15.45	12.66	50.30	1.93	17.41	10.75	1.06	78914.89
17	11.11	11.96	56.59	1.50	17.91	10.55	1.06	80663.15
18	14.85	12.03	63.13	0.97	18.91	10.51	1.04	81842.97
19	13.47	11.76	64.73	1.21	18.60	10.33	1.05	81365.18
20	11.23	11.78	58.45	1.55	18.51	10.32	1.04	80052.43
21	10.75	12.04	61.91	1.50	18.40	10.44	1.04	80925.13
22	10.19	11.89	68.34	1.08	18.32	10.52	1.04	81224.23
23	11.77	11.92	72.09	1.20	18.52	10.52	1.04	81199.15
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	11.01	12.03	55.12	1.13	18.87	10.35	1.04	79453.73
最大值	15.45	13.13	72.09	1.93	20.85	11.58	1.06	82219.16
發生時間	16	3	23	16	5	3		11
最小值	7.57	11.31	36.43	0.47	16.79	9.39	1.01	65785.65
發生時間	6	2	6	5	15	5		3
零點偏移(率)	-0.03 %	-0.04 %	-0.06 %	-0.01 %		-0.12	-0.01	0.00 %
全幅偏移(率)	-0.32 %	2.07 %	0.64 %	0.66 %		-0.29	0.00	0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 115年04月08日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.02	11.73	53.24	1.74	17.63	9.91	1.32	75562.16
1	8.85	11.86	56.28	1.86	18.43	10.15	1.32	73873.35
2	9.30	11.11	57.22	1.83	19.09	9.59	1.31	77049.32
3	9.70	10.93	53.14	1.84	19.54	9.34	1.31	76449.12
4	8.94	11.22	52.03	1.86	19.01	9.48	1.31	76065.81
5	9.51	11.27	55.27	1.90	18.40	9.61	1.31	75978.76
6	9.21	10.95	54.04	1.89	19.22	9.42	1.31	76795.89
7	10.90	11.24	50.72	1.92	19.02	9.56	1.31	75785.76
8	8.60	11.13	52.63	1.74	19.12	9.52	1.31	75087.17
9	9.40	11.34	50.24	1.71	19.11	9.31	1.33	75795.94
10	9.17	11.13	49.14	1.65	18.60	9.40	1.32	75436.87
11	9.38	11.37	48.83	1.60	19.41	9.20	1.31	75347.88
12	9.32	11.35	45.58	1.66	19.01	8.91	1.31	73659.13
13	9.29	11.45	46.89	1.69	18.99	9.05	1.33	74389.20
14	8.64	11.05	42.55	1.49	19.47	8.94	1.33	73658.73
15	10.52	11.27	43.37	1.64	19.31	8.93	1.30	73257.76
16	9.45	12.71	40.78	1.88	20.06	8.48	1.30	74802.20
17	8.70	11.99	37.79	2.15	20.02	7.86	1.30	71574.88
18	9.54	8.59	31.88	2.86	20.80	6.73	1.28	73212.55
19	10.34	16.86	43.74	3.93	20.38	6.49	1.29	72325.44
20	8.64	10.47	61.67	0.54	17.45	8.95	1.31	74168.17
21	10.29	10.45	64.02	0.36	18.40	9.14	1.31	76330.07
22	10.20	10.77	54.60	1.48	18.12	9.13	1.31	77348.55
23	10.52	11.20	57.97	1.72	18.19	9.40	1.31	79046.53
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	9.48	11.39	50.15	1.79	19.03	9.02	1.31	75125.05
最大值	10.90	16.86	64.02	3.93	20.80	10.15	1.35	79046.53
發生時間	7	19	21	19	18	1		23
最小值	8.60	8.59	31.88	0.36	17.45	6.49	1.27	71574.88
發生時間	8	18	18	21	20	19		17
零點偏移(率)	-0.03 %	-0.00 %	-0.03 %	0.00 %		-0.10	-0.01	0.20 %
全幅偏移(率)	-1.15 %	-0.30 %	0.05 %	-0.13 %		0.24	0.04	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								