

P001 樹林焚化廠CEMS系統日報表-A 報表日期: 115年08月19日

報表日期: 115年08月19日

項目 單位 小時\限標	#1-HCl_C ppm	#1-CO_C ppm	#1-NOx_C ppm	#1-SO2_C ppm	#1-H2O %	#1-O2_C %	#1-OPAC %	#1-FLOW_C m3/Hour
0	9.17	11.42	60.91	1.60	18.68	11.01	1.20	74962.34
1	8.23	11.78	66.46	1.57	18.65	11.27	1.20	72792.28
2	10.06	12.68	48.04	1.47	20.68	10.45	1.19	77465.03
3	11.31	11.43	59.06	2.88	17.59	11.09	1.19	76050.62
4	8.72	11.40	59.94	2.88	17.63	11.07	1.19	76005.00
5	13.89	13.23	65.96	3.19	17.00	11.53	1.18	74246.14
6	8.72	12.63	58.10	2.20	18.45	11.04	1.18	74596.07
7	9.76	12.54	62.83	2.05	19.69	10.81	1.18	75297.64
8	9.28	12.42	57.21	2.36	18.71	10.81	1.19	75500.93
9	9.50	12.60	58.29	2.54	18.43	11.00	1.19	74388.94
10	10.08	12.48	57.24	2.15	18.29	10.91	1.18	74901.30
11	9.37	13.82	54.01	3.33	15.59	11.75	1.18	70509.56
12	7.07	13.31	52.13	3.16	16.15	11.77	1.18	69054.72
13	10.43	13.12	51.23	3.02	17.17	11.66	1.18	69968.33
14	10.35	13.24	55.10	3.20	16.75	11.81	1.18	70042.85
15	11.45	13.16	55.76	3.26	16.74	11.75	1.18	70191.62
16	8.03	13.61	52.26	3.05	16.25	11.86	1.18	69753.76
17	11.36	14.13	55.10	3.92	14.94	12.05	1.18	69705.83
18	13.30	13.05	54.21	3.43	16.05	11.59	1.19	72076.42
19	11.40	12.98	50.83	2.68	17.79	11.05	1.18	74500.32
20	8.73	13.01	60.45	3.00	18.64	11.28	1.22	72306.35
21	10.58	13.37	54.27	3.19	18.82	11.00	1.19	73900.62
22	9.24	13.36	52.08	2.76	17.97	11.53	1.19	70536.46
23	8.81	13.61	57.76	1.70	18.43	11.63	1.18	69841.63
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	9.95	12.85	56.63	2.69	17.71	11.32	1.19	72858.12
最 大 值	13.89	14.13	66.46	3.92	20.68	12.05	1.24	77465.03
發生時間	5	17	1	17	2	17		2
最 小 值	7.07	11.40	48.04	1.47	14.94	10.45	1.17	69054.72
發生時間	12	4	2	2	17	2		12
零點偏移(率)	-0.02 %	0.00 %	-0.01 %	-0.06 %		0.01	-0.01	0.20 %
全幅偏移(率)	0.90 %	0.70 %	0.65 %	1.11 %		-0.16	0.00	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A

報表日期: 115年08月19日

項目 單位 小時\限標	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	10.07	11.73	55.28	2.51	18.65	9.81	1.31	73830.69
1	5.14	11.75	63.61	2.32	20.12	10.04	1.31	72481.93
2	9.51	11.51	53.56	2.39	21.47	9.32	1.31	77500.41
3	6.68	11.68	52.37	2.75	19.83	9.68	1.29	74967.02
4	7.55	11.37	58.79	2.72	19.39	9.82	1.27	74090.04
5	6.36	11.32	58.80	2.70	19.28	9.80	1.27	74901.42
6	6.87	11.77	54.85	2.42	18.91	10.00	1.27	76006.83
7	2.74	12.73	58.40	2.23	18.09	10.55	1.29	74738.63
8	6.75	12.59	57.20	2.35	19.36	9.93	1.26	76338.76
9	9.38	11.02	54.14	2.46	19.49	9.55	1.24	75358.49
10	10.24	11.11	61.16	2.89	18.97	9.75	1.24	75677.72
11	9.74	11.09	50.75	2.36	19.36	9.66	1.23	73611.52
12	7.18	10.99	52.93	2.18	18.13	9.74	1.24	75426.12
13	10.64	11.00	47.60	2.12	17.59	9.77	1.26	71926.48
14	7.61	10.77	45.59	2.05	17.21	9.62	1.24	71507.36
15	8.67	10.82	49.56	1.93	17.55	9.52	1.26	72678.10
16	8.76	11.44	50.11	2.03	16.79	9.97	1.27	71556.53
17	5.61	11.29	52.99	1.85	17.53	9.98	1.25	73004.08
18	11.03	11.38	52.20	2.28	17.54	9.98	1.25	73294.06
19	8.97	11.66	53.74	2.19	17.12	9.95	1.23	72173.37
20	10.27	11.79	52.55	2.30	17.56	9.86	1.23	72178.31
21	6.13	11.27	52.00	2.02	20.89	8.99	1.24	76648.50
22	9.68	11.73	40.80	1.54	22.00	8.55	1.27	75695.08
23	8.31	11.55	42.57	1.57	21.54	8.80	1.25	74636.48
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	8.08	11.47	52.98	2.26	18.93	9.69	1.26	74176.16
最 大 值	11.03	12.73	63.61	2.89	22.00	10.55	1.44	77500.41
發生時間	18	7	1	10	22	7		2
最 小 值	2.74	10.77	40.80	1.54	16.79	8.55	1.23	71507.36
發生時間	7	14	22	22	16	22		14
零點偏移(率)	-0.02 %	-0.01 %	-0.03 %	-0.01 %		-0.06	-0.01	0.20 %
全幅偏移(率)	-0.65 %	1.93 %	1.11 %	1.36 %		0.23	0.00	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								