

P001 樹林焚化廠CEMS系統日報表-A 報表日期: 115年09月08日

報表日期: 115年09月08日

項目 單位	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO ₂ _C	#1-H ₂ O	#1-O ₂ _C	#1-OPAC	#1-FLOW_C
小時\限標	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
0	8.50	11.53	57.23	1.86	18.61	11.06	1.18	70272.67
1	9.73	11.40	59.95	2.05	19.14	10.90	1.18	75090.64
2	10.07	11.36	61.89	2.77	18.63	10.75	1.18	76875.77
3	9.24	11.22	56.79	2.44	19.07	10.66	1.18	77254.02
4	10.74	11.15	62.18	2.37	20.08	10.26	1.17	78921.34
5	11.11	12.71	49.34	2.68	19.50	10.69	1.16	74720.17
6	8.92	12.82	58.82	2.35	18.37	11.15	1.18	73408.12
7	10.95	12.79	50.99	2.74	17.81	11.21	1.17	73209.88
8	8.96	12.64	44.93	2.26	18.57	11.00	1.17	73308.40
9	9.48	12.99	50.11	2.17	18.11	11.11	1.18	73020.41
10	10.20	12.78	51.76	2.34	18.06	11.19	1.18	72705.20
11	10.30	12.77	54.47	1.97	18.88	11.10	1.17	73739.74
12	8.97	12.99	57.27	1.66	19.19	11.21	1.18	71719.39
13	10.26	12.67	52.90	1.72	19.50	10.88	1.18	73831.05
14	10.39	12.52	53.14	1.88	19.87	10.74	1.18	73868.21
15	10.92	13.36	60.01	1.78	19.47	11.42	1.18	69711.38
16	9.66	13.10	50.68	1.70	17.23	10.95	1.18	74244.87
17	10.93	12.40	56.77	0.73	15.52	11.83	1.18	69921.60
18	15.42	12.46	55.91	2.10	15.96	11.73	1.18	71114.44
19	10.59	11.82	59.25	2.12	18.01	11.27	1.18	71942.35
20	7.94	11.55	50.05	1.46	18.29	10.90	1.18	74731.23
21	9.09	11.88	59.50	1.41	17.71	11.13	1.18	73825.83
22	10.10	11.33	61.73	1.42	18.22	10.97	1.18	74242.66
23	9.28	11.88	56.47	2.10	18.32	11.00	1.18	73752.19
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	10.07	12.25	55.51	2.00	18.42	11.05	1.18	73559.65
最 大 值	15.42	13.36	62.18	2.77	20.08	11.83	1.19	78921.34
發生時間	18	15	4	2	4	17		4
最 小 值	7.94	11.15	44.93	0.73	15.52	10.26	1.15	69711.38
發生時間	20	4	8	17	17	4		15
零點偏移(率)	-0.19 %	-0.01 %	-0.03 %	0.01 %		-0.03	-0.01	0.20 %
全幅偏移(率)	0.80 %	1.31 %	-0.29 %	-0.76 %		-0.24	0.04	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002 樹林焚化廠CEMS系統日報表-A

報表日期: 115年09月08日

項目 單位 小時\限標	#2-HCl_C ppm	#2-CO_C ppm	#2-NOx_C ppm	#2-SO2_C ppm	#2-H2O %	#2-O2_C %	#2-OPAC %	#2-FLOW_C m3/Hour
0	6.82	12.72	54.36	1.50	18.16	11.09	0.94	82037.47
1	1.77	12.55	54.53	1.18	19.32	10.83	0.94	83320.13
2	5.83	12.41	54.86	0.99	18.64	10.89	0.94	83989.37
3	3.26	13.66	55.96	1.00	18.87	10.74	0.94	84763.67
4	6.65	12.38	55.99	1.40	17.65	11.02	0.94	83667.59
5	4.36	12.17	54.26	1.32	18.30	10.87	0.94	84172.21
6	4.63	12.39	49.26	1.39	18.38	10.88	0.94	86439.51
7	4.04	12.50	61.81	1.50	17.60	11.14	0.96	82012.80
8	7.78	12.37	48.45	1.36	18.04	10.79	0.94	84549.89
9	5.51	12.42	50.31	1.28	18.54	10.92	0.96	82867.57
10	5.98	12.27	42.88	1.53	18.35	10.79	0.96	84344.74
11	7.57	12.42	51.27	0.66	19.14	10.89	0.95	82480.55
12	4.39	12.34	41.77	1.34	17.53	10.98	0.96	83477.21
13	7.88	13.29	45.09	1.20	18.58	10.82	0.97	83287.42
14	4.13	12.80	49.33	1.22	18.49	11.15	0.97	80602.58
15	6.44	12.47	45.24	1.64	17.69	11.08	0.96	82194.71
16	8.38	13.94	48.27	2.63	16.20	11.17	0.95	82835.62
17	7.30	14.13	53.74	2.80	15.02	11.60	0.96	81266.85
18	10.46	14.14	53.98	1.83	17.82	11.41	0.96	79810.18
19	1.47	15.11	56.75	0.65	18.11	12.02	0.95	74608.89
20	7.44	13.16	44.61	1.00	19.44	10.33	0.94	87063.82
21	8.04	13.40	52.05	1.65	18.31	10.70	0.94	84690.85
22	13.47	13.65	56.31	1.77	18.23	10.92	0.94	83295.59
23	5.03	13.00	58.18	1.70	17.85	10.96	0.94	83010.09
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	6.19	12.99	51.64	1.44	18.09	11.00	0.95	82949.55
最 大 值	13.47	15.11	61.81	2.80	19.44	12.02	0.98	87063.82
發生時間	22	19	7	17	20	19		20
最 小 值	1.47	12.17	41.77	0.65	15.02	10.33	0.93	74608.89
發生時間	19	5	12	19	17	20		19
零點偏移(率)	-0.07 %	-0.09 %	-0.07 %	-0.01 %		0.03	-0.01	-0.10 %
全幅偏移(率)	1.22 %	-0.59 %	-0.27 %	-0.24 %		0.25	0.00	0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A 報表日期: 115年09月08日

報表日期: 115年09月08日

[illegible]