

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 115年06月17日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	10.80	12.61	58.30	1.51	19.68	10.63	1.23	84286.31
1	10.46	12.23	60.06	0.91	20.63	10.18	1.23	87100.05
2	9.31	12.76	58.33	1.25	19.47	10.44	1.23	86597.48
3	9.96	12.72	57.34	1.35	17.37	11.17	1.23	82596.77
4	6.67	12.77	60.56	1.24	17.09	11.31	1.24	81624.21
5	11.33	11.48	57.62	1.93	16.69	11.31	1.25	82332.47
6	12.29	11.42	57.95	1.89	16.96	11.22	1.25	82670.81
7	8.04	11.30	62.48	1.75	18.07	10.99	1.25	83350.41
8	10.76	11.93	61.51	1.97	18.77	10.52	1.25	86440.93
9	8.34	13.02	51.83	2.70	17.21	10.87	1.25	85399.05
10	7.70	14.14	56.36	2.42	15.45	11.82	1.25	77547.95
11	10.95	11.98	59.59	2.07	15.54	11.99	1.24	77565.78
12	12.04	11.94	61.69	2.35	16.27	11.43	1.25	80806.16
13	5.79	11.61	53.51	1.67	15.54	11.66	1.24	79911.95
14	7.31	12.23	58.94	1.91	14.25	12.28	1.23	75668.28
15	11.90	12.31	62.78	2.90	15.34	12.05	1.24	76922.80
16	9.93	11.68	55.63	2.35	15.74	11.54	1.25	81407.17
17	9.32	11.44	56.82	1.79	16.78	11.26	1.26	82835.07
18	8.36	11.48	55.83	1.70	17.30	11.08	1.25	83246.98
19	12.86	11.79	57.29	2.17	16.43	11.51	1.25	80454.65
20	10.70	11.76	58.12	2.30	16.50	11.46	1.25	80973.56
21	7.98	11.88	59.45	1.96	16.31	11.47	1.25	81132.13
22	6.68	11.61	58.96	1.85	15.69	11.57	1.25	80990.46
23	8.58	11.41	51.51	2.53	18.19	11.11	1.25	82308.83
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	9.50	12.06	58.02	1.94	16.97	11.29	1.24	81840.43
最大值	12.86	14.14	62.78	2.90	20.63	12.28	1.27	87100.05
發生時間	19	10	15	15	1	14		1
最小值	5.79	11.30	51.51	0.91	14.25	10.18	1.19	75668.28
發生時間	13	7	23	1	14	1		14
零點偏移(率)	0.00 %	-0.07 %	-0.09 %	-0.01 %		-0.02	-0.01	0.10 %
全幅偏移(率)	-2.85 %	-1.57 %	0.48 %	-0.50 %		0.14	-0.06	0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 115年06月17日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	10.63	12.71	41.11	0.91	19.94	10.11	0.92	86525.80
1	5.94	12.25	56.82	1.64	19.40	10.47	0.92	84705.64
2	4.98	12.05	60.41	1.39	19.27	10.53	0.92	85027.08
3	9.52	12.06	50.34	1.23	19.72	10.35	0.92	86315.71
4	6.22	12.28	54.39	1.85	18.07	10.86	0.92	84042.95
5	6.70	12.27	56.67	1.97	17.50	10.96	0.90	83208.56
6	11.09	12.42	44.13	2.13	18.37	10.45	0.92	90251.36
7	5.31	11.94	57.71	1.41	18.62	10.50	0.93	85866.64
8	7.57	11.91	53.96	1.20	19.51	10.36	0.94	85443.61
9	10.84	11.87	52.04	1.35	19.66	10.31	0.94	85918.24
10	5.77	12.29	55.29	1.61	18.06	10.87	0.95	82671.04
11	2.49	12.87	57.53	2.05	16.64	11.44	0.95	79633.86
12	5.79	12.13	54.30	1.13	18.78	10.69	0.95	84016.31
13	10.03	12.88	50.84	2.40	17.36	10.87	0.94	83430.38
14	9.93	13.40	59.49	2.74	16.57	11.87	0.94	78125.32
15	13.61	13.06	55.34	2.62	16.63	11.61	0.94	79092.01
16	13.22	12.42	50.18	2.37	17.69	11.05	0.92	82374.32
17	1.74	12.71	49.79	1.83	17.47	10.94	0.93	84208.93
18	3.22	12.01	53.85	1.08	19.48	10.46	0.94	84679.15
19	15.31	12.52	47.68	3.06	17.75	10.90	0.96	82809.83
20	6.24	12.15	50.01	3.11	17.76	10.78	0.95	84099.75
21	1.80	12.40	62.09	1.36	18.17	10.72	0.94	84333.59
22	7.38	12.34	59.90	2.02	17.45	10.99	0.94	82640.45
23	9.81	11.87	51.97	1.57	18.60	10.48	0.94	85527.81
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	7.71	12.37	53.58	1.83	18.27	10.77	0.93	83956.18
最大值	15.31	13.40	62.09	3.11	19.94	11.87	0.97	90251.36
發生時間	19	14	21	20	0	14		6
最小值	1.74	11.87	41.11	0.91	16.57	10.11	0.90	78125.32
發生時間	17	9	0	0	14	0		14
零點偏移(率)	-0.02 %	-0.01 %	-0.31 %	-0.08 %		-0.01	-0.01	-0.10 %
全幅偏移(率)	0.42 %	-1.86 %	1.12 %	0.26 %		0.07	0.00	0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 115年06月17日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	2.98	11.43	46.30	2.48	21.17	8.96	1.29	74422.16
1	3.61	11.55	40.39	2.31	21.08	8.69	1.30	76151.00
2	6.62	10.86	47.53	3.09	19.11	8.95	1.29	74673.51
3	4.51	10.83	52.56	2.80	18.75	9.30	1.27	72428.05
4	5.61	10.77	52.40	2.66	17.23	9.42	1.27	72147.29
5	13.33	10.97	55.73	3.47	17.09	9.45	1.27	72803.23
6	7.83	11.02	52.84	2.99	16.94	9.47	1.27	73301.40
7	3.44	11.26	59.83	3.09	19.37	9.72	1.27	72116.57
8	5.17	12.26	51.03	3.02	19.39	9.06	1.30	77303.22
9	5.31	10.97	57.87	2.86	18.99	9.46	1.30	75323.30
10	6.65	11.21	61.07	3.00	17.82	9.88	1.29	73619.36
11	7.13	12.01	54.62	3.05	17.87	9.54	1.28	74637.54
12	9.56	11.08	50.87	3.10	18.44	9.18	1.30	75062.74
13	6.81	11.06	52.30	2.89	18.06	8.99	1.32	75682.59
14	8.69	11.24	57.41	2.86	17.83	9.89	1.28	72038.49
15	6.92	11.45	60.70	3.08	17.68	10.12	1.26	70440.01
16	8.69	11.02	55.07	3.31	18.56	9.11	1.26	74705.71
17	10.35	11.26	45.18	3.42	18.15	8.68	1.27	75818.91
18	7.30	12.02	62.81	2.41	18.40	9.33	1.28	77567.67
19	6.62	11.09	64.74	1.33	18.28	9.82	1.31	77067.29
20	12.37	11.08	65.76	1.67	17.37	9.81	1.31	75738.66
21	7.88	10.64	58.70	1.64	17.70	9.32	1.31	74861.60
22	5.53	10.61	59.55	1.35	17.33	9.40	1.31	74754.14
23	12.13	10.75	54.54	1.95	17.79	9.36	1.31	74995.13
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	7.29	11.19	54.99	2.66	18.35	9.37	1.29	74485.82
最大值	13.33	12.26	65.76	3.47	21.17	10.12	1.36	77567.67
發生時間	5	8	20	5	0	15		18
最小值	2.98	10.61	40.39	1.33	16.94	8.68	1.24	70440.01
發生時間	0	22	1	19	6	17		15
零點偏移(率)	-0.06 %	0.01 %	-0.19 %	0.00 %		-0.03	-0.01	-0.10 %
全幅偏移(率)	-1.26 %	-0.42 %	1.07 %	0.03 %		0.37	0.04	-0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								