

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 112年08月03日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.62	9.97	60.73	1.62	17.16	11.77	1.07	77922.43
1	7.72	11.36	54.69	1.93	16.83	11.76	1.07	78746.92
2	4.73	11.40	62.05	1.30	17.34	11.85	1.08	77381.94
3	9.81	11.41	56.07	2.02	16.34	11.83	1.06	78554.36
4	9.21	13.66	52.88	2.34	15.82	11.92	1.05	74916.00
5	8.53	11.31	61.12	1.48	17.75	11.28	1.05	72914.54
6	2.24	12.63	67.00	0.77	18.03	11.73	1.06	71511.86
7	2.29	10.89	51.68	0.79	19.08	10.79	1.07	78585.37
8	7.95	12.09	64.60	1.43	17.95	11.27	1.10	81735.08
9	8.15	12.71	50.27	1.92	16.17	11.74	1.10	77938.35
10	7.89	12.81	58.24	2.23	15.34	12.25	1.10	74118.11
11	10.43	13.63	54.72	2.24	15.49	11.99	1.09	76810.60
12	8.69	9.12	56.88	2.10	15.66	12.03	1.08	77176.78
13	9.08	11.08	56.19	1.21	17.53	11.47	1.08	80497.22
14	7.59	11.76	63.42	1.07	17.81	11.61	1.06	78681.59
15	9.30	12.77	44.39	2.15	16.24	11.86	1.07	78147.56
16	9.14	4.75	58.44	2.30	15.37	12.33	1.07	75001.68
17	11.77	15.50	59.51	2.19	15.42	12.25	1.07	75585.51
18	8.89	7.99	62.60	1.03	17.47	11.74	1.07	78401.00
19	9.37	8.25	47.69	1.42	16.55	11.85	1.12	78141.25
20	10.03	9.06	52.81	1.39	17.28	11.63	1.06	79535.80
21	8.85	8.14	57.15	1.21	17.40	11.69	1.07	78820.87
22	9.96	7.92	63.72	1.20	17.35	11.76	1.07	78383.10
23	8.11	7.81	47.64	1.37	16.93	11.86	1.07	77355.03
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.26	10.75	56.85	1.61	16.85	11.76	1.08	77369.29
最大值	11.77	15.50	67.00	2.34	19.08	12.33	1.30	81735.08
發生時間	17	17	6	4	7	16		8
最小值	2.24	4.75	44.39	0.77	15.34	10.79	1.05	71511.86
發生時間	6	16	15	6	10	7		6
零點偏移(率)	-0.08 %	-0.03 %	-0.11 %	-0.00 %		-0.01		0.00 %
全幅偏移(率)	0.02 %	0.14 %	0.19 %	0.64 %		-0.24		0.40 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 112年08月03日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.11	9.82	39.96	1.20	21.00	9.44	1.15	87469.12
1	7.81	10.87	40.86	1.48	21.80	9.17	1.14	86504.40
2	6.76	9.70	53.01	1.83	18.28	9.73	1.13	81736.20
3	9.55	15.01	48.12	2.02	18.24	9.81	1.13	81558.58
4	10.24	8.18	64.74	1.73	18.62	9.94	1.12	80204.02
5	9.33	8.11	58.27	1.67	18.24	9.91	1.12	82552.68
6	8.83	5.27	55.62	0.73	20.75	9.33	1.15	85325.64
7	9.32	8.36	64.67	1.10	20.72	9.38	1.15	85325.90
8	8.97	6.32	57.77	1.17	19.68	9.56	1.16	85492.16
9	9.58	16.06	48.54	1.57	18.50	9.70	1.15	86166.54
10	10.64	12.06	50.02	2.63	16.85	10.18	1.15	82472.56
11	8.92	4.73	61.85	1.69	17.35	10.19	1.17	83908.68
12	7.45	9.38	53.75	1.28	18.24	10.35	1.21	82235.52
13	9.55	11.16	51.15	1.44	18.27	10.14	1.15	84072.18
14	8.82	9.36	58.05	1.26	18.72	10.27	1.15	82967.05
15	9.85	8.26	48.67	1.36	18.45	10.16	1.15	83971.21
16	9.05	7.30	47.04	1.86	18.29	9.95	1.15	82790.63
17	8.43	4.88	68.53	1.17	18.91	10.49	1.16	78820.69
18	7.72	6.78	64.63	0.73	20.22	9.87	1.15	84216.73
19	8.63	19.83	39.46	1.17	19.59	10.08	1.15	82887.86
20	9.69	8.95	46.53	1.55	18.79	9.93	1.15	85021.20
21	10.18	5.60	52.10	1.07	19.88	9.45	1.15	87302.57
22	8.96	15.00	52.45	1.74	17.76	10.21	1.15	82358.58
23	7.54	6.99	55.45	0.94	19.38	9.89	1.15	81865.90
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.96	9.50	53.38	1.43	19.02	9.88	1.15	83634.44
最大值	10.64	19.83	68.53	2.63	21.80	10.49	1.24	87469.12
發生時間	10	19	17	10	1	17		0
最小值	6.76	4.73	39.46	0.73	16.85	9.17	1.12	78820.69
發生時間	2	11	19	6	10	1		17
零點偏移(率)	-0.07 %	-0.01 %	-0.03 %	-0.00 %		0.00		-0.10 %
全幅偏移(率)	0.00 %	1.21 %	-0.10 %	0.51 %		-0.45		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 112年08月03日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	0.12	10.28	51.85	0.70	18.18	9.99	0.99	75824.14
1	0.56	8.14	48.50	0.95	17.77	9.86	1.01	78718.49
2	1.28	11.97	62.84	0.98	17.54	10.42	0.99	73975.01
3	0.34	14.43	39.59	0.66	17.99	9.33	1.00	76520.53
4	2.86	9.94	25.46	1.29	17.63	8.89	1.01	76872.29
5	6.84	10.47	42.62	1.45	16.42	10.04	1.03	74322.40
6	12.95	9.08	41.62	1.49	16.70	9.81	1.02	77550.34
7	5.86	8.57	62.77	1.97	15.15	10.83	1.03	77515.73
8	13.16	8.57	46.50	2.95	15.11	10.26	1.02	74621.12
9	11.94	7.83	53.33	2.45	15.92	9.69	1.02	80320.20
10	4.19	9.84	51.76	2.26	13.37	10.74	1.00	74892.01
11	2.36	7.90	63.47	0.95	16.54	10.56	1.03	82114.92
12	5.29	12.36	60.10	1.30	16.01	10.69	1.06	84457.93
13	9.66	6.60	58.86	2.03	15.06	11.20	1.06	80088.58
14	2.05	12.21	53.09	0.65	17.71	10.54	1.05	80781.77
15	5.47	12.07	57.10	1.04	17.36	9.83	1.03	86461.28
16	1.85	7.01	64.78	1.73	14.17	11.25	1.03	71397.34
17	0.14	10.57	67.14	1.15	15.42	11.40	1.05	72735.76
18	0.39	13.94	64.19	1.35	14.91	11.81	1.09	74044.00
19	0.00	7.45	53.00	0.93	15.91	11.43	1.08	75813.11
20	0.03	7.33	57.82	0.74	16.67	11.24	1.06	76002.76
21	0.07	8.10	69.50	0.85	16.45	10.87	1.06	75869.15
22	3.82	8.06	66.39	1.38	15.76	11.18	1.08	77439.37
23	4.14	9.15	55.29	1.03	16.40	10.90	1.05	78609.93
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	3.97	9.66	54.90	1.34	16.26	10.53	1.03	77372.84
最大值	13.16	14.43	69.50	2.95	18.18	11.81	1.13	86461.28
發生時間	8	3	21	8	0	18		15
最小值	0.00	6.60	25.46	0.65	13.37	8.89	0.99	71397.34
發生時間	19	13	4	14	10	4		16
零點偏移(率)	0.00 %	-0.01 %	-0.10 %	-0.09 %		-0.02		0.00 %
全幅偏移(率)	0.04 %	1.51 %	0.00 %	0.58 %		-0.17		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								