

P001 樹林焚化廠CEMS系統日報表-A 報表日期: 115年07月06日

報表日期: 115年07月06日

項目 單位 小時\限標	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	7.31	12.80	64.18	0.87	18.86	11.97	1.18	74728.68
1	7.49	12.05	44.70	1.20	18.34	11.49	1.19	78761.62
2	13.84	12.61	47.88	1.69	17.49	12.06	1.20	75137.03
3	3.86	12.12	45.39	1.52	17.85	11.62	1.20	78064.88
4	8.64	11.67	44.22	1.95	17.56	11.28	1.20	81324.19
5	10.78	13.63	64.31	2.27	16.75	12.00	1.19	77880.07
6	11.51	14.09	66.19	2.30	16.50	12.29	1.19	73921.40
7	6.94	12.94	46.26	2.06	17.75	11.12	1.19	82202.51
8	10.73	12.62	61.08	2.04	17.84	11.31	1.19	80921.88
9	6.96	11.49	65.85	1.72	18.09	11.20	1.18	81422.23
10	7.66	11.62	53.44	1.59	17.51	11.21	1.20	81501.01
11	6.90	12.83	48.56	1.72	15.42	12.03	1.21	76639.94
12	6.88	12.13	56.96	2.16	15.44	11.91	1.23	77658.71
13	9.30	11.87	58.76	1.83	17.33	11.58	1.19	78725.46
14	9.80	11.79	55.19	2.08	16.88	11.58	1.18	78781.94
15	8.46	12.51	66.21	1.64	16.47	12.17	1.18	74279.27
16	9.59	13.05	47.79	1.56	16.81	11.68	1.19	78148.08
17	11.11	12.61	54.84	2.23	17.64	11.08	1.19	82481.92
18	5.84	12.70	56.79	1.04	17.75	11.15	1.19	81686.10
19	10.03	12.36	59.20	1.27	20.45	10.36	1.19	85504.81
20	10.52	12.52	53.02	2.14	19.55	10.32	1.19	86786.84
21	9.26	13.05	54.72	2.58	19.01	10.65	1.20	84412.79
22	9.47	13.35	59.58	2.40	17.93	11.58	1.18	77804.26
23	8.85	12.91	58.88	2.12	18.96	11.20	1.19	80058.98
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	8.82	12.56	55.58	1.83	17.67	11.45	1.19	79534.78
最 大 值	13.84	14.09	66.21	2.58	20.45	12.29	1.24	86786.84
發生時間	2	6	15	21	19	6		20
最 小 值	3.86	11.49	44.22	0.87	15.42	10.32	1.18	73921.40
發生時間	3	9	4	0	11	20		6
零點偏移(率)	-0.04 %	-0.02 %	-0.02 %	0.00 %		-0.03	-0.01	0.00 %
全幅偏移(率)	0.64 %	0.51 %	-0.28 %	1.75 %		-0.08	-0.06	0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002 樹林焚化廠CEMS系統日報表-A

報表日期: 115年07月06日

[illegible]

P003 樹林焚化廠CEMS系統日報表-A

報表日期: 115年07月06日

項目 單位 小時\限標	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	4.52	11.12	42.56	3.14	19.86	9.44	1.29	73197.66
1	3.52	11.26	42.54	2.67	22.37	9.17	1.26	73047.31
2	2.56	10.92	37.49	3.00	19.73	9.12	1.25	73810.45
3	3.29	11.06	33.69	2.84	18.77	9.17	1.25	74390.29
4	2.85	10.99	33.36	2.75	18.46	9.15	1.25	74048.66
5	3.49	11.00	36.01	2.91	18.25	9.10	1.27	74522.70
6	3.78	11.18	34.22	2.89	18.32	9.19	1.27	74404.07
7	5.20	11.39	51.30	3.28	18.72	9.47	1.29	74831.40
8	3.33	11.41	49.47	2.32	17.59	9.93	1.29	73294.60
9	7.14	11.76	54.73	1.69	17.10	10.47	1.30	77395.16
10	5.34	12.51	59.60	1.66	16.33	11.09	1.27	72283.53
11	6.84	12.25	61.21	1.64	16.89	10.96	1.25	72863.72
12	5.15	12.04	56.08	1.56	17.16	10.65	1.27	73840.87
13	3.76	10.96	57.61	1.43	18.65	9.53	1.27	72254.07
14	3.36	11.28	52.98	1.38	18.03	9.76	1.27	70900.40
15	2.39	11.06	53.36	2.02	18.18	9.68	1.26	69243.97
16	3.63	12.05	59.48	2.75	17.99	9.75	1.26	72111.06
17	10.90	11.93	58.57	2.99	17.89	9.50	1.26	74758.04
18	5.93	12.33	62.77	3.11	19.07	9.37	1.29	76761.49
19	6.59	12.03	52.95	3.04	20.83	9.00	1.31	78552.22
20	8.69	12.60	44.34	3.14	20.45	8.63	1.30	79255.53
21	9.56	13.20	46.32	3.19	20.81	8.65	1.27	79247.86
22	9.25	12.20	56.40	3.24	18.93	9.50	1.30	76228.36
23	6.05	12.57	56.24	3.12	19.72	9.87	1.31	71193.23
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	5.30	11.71	49.72	2.57	18.75	9.59	1.28	74268.19
最 大 值	10.90	13.20	62.77	3.28	22.37	11.09	1.31	79255.53
發生時間	17	21	18	7	1	10		20
最 小 值	2.39	10.92	33.36	1.38	16.33	8.63	1.23	69243.97
發生時間	15	2	4	14	10	20		15
零點偏移(率)	-0.04 %	0.00 %	-0.03 %	-0.00 %		-0.04	-0.01	-0.10 %
全幅偏移(率)	-1.59 %	-0.79 %	-0.69 %	-0.79 %		0.42	0.00	-0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								