

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 115年06月21日

| 項目 | #1-HCl_C | #1-CO_C | #1-NOx_C | #1-SO2_C | #1-H2O | #1-O2_C | #1-OPAC | #1-FLOW_C |
|---------|----------|----------|----------|----------|----------|----------|----------|-----------|
| 單位 | ppm | ppm | ppm | ppm | % | % | % | m3/Hour |
| 小時\限標 | 60.00 | 150.00 | 220.00 | 150.00 | 100.00 | 25.00 | 10.00 | 999999.00 |
| 0 | 6.39 | 12.32 | 60.58 | 0.89 | 21.08 | 10.37 | 1.25 | 85000.34 |
| 1 | 12.26 | 12.72 | 50.59 | 1.66 | 19.74 | 10.78 | 1.25 | 83778.43 |
| 2 | 8.37 | 13.94 | 49.68 | 1.99 | 19.53 | 10.31 | 1.25 | 87420.83 |
| 3 | 9.93 | 13.16 | 45.76 | 2.75 | 16.89 | 11.51 | 1.25 | 80521.24 |
| 4 | 7.62 | 13.06 | 49.60 | 1.97 | 16.92 | 11.54 | 1.25 | 80154.42 |
| 5 | 11.50 | 11.59 | 45.37 | 1.45 | 17.26 | 11.37 | 1.25 | 78000.27 |
| 6 | 14.57 | 11.68 | 49.21 | 1.73 | 16.82 | 11.22 | 1.26 | 82791.83 |
| 7 | 7.61 | 12.29 | 49.49 | 1.58 | 17.63 | 10.94 | 1.27 | 83798.60 |
| 8 | 13.50 | 12.35 | 48.53 | 2.05 | 17.24 | 11.13 | 1.26 | 82912.70 |
| 9 | 6.34 | 11.80 | 50.48 | 1.85 | 17.13 | 11.27 | 1.25 | 81959.87 |
| 10 | 10.58 | 11.58 | 51.59 | 1.59 | 16.65 | 11.42 | 1.25 | 80588.52 |
| 11 | 11.33 | 11.54 | 48.66 | 2.50 | 16.49 | 11.39 | 1.25 | 81185.42 |
| 12 | 8.42 | 11.69 | 57.39 | 2.33 | 16.95 | 11.49 | 1.25 | 79952.56 |
| 13 | 11.02 | 12.88 | 65.55 | 2.73 | 16.48 | 12.29 | 1.24 | 73436.10 |
| 14 | 10.14 | 12.00 | 52.12 | 2.47 | 17.28 | 11.67 | 1.25 | 77991.97 |
| 15 | 8.59 | 11.87 | 57.49 | 2.64 | 16.98 | 11.62 | 1.25 | 79076.26 |
| 16 | 9.48 | 11.63 | 56.28 | 2.28 | 17.82 | 11.16 | 1.25 | 81699.05 |
| 17 | 14.56 | 11.42 | 55.13 | 2.84 | 17.79 | 10.93 | 1.25 | 84361.05 |
| 18 | 7.61 | 11.17 | 53.45 | 2.51 | 18.10 | 10.86 | 1.25 | 84118.45 |
| 19 | 15.26 | 11.32 | 50.69 | 2.99 | 17.36 | 11.04 | 1.25 | 83241.93 |
| 20 | 8.31 | 11.47 | 52.12 | 2.46 | 17.17 | 11.19 | 1.25 | 82368.28 |
| 21 | 12.72 | 11.40 | 54.33 | 2.65 | 17.47 | 11.15 | 1.25 | 82322.16 |
| 22 | 7.25 | 11.55 | 57.25 | 2.18 | 17.09 | 11.34 | 1.25 | 81445.25 |
| 23 | 14.17 | 11.59 | 53.56 | 2.57 | 16.60 | 11.43 | 1.25 | 80823.80 |
| 監測時數 | 24 | 24 | 24 | 24 | 24 | 24 | 24 | 24 |
| 超限次數 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 有效時數 | 24 | 24 | 24 | 24 | 24 | 24 | 24 | 24 |
| 平均值 | 10.31 | 12.00 | 52.70 | 2.19 | 17.52 | 11.23 | 1.25 | 81622.89 |
| 最大值 | 15.26 | 13.94 | 65.55 | 2.99 | 21.08 | 12.29 | 1.28 | 87420.83 |
| 發生時間 | 19 | 2 | 13 | 19 | 0 | 13 | | 2 |
| 最小值 | 6.34 | 11.17 | 45.37 | 0.89 | 16.48 | 10.31 | 1.23 | 73436.10 |
| 發生時間 | 9 | 18 | 5 | 0 | 13 | 2 | | 13 |
| 零點偏移(率) | -0.06 % | -0.01 % | -0.18 % | -0.00 % | | 0.00 | -0.01 | 0.20 % |
| 全幅偏移(率) | 0.04 % | 0.03 % | -0.27 % | -0.21 % | | -0.11 | -0.06 | 0.10 % |
| 有效比率 | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % |
| 備註 | | | | | | | | |

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 115年06月21日

| 項目 | #2-HCl_C | #2-CO_C | #2-NOx_C | #2-SO2_C | #2-H2O | #2-O2_C | #2-OPAC | #2-FLOW_C |
|---------|----------|----------|----------|----------|----------|----------|----------|-----------|
| 單位 | ppm | ppm | ppm | ppm | % | % | % | m3/Hour |
| 小時\限標 | 60.00 | 150.00 | 220.00 | 150.00 | 100.00 | 25.00 | 10.00 | 999999.00 |
| 0 | 8.68 | 12.17 | 51.82 | 0.71 | 21.05 | 9.72 | 1.01 | 87914.29 |
| 1 | 10.84 | 12.12 | 59.45 | 1.33 | 20.44 | 10.41 | 1.02 | 84017.18 |
| 2 | 7.19 | 12.36 | 48.46 | 1.58 | 18.98 | 10.78 | 1.02 | 83418.43 |
| 3 | 9.26 | 13.29 | 52.61 | 1.28 | 19.62 | 10.51 | 1.01 | 85078.35 |
| 4 | 13.02 | 12.25 | 46.96 | 2.07 | 20.12 | 10.04 | 0.99 | 88245.83 |
| 5 | 5.43 | 12.05 | 56.61 | 2.32 | 18.92 | 10.54 | 0.99 | 84695.79 |
| 6 | 14.61 | 12.57 | 58.06 | 3.08 | 18.51 | 10.48 | 1.02 | 82177.91 |
| 7 | 7.79 | 12.49 | 52.54 | 1.90 | 19.12 | 10.88 | 1.03 | 82057.39 |
| 8 | 15.19 | 12.25 | 42.33 | 2.40 | 19.10 | 10.56 | 1.04 | 84850.99 |
| 9 | 8.83 | 12.85 | 52.64 | 2.80 | 19.14 | 10.44 | 1.03 | 85051.38 |
| 10 | 8.85 | 11.94 | 46.80 | 0.83 | 18.66 | 10.69 | 1.03 | 83695.70 |
| 11 | 7.25 | 13.69 | 47.08 | 1.83 | 19.51 | 10.63 | 1.03 | 83430.14 |
| 12 | 8.88 | 12.50 | 48.78 | 1.14 | 19.36 | 10.91 | 1.02 | 81132.24 |
| 13 | 11.19 | 12.27 | 45.74 | 1.54 | 19.49 | 10.67 | 1.03 | 82841.68 |
| 14 | 12.84 | 12.09 | 36.47 | 2.41 | 19.34 | 10.51 | 1.05 | 84127.34 |
| 15 | 8.55 | 12.08 | 50.11 | 2.20 | 18.81 | 10.61 | 1.04 | 83753.11 |
| 16 | 10.50 | 12.44 | 49.08 | 1.24 | 19.93 | 10.77 | 1.02 | 81994.81 |
| 17 | 3.96 | 13.44 | 54.85 | 0.81 | 19.43 | 11.53 | 1.03 | 76095.62 |
| 18 | 10.83 | 13.78 | 52.28 | 2.10 | 19.18 | 11.10 | 1.03 | 79160.73 |
| 19 | 16.69 | 11.77 | 44.52 | 2.37 | 19.75 | 10.16 | 1.02 | 86489.70 |
| 20 | 11.62 | 11.80 | 42.24 | 2.52 | 19.33 | 10.05 | 1.02 | 87271.81 |
| 21 | 8.51 | 12.60 | 47.82 | 1.78 | 19.70 | 10.15 | 1.02 | 85916.91 |
| 22 | 5.38 | 12.54 | 50.85 | 1.53 | 18.14 | 10.78 | 1.02 | 83138.56 |
| 23 | 11.20 | 12.26 | 56.47 | 1.85 | 18.19 | 10.71 | 1.02 | 83163.79 |
| 監測時數 | 24 | 24 | 24 | 24 | 24 | 24 | 24 | 24 |
| 超限次數 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 有效時數 | 24 | 24 | 24 | 24 | 24 | 24 | 24 | 24 |
| 平均值 | 9.88 | 12.48 | 49.77 | 1.82 | 19.33 | 10.57 | 1.02 | 83738.32 |
| 最大值 | 16.69 | 13.78 | 59.45 | 3.08 | 21.05 | 11.53 | 1.08 | 88245.83 |
| 發生時間 | 19 | 18 | 1 | 6 | 0 | 17 | | 4 |
| 最小值 | 3.96 | 11.77 | 36.47 | 0.71 | 18.14 | 9.72 | 0.98 | 76095.62 |
| 發生時間 | 17 | 19 | 14 | 0 | 22 | 0 | | 17 |
| 零點偏移(率) | -0.13 % | -0.05 % | -0.04 % | -0.01 % | | -0.02 | -0.01 | -0.10 % |
| 全幅偏移(率) | -1.78 % | -2.49 % | 1.17 % | 0.35 % | | 0.09 | 0.00 | 0.00 % |
| 有效比率 | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % |
| 備註 | | | | | | | | |

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 115年06月21日

| 項目 | #3-HCl_C | #3-CO_C | #3-NOx_C | #3-SO2_C | #3-H2O | #3-O2_C | #3-OPAC | #3-FLOW_C |
|---------|----------|----------|----------|----------|----------|----------|----------|-----------|
| 單位 | ppm | ppm | ppm | ppm | % | % | % | m3/Hour |
| 小時\限標 | 60.00 | 150.00 | 220.00 | 150.00 | 100.00 | 25.00 | 10.00 | 999999.00 |
| 0 | 10.76 | 10.93 | 55.23 | 2.14 | 19.55 | 9.16 | 1.30 | 75620.75 |
| 1 | 6.53 | 11.15 | 59.40 | 1.47 | 21.53 | 9.14 | 1.29 | 74742.98 |
| 2 | 8.66 | 10.82 | 52.45 | 1.62 | 19.92 | 9.18 | 1.31 | 75053.82 |
| 3 | 3.68 | 10.89 | 59.45 | 1.57 | 19.26 | 9.44 | 1.32 | 74659.85 |
| 4 | 4.22 | 11.04 | 58.11 | 1.45 | 18.36 | 9.72 | 1.36 | 74233.95 |
| 5 | 3.14 | 10.96 | 61.42 | 1.47 | 18.67 | 9.39 | 1.35 | 75589.25 |
| 6 | 7.92 | 10.95 | 60.24 | 1.76 | 17.95 | 9.63 | 1.36 | 75340.24 |
| 7 | 5.56 | 12.13 | 62.53 | 1.62 | 18.06 | 9.61 | 1.32 | 72677.33 |
| 8 | 7.99 | 12.08 | 57.56 | 1.54 | 17.60 | 9.77 | 1.34 | 73019.46 |
| 9 | 4.38 | 11.88 | 56.04 | 1.40 | 17.65 | 9.56 | 1.31 | 73894.06 |
| 10 | 7.93 | 12.00 | 55.52 | 1.59 | 18.25 | 9.15 | 1.33 | 76494.99 |
| 11 | 6.99 | 11.15 | 60.86 | 2.49 | 18.17 | 9.43 | 1.31 | 74763.58 |
| 12 | 4.78 | 10.90 | 51.15 | 2.77 | 19.32 | 9.04 | 1.33 | 75007.69 |
| 13 | 6.79 | 11.40 | 43.04 | 2.87 | 19.03 | 8.77 | 1.29 | 74797.33 |
| 14 | 6.48 | 11.31 | 40.34 | 2.64 | 19.03 | 8.83 | 1.29 | 74118.60 |
| 15 | 4.95 | 11.60 | 40.59 | 2.71 | 19.08 | 8.81 | 1.27 | 73255.50 |
| 16 | 3.82 | 11.38 | 41.28 | 2.64 | 19.57 | 8.68 | 1.30 | 74892.02 |
| 17 | 7.00 | 10.90 | 44.69 | 2.78 | 18.85 | 8.99 | 1.31 | 74864.77 |
| 18 | 4.65 | 10.73 | 46.67 | 2.64 | 18.31 | 9.10 | 1.31 | 74243.56 |
| 19 | 4.74 | 11.01 | 45.91 | 2.74 | 18.99 | 8.83 | 1.29 | 75059.86 |
| 20 | 6.41 | 10.80 | 49.31 | 2.96 | 19.02 | 8.80 | 1.28 | 75395.05 |
| 21 | 5.60 | 11.48 | 43.49 | 2.85 | 18.50 | 8.86 | 1.31 | 75359.00 |
| 22 | 8.67 | 11.38 | 40.09 | 3.19 | 19.48 | 8.33 | 1.29 | 76162.93 |
| 23 | 3.56 | 11.09 | 41.82 | 2.63 | 19.18 | 8.78 | 1.29 | 72945.37 |
| 監測時數 | 24 | 24 | 24 | 24 | 24 | 24 | 24 | 24 |
| 超限次數 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 有效時數 | 24 | 24 | 24 | 24 | 24 | 24 | 24 | 24 |
| 平均值 | 6.05 | 11.25 | 51.13 | 2.23 | 18.89 | 9.13 | 1.31 | 74674.66 |
| 最大值 | 10.76 | 12.13 | 62.53 | 3.19 | 21.53 | 9.77 | 1.36 | 76494.99 |
| 發生時間 | 0 | 7 | 7 | 22 | 1 | 8 | | 10 |
| 最小值 | 3.14 | 10.73 | 40.09 | 1.40 | 17.60 | 8.33 | 1.27 | 72677.33 |
| 發生時間 | 5 | 18 | 22 | 9 | 8 | 22 | | 7 |
| 零點偏移(率) | -0.04 % | 0.00 % | -0.01 % | -0.00 % | | -0.03 | -0.01 | -0.20 % |
| 全幅偏移(率) | -2.55 % | -0.01 % | 0.71 % | 0.32 % | | 0.39 | 0.04 | -0.20 % |
| 有效比率 | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % |
| 備註 | | | | | | | | |