

## P001\_樹林焚化廠CEMS系統日報表-A

報表日期: 113年03月30日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	4.74	4.53	54.13	1.38	16.64	12.01	1.03	77696.55
1	7.02	4.67	53.89	1.59	18.89	11.14	1.02	83315.07
2	7.75	4.61	58.22	0.99	18.50	11.31	1.02	82266.77
3	8.35	4.89	52.52	1.08	17.27	11.85	1.01	79083.07
4	5.50	4.95	59.78	1.46	16.38	12.31	1.02	74824.95
5	0.15	9.97	60.60	2.94	13.90	14.38	1.10	69994.22
6	0.63	4.68	47.29	2.01	15.60	12.50	1.05	74770.36
7	9.12	5.03	43.13	2.53	16.01	11.41	1.02	83508.65
8	10.70	8.05	42.71	4.02	13.65	11.87	1.03	79792.94
9	9.42	5.65	47.03	3.61	14.10	11.84	1.07	79603.63
10	4.57	7.72	49.10	3.94	12.90	12.14	1.04	75998.54
11	3.05	3.85	53.39	3.20	14.71	11.87	1.06	77017.74
12	7.75	2.96	63.37	2.69	15.22	11.77	1.06	79040.52
13	9.37	5.31	54.64	3.17	14.55	11.68	1.04	78932.70
14	9.78	4.38	52.82	2.85	15.15	11.70	1.04	79266.46
15	9.79	4.67	63.67	2.31	15.41	11.83	1.05	77769.34
16	9.19	3.90	50.03	1.91	16.31	11.72	1.06	79654.38
17	12.52	4.02	47.94	2.10	15.97	11.66	1.05	81027.12
18	7.77	4.03	43.92	2.21	15.11	11.90	1.06	79155.95
19	6.51	5.17	40.62	2.19	14.61	11.97	1.05	78442.61
20	5.34	4.43	45.83	1.98	14.92	11.92	1.04	78778.52
21	4.31	3.11	59.09	1.05	15.75	11.77	1.05	79142.87
22	7.12	3.32	59.41	0.95	16.58	11.24	1.06	83449.03
23	8.63	3.73	46.07	2.13	15.43	11.63	1.06	81875.17
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	7.05	4.90	52.05	2.26	15.57	11.89	1.04	78933.63
最大值	12.52	9.97	63.67	4.02	18.89	14.38	1.24	83508.65
發生時間	17	5	15	8	1	5		7
最小值	0.15	2.96	40.62	0.95	12.90	11.14	0.99	69994.22
發生時間	5	12	19	22	10	1		5
零點偏移(率)	-0.06 %	-0.09 %	-0.08 %	-0.01 %		0.01		0.10 %
全幅偏移(率)	0.00 %	-0.02 %	0.09 %	0.28 %		-0.05		0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002\_樹林焚化廠CEMS系統日報表-A

報表日期: 113年03月30日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	5.06	3.83	44.58	2.25	15.01	11.77	1.02	76355.40
1	6.41	3.72	55.17	2.08	17.81	11.53	1.02	75465.13
2	7.46	4.11	45.95	2.00	18.57	10.78	1.00	81039.12
3	6.80	3.44	54.18	1.98	16.84	11.68	0.99	75597.14
4	5.29	4.13	55.89	2.28	16.57	11.75	0.99	75120.44
5	6.33	3.91	51.71	1.90	17.64	11.61	1.00	75488.61
6	3.75	3.77	63.71	1.46	17.81	11.33	1.03	75960.99
7	7.22	3.10	43.44	3.07	15.23	11.19	1.02	80848.55
8	9.15	2.33	47.47	3.12	13.69	11.92	1.02	76114.06
9	5.19	2.26	51.24	3.43	13.40	12.07	1.04	75751.39
10	6.93	5.59	47.06	3.77	12.65	12.11	1.04	75089.69
11	5.15	1.73	50.94	2.73	14.88	11.55	1.05	77060.11
12	13.99	5.74	53.63	3.55	14.80	11.41	1.03	78944.75
13	11.32	5.11	51.02	1.53	12.49	11.80	1.05	77090.14
14	12.27	3.94	61.36	1.53	13.14	11.97	1.07	75402.38
15	12.70	3.72	57.27	2.00	14.61	11.72	1.07	76500.41
16	2.85	1.97	59.85	5.18	15.22	11.42	1.06	78446.19
17	8.14	2.02	47.14	2.12	15.52	11.55	1.06	76621.38
18	9.42	2.09	47.73	1.79	16.40	11.43	1.05	77157.19
19	5.30	2.23	41.07	2.52	14.73	11.55	1.04	77273.13
20	0.27	2.20	46.09	1.81	14.34	11.92	1.04	74571.20
21	3.05	2.01	52.93	1.82	15.32	11.79	1.02	75658.64
22	3.83	2.09	56.57	1.62	16.33	11.49	1.02	77163.75
23	2.20	2.43	57.48	2.41	15.11	12.04	1.03	73466.66
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	6.67	3.23	51.81	2.41	15.34	11.64	1.03	76591.10
最大值	13.99	5.74	63.71	5.18	18.57	12.11	1.10	81039.12
發生時間	12	12	6	16	2	10		2
最小值	0.27	1.73	41.07	1.46	12.49	10.78	0.99	73466.66
發生時間	20	11	19	6	13	2		23
零點偏移(率)	-0.06 %	-0.01 %	-0.03 %	-0.01 %		-0.03		-0.10 %
全幅偏移(率)	0.14 %	0.57 %	0.10 %	-0.16 %		-0.29		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003\_樹林焚化廠CEMS系統日報表-A

報表日期: 113年03月30日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	2.80	3.63	56.82	0.65	16.54	10.52	1.02	78100.77
1	5.58	3.96	52.68	0.84	17.65	10.35	1.01	80960.44
2	5.53	5.26	61.13	0.64	17.68	10.34	1.01	81166.58
3	7.50	4.03	48.92	0.67	16.89	10.39	1.01	78800.78
4	5.41	4.35	49.34	0.54	17.23	10.31	1.01	79711.76
5	5.07	4.56	43.05	0.71	16.79	10.25	1.01	80317.62
6	4.13	4.48	48.47	0.75	15.97	10.42	1.01	78837.49
7	8.98	3.33	53.75	2.30	13.99	10.87	1.02	79109.73
8	7.88	3.77	61.39	2.15	13.89	11.05	1.04	77901.28
9	8.87	4.85	58.60	2.47	13.71	11.17	1.04	77471.91
10	8.96	3.16	58.67	2.82	13.16	11.28	1.04	76508.01
11	8.64	2.55	58.79	2.45	13.51	11.13	1.03	76295.80
12	9.09	4.86	60.10	1.83	14.65	10.91	1.04	78168.71
13	11.28	6.79	63.16	2.06	14.76	10.96	1.04	77596.30
14	13.23	5.40	62.64	2.70	14.93	11.01	1.04	77020.97
15	12.23	3.88	47.03	3.89	14.35	10.57	1.04	77624.74
16	1.14	1.65	42.42	1.96	14.94	10.97	1.04	77453.17
17	2.57	1.38	46.36	0.69	16.88	10.42	1.04	80545.65
18	1.60	1.44	41.99	0.55	17.20	10.16	1.04	80494.59
19	3.65	1.54	37.26	0.74	16.06	10.60	1.02	78242.34
20	6.76	2.31	45.41	1.47	15.04	11.08	1.02	77191.60
21	7.03	1.87	41.40	1.65	14.66	11.00	1.03	76765.61
22	7.39	1.43	44.74	1.15	15.93	10.79	1.03	77406.84
23	3.71	1.49	47.22	0.76	16.59	10.75	1.04	77930.41
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	6.63	3.42	51.31	1.52	15.54	10.72	1.03	78400.96
最大值	13.23	6.79	63.16	3.89	17.68	11.28	1.05	81166.58
發生時間	14	13	13	15	2	10		2
最小值	1.14	1.38	37.26	0.54	13.16	10.16	0.99	76295.80
發生時間	16	17	19	4	10	18		11
零點偏移(率)	-0.02 %	-0.08 %	-0.05 %	-0.01 %		0.00		0.00 %
全幅偏移(率)	6.12 %	0.78 %	10.80 %	-0.14 %		0.03		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								