

P001 樹林焚化廠CEMS系統日報表-A 報表日期: 114年10月06日

報表日期: 114年10月06日

項目 單位 小時\限標	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO ₂ _C	#1-H ₂ O	#1-O ₂ _C	#1-OPAC	#1-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	7.56	15.15	47.24	3.30	15.68	11.39	1.18	78737.57
1	7.20	14.62	62.64	3.32	15.88	12.52	1.18	70454.18
2	5.12	13.01	59.52	3.44	15.29	12.33	1.19	74245.83
3	13.44	11.69	56.46	2.95	15.57	11.50	1.18	80821.19
4	9.89	12.59	58.12	2.63	15.46	11.59	1.17	78935.53
5	4.11	11.43	59.66	2.52	12.73	11.47	1.16	77051.36
6	5.66	12.55	57.33	2.14	13.62	12.33	1.18	71358.89
7	4.85	12.77	53.40	2.61	15.23	12.24	1.19	74174.00
8	13.25	12.71	62.16	4.24	15.63	11.63	1.19	79401.37
9	8.17	12.68	52.07	3.79	15.15	12.30	1.18	74050.85
10	11.04	12.88	53.74	3.57	15.09	11.58	1.18	79901.89
11	7.38	12.11	54.11	4.19	14.40	11.97	1.18	75611.42
12	8.93	12.42	58.32	4.57	13.92	11.91	1.18	76285.27
13	7.26	12.73	59.19	3.68	14.61	12.38	1.18	72586.05
14	6.55	11.79	51.25	3.14	15.56	11.58	1.17	77917.32
15	3.05	12.62	57.22	2.81	15.45	12.17	1.18	73091.36
16	9.36	12.38	52.02	2.78	16.36	11.45	1.18	78432.34
17	8.94	13.41	63.25	2.06	16.24	11.76	1.18	76213.86
18	7.19	13.07	68.09	1.81	16.17	11.56	1.18	77219.46
19	10.89	13.66	47.89	2.05	15.59	11.48	1.18	78451.21
20	11.12	12.79	42.10	2.08	15.92	11.08	1.17	81548.11
21	10.37	13.54	51.37	2.40	15.47	11.38	1.15	79539.94
22	8.98	13.27	60.40	1.73	16.48	11.25	1.18	79632.48
23	5.84	12.72	57.17	2.00	17.04	11.12	1.18	80467.33
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	8.17	12.86	56.03	2.91	15.36	11.75	1.18	76922.03
最 大 值	13.44	15.15	68.09	4.57	17.04	12.52	1.20	81548.11
發生時間	3	0	18	12	23	1		20
最 小 值	3.05	11.43	42.10	1.73	12.73	11.08	1.15	70454.18
發生時間	15	5	20	22	5	20		1
零點偏移(率)	-0.07 %	-0.01 %	-0.14 %	0.01 %		0.03		0.20 %
全幅偏移(率)	0.34 %	0.69 %	-0.19 %	-0.12 %		0.07		0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A

報表日期: 114年10月06日

項目 單位 小時\限標	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.00	14.02	56.36	0.84	16.04	10.30	1.35	75238.27
1	9.01	13.62	56.55	1.35	17.24	10.26	1.34	75550.77
2	14.36	12.44	57.13	2.79	17.00	9.79	1.37	78061.94
3	5.82	12.97	54.45	0.63	17.81	9.81	1.39	79872.92
4	8.64	12.57	53.58	1.02	16.58	10.04	1.40	79646.68
5	9.78	12.82	54.57	1.27	17.16	9.75	1.39	79247.57
6	5.24	12.45	59.97	0.53	18.20	9.73	1.41	78077.45
7	10.53	12.90	42.79	0.99	19.07	9.29	1.40	81961.29
8	6.54	13.59	54.58	0.51	18.54	9.86	1.41	76865.91
9	7.24	16.42	49.21	1.04	18.40	9.09	1.40	81707.16
10	10.06	9.98	60.59	2.06	15.89	9.86	1.38	77137.48
11	12.21	12.23	63.52	2.16	15.45	10.00	1.41	75782.39
12	5.27	12.53	57.88	0.88	16.06	10.12	1.35	71240.15
13	7.16	12.90	63.94	0.64	16.66	10.31	1.35	71572.98
14	8.36	12.24	55.79	0.73	17.53	9.64	1.35	76088.99
15	8.55	13.64	52.59	0.79	17.36	9.41	1.36	77021.55
16	10.37	12.33	51.34	0.67	17.32	9.47	1.37	81072.10
17	8.32	13.35	51.66	0.58	17.72	9.42	1.38	79542.49
18	10.11	13.89	56.17	0.62	17.65	9.85	1.36	78738.16
19	8.39	13.39	54.66	0.62	17.76	9.82	1.37	80386.02
20	12.23	12.36	56.84	0.98	18.54	9.49	1.43	82744.72
21	8.68	12.48	56.33	0.67	18.95	9.43	1.40	81127.80
22	9.40	14.34	47.34	0.55	19.47	9.11	1.37	84165.89
23	7.53	13.39	48.55	0.48	17.65	9.81	1.36	79587.91
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	8.82	13.04	54.85	0.98	17.50	9.74	1.38	78434.94
最 大 值	14.36	16.42	63.94	2.79	19.47	10.31	1.44	84165.89
發生時間	2	9	13	2	22	13		22
最 小 值	5.24	9.98	42.79	0.48	15.45	9.09	1.34	71240.15
發生時間	6	10	7	23	11	9		12
零點偏移(率)	-0.08 %	0.00 %	-0.05 %	-0.01 %		-0.03		0.10 %
全幅偏移(率)	0.99 %	0.69 %	0.09 %	0.86 %		0.35		0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								