

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 112年10月10日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	4.62	8.36	60.29	0.96	19.40	11.39	1.01	72146.79
1	3.87	10.32	67.47	1.24	19.06	11.95	1.00	68389.34
2	9.38	7.51	60.39	1.38	18.97	11.04	0.99	75719.91
3	8.48	8.47	65.97	1.27	18.42	11.46	0.99	72974.69
4	7.19	9.19	61.16	1.23	18.39	11.61	0.98	72035.24
5	8.48	10.66	59.68	1.39	18.40	11.32	1.02	76786.86
6	7.51	10.38	62.04	1.03	19.01	11.16	1.02	74850.04
7	8.12	7.87	56.97	1.16	18.61	11.20	1.02	75258.75
8	6.05	7.67	58.16	1.17	17.70	11.45	1.03	74216.18
9	6.88	7.73	57.35	1.17	18.11	11.29	1.04	75095.65
10	8.82	8.51	48.53	1.94	16.72	11.48	1.05	74074.49
11	8.44	8.00	62.94	1.39	17.67	11.55	1.07	73326.11
12	8.62	7.74	43.97	1.51	16.98	11.58	1.06	73686.25
13	8.07	7.89	61.97	1.38	17.47	11.50	1.05	74130.64
14	9.53	7.92	48.88	1.93	16.61	11.69	1.05	73357.27
15	6.63	7.57	59.71	1.64	17.30	11.59	1.07	73884.24
16	7.17	7.63	52.80	1.83	16.30	11.72	1.07	73560.08
17	4.86	8.38	62.90	1.59	16.32	12.25	1.09	69407.31
18	0.31	9.10	59.70	1.09	18.08	11.72	1.09	72585.72
19	0.69	8.12	60.71	0.85	18.28	11.53	1.06	74160.21
20	2.93	7.41	52.07	1.51	17.44	11.30	1.05	76678.30
21	4.80	7.56	60.05	1.26	17.97	11.44	1.05	74549.11
22	6.17	8.19	46.12	0.95	19.40	11.01	1.05	76181.14
23	7.82	7.60	58.58	0.78	20.07	10.63	1.05	77924.20
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	6.48	8.32	57.85	1.32	18.03	11.45	1.04	73957.44
最大值	9.53	10.66	67.47	1.94	20.07	12.25	1.13	77924.20
發生時間	14	5	1	10	23	17		23
最小值	0.31	7.41	43.97	0.78	16.30	10.63	0.97	68389.34
發生時間	18	20	12	23	16	23		1
零點偏移(率)	-0.01 %	-0.01 %	-0.01 %	-0.00 %		0.02		0.00 %
全幅偏移(率)	0.02 %	0.24 %	-0.17 %	0.17 %		0.17		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 112年10月10日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.12	4.11	49.48	1.64	19.62	9.86	1.05	85569.98
1	6.87	12.65	51.35	1.54	19.47	9.57	1.05	88727.33
2	8.62	4.45	63.31	1.41	19.40	10.41	1.05	82380.04
3	7.58	3.68	60.37	1.49	18.83	9.82	1.05	87634.63
4	8.02	6.53	53.66	2.96	16.43	10.37	1.07	86167.96
5	7.11	2.85	57.93	2.18	17.49	10.36	1.07	85762.18
6	4.90	5.62	57.92	2.02	17.35	10.18	1.07	88507.14
7	4.21	5.75	57.71	1.76	17.22	10.53	1.07	83835.38
8	6.16	5.59	53.10	1.79	17.56	10.07	1.07	87733.74
9	8.20	3.63	56.36	2.02	16.83	10.30	1.06	85555.87
10	8.82	3.48	55.51	1.67	17.27	10.37	1.06	85128.42
11	6.93	6.91	57.44	2.96	15.13	10.71	1.04	84149.21
12	7.91	1.98	55.36	3.16	15.01	10.61	1.03	85179.74
13	8.67	3.95	56.16	2.47	16.67	10.27	1.04	86956.71
14	7.61	4.37	56.54	2.27	17.25	10.38	1.05	84768.81
15	9.26	10.76	53.58	2.75	15.71	10.74	1.05	83577.36
16	8.41	1.54	56.83	2.41	16.38	10.63	1.05	84014.41
17	7.55	2.17	54.19	1.81	17.21	10.72	1.05	82098.97
18	7.32	3.86	52.36	1.87	17.23	10.34	1.05	85512.37
19	5.24	3.17	60.95	1.51	17.25	10.48	1.06	84354.94
20	3.73	4.21	45.83	2.39	16.37	10.46	1.06	85413.79
21	5.81	3.52	55.46	1.30	17.87	10.23	1.07	85128.60
22	4.49	3.26	46.78	1.13	18.75	10.44	1.07	82484.33
23	3.67	4.94	47.96	1.99	18.27	9.98	1.07	86828.42
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	6.88	4.71	54.84	2.02	17.36	10.33	1.06	85311.26
最大值	9.26	12.65	63.31	3.16	19.62	10.74	1.07	88727.33
發生時間	15	1	2	12	0	15		1
最小值	3.67	1.54	45.83	1.13	15.01	9.57	1.02	82098.97
發生時間	23	16	20	22	12	1		17
零點偏移(率)	-0.17 %	-0.01 %	-0.01 %	0.00 %		0.03		-0.20 %
全幅偏移(率)	-0.12 %	1.52 %	0.27 %	0.17 %		0.38		-0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 112年10月10日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	6.83	4.60	59.40	1.17	17.83	10.65	0.97	83364.55
1	5.15	5.42	48.28	1.41	17.34	10.85	0.97	80216.90
2	8.59	4.90	50.62	1.88	16.14	10.67	0.96	80441.42
3	7.44	4.87	49.44	1.75	16.31	10.71	0.97	81190.01
4	8.20	7.52	49.51	1.67	17.11	10.37	0.98	83068.65
5	3.78	4.49	52.10	1.44	16.28	10.85	0.97	78392.91
6	7.13	9.52	51.87	1.91	15.44	10.84	0.97	80044.72
7	8.26	9.07	50.03	1.37	16.68	10.58	0.95	80346.66
8	4.73	9.94	52.25	1.52	16.19	10.58	0.95	81941.39
9	7.33	3.78	50.88	1.77	15.36	10.79	0.95	79000.97
10	3.48	5.07	45.09	2.57	14.01	10.91	0.94	74578.19
11	0.80	10.07	48.13	2.21	13.81	11.59	0.94	67074.79
12	0.20	4.30	48.42	1.74	14.46	11.39	0.95	69448.09
13	2.51	5.21	44.18	1.69	14.60	10.64	0.94	72319.65
14	3.60	5.35	41.83	1.57	15.09	10.48	0.94	73624.93
15	5.44	7.96	42.09	1.91	14.38	10.59	0.97	73484.02
16	7.66	9.95	35.29	2.18	15.30	10.00	0.94	72233.44
17	6.35	4.55	37.47	1.24	17.90	9.42	0.94	77105.90
18	7.12	3.83	38.60	1.42	17.62	9.70	0.94	80556.78
19	4.98	8.83	36.63	1.18	16.33	10.11	0.94	78693.58
20	6.64	5.42	49.61	1.47	16.19	10.43	0.94	78092.70
21	8.01	6.20	51.16	1.53	16.24	10.44	0.95	77779.71
22	9.02	6.25	47.70	1.46	16.19	10.40	0.94	77623.03
23	7.25	5.54	49.60	1.14	17.70	10.27	0.94	78620.64
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	5.85	6.36	47.09	1.63	16.02	10.55	0.95	77468.48
最大值	9.02	10.07	59.40	2.57	17.90	11.59	0.99	83364.55
發生時間	22	11	0	10	17	11		0
最小值	0.20	3.78	35.29	1.14	13.81	9.42	0.92	67074.79
發生時間	12	9	16	23	11	17		11
零點偏移(率)	-0.02 %	0.00 %	-0.14 %	0.00 %		0.02		0.00 %
全幅偏移(率)	0.04 %	0.04 %	-0.43 %	0.03 %		0.41		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								