

P001 樹林焚化廠CEMS系統日報表-A 報表日期: 114年10月11日

報表日期: 114年10月11日

項目 單位 小時\限標	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.32	13.51	54.20	2.07	16.95	11.73	1.20	74852.33
1	8.85	12.88	42.64	2.50	18.12	11.10	1.20	81298.21
2	8.85	13.12	56.73	2.83	17.79	11.35	1.22	78105.65
3	9.37	12.97	46.17	3.27	15.80	11.46	1.22	77557.74
4	10.49	12.98	54.51	2.97	16.94	11.35	1.22	79523.14
5	11.13	14.77	37.33	4.05	15.36	11.61	1.23	76047.76
6	7.97	14.55	54.96	3.19	16.11	11.47	1.23	78321.84
7	9.10	14.59	54.40	3.10	15.53	11.68	1.23	77126.06
8	9.58	14.79	57.68	2.77	17.02	11.33	1.25	79780.29
9	11.47	14.33	58.29	3.52	15.66	11.56	1.25	78343.04
10	13.11	13.94	58.16	4.22	16.19	11.12	1.24	79535.72
11	9.99	14.29	47.22	4.12	15.26	11.45	1.24	78355.85
12	3.68	13.56	55.86	2.71	15.37	11.60	1.24	78322.13
13	7.55	13.16	56.76	3.27	14.75	11.69	1.23	77623.64
14	6.99	13.92	58.57	2.93	15.63	12.09	1.23	72438.42
15	7.49	13.44	52.49	2.20	17.15	11.16	1.23	81116.10
16	7.12	14.16	65.27	1.87	17.52	11.20	1.23	80634.93
17	9.91	14.47	45.84	3.08	14.69	11.69	1.24	77278.56
18	9.05	14.58	52.05	2.52	16.62	11.50	1.23	78001.84
19	10.40	13.77	45.48	2.10	18.02	10.78	1.23	83129.39
20	8.92	14.06	49.18	2.27	17.44	11.03	1.24	82257.06
21	9.72	14.21	54.36	2.52	17.15	11.25	1.22	80414.13
22	8.09	14.19	53.49	2.28	17.30	11.25	1.22	79730.21
23	8.36	13.85	50.35	2.83	16.00	11.71	1.22	75865.72
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	9.02	13.92	52.58	2.88	16.43	11.42	1.23	78569.16
最 大 值	13.11	14.79	65.27	4.22	18.12	12.09	1.25	83129.39
發生時間	10	8	16	10	1	14		19
最 小 值	3.68	12.88	37.33	1.87	14.69	10.78	1.19	72438.42
發生時間	12	1	5	16	17	19		14
零點偏移(率)	-0.03 %	0.00 %	-0.01 %	0.00 %		0.03		0.20 %
全幅偏移(率)	0.03 %	0.81 %	-0.12 %	0.27 %		0.01		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002 樹林焚化廠CEMS系統日報表-A

報表日期: 114年10月11日

項目 單位 小時\限標	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.44	12.77	37.33	0.67	17.76	10.60	0.95	80059.20
1	8.37	13.86	70.26	0.48	19.66	11.65	0.97	73304.06
2	9.68	12.14	47.36	0.52	18.94	10.10	0.96	85878.99
3	8.55	13.25	42.06	1.33	17.00	11.12	0.95	80284.06
4	8.23	13.21	42.85	1.59	16.92	11.07	0.94	80252.90
5	9.19	12.51	46.00	0.69	18.50	10.77	0.94	82734.41
6	5.39	12.57	46.59	1.65	17.43	10.55	0.94	83695.49
7	7.60	12.26	47.26	1.15	18.01	10.84	0.94	80128.64
8	11.29	11.90	40.05	1.21	17.60	10.65	0.95	83843.58
9	15.94	13.00	42.52	1.66	16.73	10.87	0.97	81846.34
10	11.93	12.86	52.64	2.90	14.65	11.28	0.96	80495.31
11	10.19	12.28	47.34	1.98	15.73	11.25	0.97	80339.36
12	14.08	14.53	48.53	2.83	14.76	11.78	0.97	78656.82
13	8.89	11.22	36.79	1.56	16.87	10.74	0.94	77777.99
14	8.22	12.32	40.61	1.38	18.44	10.26	0.94	78060.96
15	6.39	12.12	24.54	0.73	18.54	10.04	0.94	81237.04
16	5.15	11.06	31.96	0.68	18.22	9.83	0.94	79088.43
17	7.73	12.28	45.69	0.49	18.59	10.16	0.94	78760.56
18	6.81	12.22	54.61	0.55	18.82	10.47	0.94	75976.87
19	3.33	12.78	38.44	0.31	18.74	10.26	0.94	80920.76
20	3.21	12.21	44.05	0.42	18.33	10.21	0.94	81322.29
21	3.94	13.31	38.45	0.36	18.52	10.12	0.94	81732.42
22	2.47	13.01	54.88	0.46	17.79	11.18	0.95	73489.04
23	2.16	12.80	45.23	0.45	18.93	10.63	0.95	80241.57
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	7.84	12.60	44.42	1.09	17.73	10.68	0.95	80005.30
最 大 值	15.94	14.53	70.26	2.90	19.66	11.78	1.01	85878.99
發生時間	9	12	1	10	1	12		2
最 小 值	2.16	11.06	24.54	0.31	14.65	9.83	0.94	73304.06
發生時間	23	16	15	19	10	16		1
零點偏移(率)	-0.01 %	-0.05 %	-0.09 %	-0.01 %		-0.22		-0.10 %
全幅偏移(率)	-0.75 %	-0.03 %	0.27 %	-0.03 %		-0.13		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A

報表日期: 114年10月11日

項目 單位 小時\限標	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.28	12.58	54.90	0.57	17.79	9.95	1.43	79580.70
1	8.34	13.33	62.71	0.60	19.38	10.18	1.43	78574.89
2	11.48	12.95	47.12	0.90	19.30	9.02	1.43	83613.08
3	9.19	13.18	55.24	0.95	16.63	10.07	1.43	77176.79
4	6.01	12.39	56.65	0.71	16.97	9.94	1.43	77806.17
5	8.57	13.17	62.21	1.12	16.26	10.25	1.41	73620.02
6	8.89	12.66	55.94	0.79	17.93	9.64	1.39	76242.56
7	7.36	11.00	54.74	0.64	17.82	9.65	1.41	78386.76
8	8.40	11.06	56.27	0.59	18.16	9.62	1.43	77443.16
9	10.51	12.05	55.32	0.60	18.28	9.63	1.41	78688.03
10	9.66	14.26	58.27	0.57	18.52	9.56	1.40	78318.63
11	10.42	15.31	51.74	0.84	17.41	9.64	1.42	77403.69
12	8.32	11.59	57.69	0.83	16.63	9.99	1.39	76645.07
13	10.61	12.49	57.93	0.87	16.32	10.08	1.36	76568.49
14	8.11	12.85	58.56	0.77	17.39	9.87	1.37	77796.31
15	7.41	13.06	58.33	0.64	17.31	9.85	1.36	83292.95
16	7.25	13.88	57.77	0.83	17.67	9.75	1.41	76524.85
17	8.51	13.33	58.11	0.56	17.82	9.66	1.41	77513.68
18	9.17	14.05	60.21	0.86	18.26	9.95	1.36	76679.59
19	6.53	13.23	52.34	0.46	18.32	9.53	1.38	79112.09
20	6.67	13.21	59.42	0.41	18.93	9.48	1.43	80034.54
21	4.14	12.83	55.82	0.41	18.09	9.48	1.42	79015.10
22	5.02	12.39	54.88	0.44	18.49	9.73	1.39	76497.89
23	7.66	13.15	50.75	0.49	19.33	9.33	1.36	77036.98
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	8.19	12.92	56.37	0.69	17.88	9.74	1.40	78065.50
最 大 值	11.48	15.31	62.71	1.12	19.38	10.25	1.46	83613.08
發生時間	2	11	1	5	1	5		2
最 小 值	4.14	11.00	47.12	0.41	16.26	9.02	1.36	73620.02
發生時間	21	7	2	20	5	2		5
零點偏移(率)	-0.12 %	0.00 %	-0.12 %	-0.01 %		-0.05		0.10 %
全幅偏移(率)	0.16 %	0.61 %	-0.15 %	0.24 %		0.38		0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								