

P001 樹林焚化廠CEMS系統日報表-A

報表日期: 114年08月24日

項目 單位 小時\限標	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	2.33	8.98	55.18	2.45	14.56	12.07	1.27	69098.15
1	1.19	8.98	56.71	1.91	16.90	11.75	1.27	69853.36
2	4.87	8.75	54.27	2.71	14.97	11.80	1.27	70932.54
3	9.45	9.41	54.66	3.30	14.33	12.00	1.25	68711.04
4	6.80	8.69	59.66	2.90	14.38	11.98	1.26	69527.84
5	9.01	10.23	62.26	3.47	13.51	12.04	1.27	69490.22
6	8.09	10.03	59.31	3.08	14.28	11.88	1.27	69784.54
7	6.56	10.06	56.99	3.25	14.35	11.98	1.27	68844.20
8	9.55	9.96	58.72	3.89	13.97	11.95	1.28	68951.06
9	9.36	10.17	57.70	3.20	14.02	12.11	1.26	67890.76
10	9.20	12.58	58.63	3.63	13.22	12.05	1.27	68898.96
11	7.73	9.37	60.53	3.39	13.36	12.24	1.27	67414.33
12	7.41	10.72	60.81	2.57	15.08	11.98	1.26	69510.71
13	7.41	11.28	60.52	3.18	13.77	12.12	1.25	68759.90
14	8.88	11.57	58.21	3.10	14.03	12.06	1.25	67643.73
15	8.72	12.21	61.57	2.89	14.62	11.94	1.25	68464.50
16	7.55	12.68	57.47	3.13	13.74	11.89	1.25	70288.47
17	10.21	9.41	59.60	3.53	13.86	12.16	1.26	69247.50
18	7.59	9.09	58.59	2.85	14.71	11.95	1.25	70671.75
19	6.36	8.90	58.36	2.92	14.13	12.11	1.25	69288.04
20	9.96	8.72	60.84	3.17	14.04	12.01	1.26	70035.86
21	8.93	9.47	59.96	2.75	14.92	11.87	1.25	70348.77
22	5.79	8.92	62.97	2.94	13.84	12.06	1.25	70156.66
23	1.36	9.09	59.75	2.93	13.55	12.15	1.25	69257.43
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	7.26	9.97	58.89	3.05	14.26	12.01	1.26	69294.60
最 大 值	10.21	12.68	62.97	3.89	16.90	12.24	1.29	70932.54
發生時間	17	16	22	8	1	11		2
最 小 值	1.19	8.69	54.27	1.91	13.22	11.75	1.25	67414.33
發生時間	1	4	2	1	10	1		11
零點偏移(率)	-0.01 %	-0.01 %	-0.01 %	0.00 %		-0.01		0.10 %
全幅偏移(率)	0.42 %	-0.70 %	0.13 %	0.01 %		0.43		0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002 樹林焚化廠CEMS系統日報表-A 報表日期: 114年08月24日

報表日期: 114年08月24日

項目 單位 小時\限標	#2-HCl_C ppm	#2-CO_C ppm	#2-NOx_C ppm	#2-SO2_C ppm	#2-H2O %	#2-O2_C %	#2-OPAC %	#2-FLOW_C m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	3.39	7.60	49.84	2.14	17.24	10.64	0.98	79653.82
1	3.54	7.68	54.48	2.25	17.42	10.82	0.99	77488.37
2	3.26	7.54	51.29	1.88	17.13	10.33	0.99	81122.22
3	3.42	7.42	50.32	2.04	16.31	10.57	0.99	77029.46
4	3.47	7.38	50.86	2.15	16.35	10.60	0.99	76155.28
5	3.42	7.82	49.46	1.96	16.94	10.26	0.98	79052.44
6	0.54	8.86	55.40	1.18	16.06	10.59	0.96	77087.52
7	5.14	8.98	51.81	1.07	15.98	10.55	0.98	77739.26
8	4.73	10.04	54.78	0.93	17.01	10.24	0.98	80285.84
9	4.65	11.73	62.19	2.09	15.88	10.44	0.98	80412.85
10	4.89	8.36	52.79	2.27	15.48	10.98	0.98	75187.00
11	4.70	8.47	48.47	1.67	16.14	11.04	0.98	77461.93
12	3.49	9.54	56.43	1.37	17.61	10.73	0.97	78061.05
13	2.91	10.18	49.35	1.96	16.71	10.45	0.94	77851.92
14	2.73	10.87	43.89	1.95	17.30	10.54	0.94	77898.29
15	2.71	10.50	44.85	1.84	16.92	10.56	0.94	79916.99
16	3.02	10.37	50.51	1.62	16.92	10.82	0.94	79734.48
17	3.20	9.04	53.37	1.40	17.43	10.69	0.94	81126.33
18	3.25	9.14	52.99	1.59	17.14	10.74	0.97	79817.31
19	3.43	11.19	53.10	1.69	16.40	10.87	0.97	79638.58
20	3.43	10.53	56.89	1.39	17.47	10.91	0.96	81011.75
21	3.70	11.14	54.40	2.19	16.12	11.07	0.97	79140.03
22	3.58	9.24	60.80	1.92	16.53	10.77	0.97	79737.94
23	3.53	9.18	55.27	1.79	16.82	10.60	0.96	78557.78
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	3.51	9.28	52.65	1.76	16.72	10.66	0.97	78798.69
最 大 值	5.14	11.73	62.19	2.27	17.61	11.07	1.00	81126.33
發生時間	7	9	9	10	12	21		17
最 小 值	0.54	7.38	43.89	0.93	15.48	10.24	0.94	75187.00
發生時間	6	4	14	8	10	8		10
零點偏移(率)	-0.10 %	-0.02 %	-0.06 %	-0.00 %		-0.07		0.00 %
全幅偏移(率)	0.14 %	0.17 %	-0.24 %	0.13 %		0.18		0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A 報表日期: 114年08月24日

報表日期: 114年08月24日

項目 單位 小時\限標	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	4.19	9.31	61.24	2.45	17.25	9.58	1.39	76028.17
1	4.61	9.95	65.08	2.83	18.56	9.90	1.38	75786.75
2	6.69	10.80	56.86	3.49	17.76	9.28	1.36	78883.87
3	3.91	8.57	52.18	2.93	17.08	9.20	1.37	75172.44
4	5.75	8.42	51.04	2.89	17.79	8.89	1.40	77128.17
5	6.32	8.56	52.43	2.73	17.10	9.12	1.40	75445.65
6	6.65	8.47	54.94	2.96	16.85	9.14	1.41	75406.46
7	5.58	12.68	51.10	2.52	16.26	9.03	1.39	73137.83
8	7.44	8.98	50.08	3.15	17.31	8.79	1.40	76872.32
9	7.96	7.95	54.48	2.96	16.88	9.05	1.36	74654.14
10	7.96	8.26	53.56	2.96	16.65	9.06	1.39	73517.23
11	7.11	8.44	53.83	2.99	17.29	9.12	1.40	73415.21
12	5.84	8.48	50.93	2.77	17.54	9.06	1.35	74313.44
13	5.36	9.54	51.70	2.69	16.75	9.22	1.36	73064.50
14	4.73	10.07	53.91	2.83	17.11	9.06	1.37	73944.20
15	4.64	9.05	53.07	2.69	17.23	8.98	1.35	73690.93
16	7.47	9.33	55.32	2.98	18.10	9.13	1.36	74672.89
17	6.09	9.80	51.23	2.83	17.87	8.95	1.38	76167.46
18	4.24	9.46	55.05	2.78	16.77	9.35	1.35	75173.13
19	4.23	8.72	53.95	2.69	17.38	9.06	1.34	74387.21
20	5.27	8.68	55.06	2.89	16.36	9.28	1.37	73315.98
21	4.39	8.50	58.55	2.79	18.26	9.04	1.41	76622.53
22	2.67	8.14	58.33	2.72	17.19	9.14	1.41	76316.71
23	2.38	8.48	60.13	2.86	15.61	9.43	1.39	72319.37
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	5.48	9.11	54.75	2.85	17.21	9.16	1.38	74976.52
最 大 值	7.96	12.68	65.08	3.49	18.56	9.90	1.43	78883.87
發生時間	9	7	1	2	1	1		2
最 小 值	2.38	7.95	50.08	2.45	15.61	8.79	1.32	72319.37
發生時間	23	9	8	0	23	8		23
零點偏移(率)	-0.09 %	0.00 %	-0.04 %	-0.05 %		-0.03		-0.10 %
全幅偏移(率)	-0.02 %	-0.82 %	0.40 %	0.11 %		0.33		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								