

P002 樹林焚化廠CEMS系統日報表-A

報表日期: 113年05月22日

項目 單位 小時\限標	#2-HCl_C ppm	#2-CO_C ppm	#2-NOx_C ppm	#2-SO2_C ppm	#2-H2O %	#2-O2_C %	#2-OPAC %	#2-FLOW_C m3/Hour
0	6.87	3.23	45.27	1.44	18.35	10.59	1.02	82373.57
1	8.40	3.16	52.09	1.25	20.72	9.99	1.02	84988.22
2	9.05	2.11	51.39	1.71	17.96	10.77	1.02	82538.03
3	10.34	2.25	51.74	2.29	16.89	11.23	1.02	79980.34
4	7.72	3.29	63.38	1.15	18.09	10.99	1.02	80539.60
5	11.19	4.65	48.48	1.94	17.38	10.76	1.02	82840.26
6	6.15	5.99	47.74	3.01	15.90	10.89	1.00	83286.13
7	6.40	2.47	50.94	2.54	16.06	11.05	0.99	81348.98
8	7.57	3.54	53.72	2.32	16.14	10.97	1.00	82682.69
9	9.60	3.31	52.31	2.19	16.51	11.00	1.02	81430.10
10	9.07	6.15	50.93	2.45	15.73	11.19	1.02	80754.05
11	9.06	4.44	51.93	2.18	16.83	10.72	1.02	83479.59
12	6.54	5.19	53.37	1.94	17.16	10.89	1.03	82317.65
13	8.71	3.06	53.29	2.14	16.79	11.00	1.03	82191.44
14	11.23	3.04	59.24	2.52	16.78	10.78	1.02	83308.54
15	17.60	2.99	56.86	3.13	16.32	11.17	1.02	80410.92
16	9.41	2.82	44.63	0.99	18.12	10.43	1.02	84643.35
17	6.67	4.06	44.88	0.85	17.35	10.65	1.00	83328.87
18	6.48	1.47	47.25	1.15	16.61	10.81	0.99	83931.33
19	7.92	3.25	47.13	2.86	15.89	10.91	1.01	83446.59
20	6.48	2.88	60.21	1.33	18.51	10.79	1.01	81709.84
21	9.65	3.50	44.84	2.07	17.76	10.38	1.02	86425.78
22	10.26	3.57	47.09	2.06	17.53	10.61	1.01	84252.64
23	10.75	3.02	50.16	1.92	17.44	10.67	1.02	83594.99
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	8.88	3.48	51.20	1.98	17.20	10.80	1.01	82741.81
最 大 值	17.60	6.15	63.38	3.13	20.72	11.23	1.05	86425.78
發生時間	15	10	4	15	1	3		21
最 小 值	6.15	1.47	44.63	0.85	15.73	9.99	0.96	79980.34
發生時間	6	18	16	17	10	1		3
零點偏移(率)	-0.13 %	0.00 %	-0.02 %	-0.02 %		-0.06		-0.10 %
全幅偏移(率)	0.14 %	0.67 %	0.34 %	0.29 %		-0.08		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A

報表日期: 113年05月22日

項目 單位 小時\限標	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.63	5.44	63.62	1.65	18.62	9.97	0.97	82870.62
1	8.96	4.11	59.85	1.07	19.73	9.84	0.98	83388.61
2	16.86	4.31	44.05	0.57	20.19	9.33	0.98	86185.39
3	9.47	3.07	42.63	0.17	19.95	9.39	0.94	82726.87
4	10.99	2.29	45.23	0.28	18.49	9.71	0.94	81038.74
5	11.86	9.06	46.92	0.52	17.17	9.89	0.93	79766.26
6	8.31	4.50	45.03	0.52	17.03	9.88	0.92	77865.19
7	9.19	7.83	42.03	0.38	18.49	9.56	0.94	76030.93
8	10.31	2.39	42.69	0.26	18.71	9.57	0.95	79261.80
9	10.78	1.29	49.29	0.37	18.51	9.82	0.95	78034.70
10	11.71	0.87	60.78	0.39	17.72	10.19	0.97	82839.54
11	14.95	14.09	46.36	0.45	18.32	9.93	0.99	82757.04
12	9.74	2.82	49.55	0.43	18.06	10.02	0.98	79910.06
13	11.90	1.83	50.91	0.36	18.21	9.88	0.99	81826.92
14	13.66	1.14	56.99	0.57	17.70	10.04	0.99	80834.17
15	17.42	2.18	49.13	0.85	17.69	10.00	0.96	80420.61
16	9.66	3.49	42.80	0.28	17.65	10.06	0.96	79123.20
17	8.46	1.37	51.59	0.18	19.61	9.83	0.97	84497.69
18	6.57	4.57	53.16	0.14	19.25	9.91	0.99	83953.89
19	8.73	9.93	44.03	0.24	17.47	10.14	1.00	82319.23
20	7.33	6.65	50.21	0.24	18.60	9.99	0.99	82778.16
21	9.26	5.04	59.42	0.22	19.89	9.99	0.99	82873.47
22	11.33	9.93	43.09	0.30	18.79	9.71	0.97	82679.88
23	8.37	7.44	50.37	0.28	18.47	10.04	0.98	80393.41
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	10.60	4.82	49.57	0.45	18.51	9.86	0.97	81432.35
最 大 值	17.42	14.09	63.62	1.65	20.19	10.19	1.02	86185.39
發生時間	15	11	0	0	2	10		2
最 小 值	6.57	0.87	42.03	0.14	17.03	9.33	0.92	76030.93
發生時間	18	10	7	18	6	2		7
零點偏移(率)	-0.05 %	-0.00 %	-0.11 %	-0.01 %		-0.06		0.20 %
全幅偏移(率)	0.02 %	0.37 %	0.18 %	0.23 %		0.27		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								