

P001 樹林焚化廠CEMS系統日報表-A 報表日期: 115年09月13日

報表日期: 115年09月13日

項目 單位 小時\限標	#1-HCl_C ppm	#1-CO_C ppm	#1-NOx_C ppm	#1-SO2_C ppm	#1-H2O %	#1-O2_C %	#1-OPAC %	#1-FLOW_C m3/Hour
0	7.57	12.30	56.27	2.03	19.17	10.66	1.15	76490.90
1	9.70	12.47	64.64	1.47	21.07	10.56	1.16	75840.28
2	9.49	12.30	56.03	2.17	19.89	10.45	1.15	77994.95
3	9.94	12.72	58.68	2.35	19.39	10.68	1.16	76792.56
4	11.22	12.72	60.09	2.98	17.57	11.21	1.15	74450.36
5	13.35	12.72	52.06	4.02	18.55	10.89	1.16	76702.88
6	10.73	12.65	60.90	2.87	19.83	10.44	1.15	77664.01
7	9.74	12.61	54.64	2.65	17.32	11.19	1.16	74196.54
8	13.19	12.51	55.22	2.77	17.92	11.04	1.15	74254.55
9	10.27	12.70	60.20	2.45	17.55	11.24	1.15	72152.45
10	9.15	12.74	61.22	2.15	18.29	11.18	1.16	72682.66
11	11.58	12.72	60.96	2.71	17.84	11.22	1.15	72701.35
12	9.56	12.52	59.62	2.39	18.05	11.04	1.14	74144.59
13	12.32	12.68	61.79	2.57	17.94	11.13	1.14	73444.66
14	8.04	13.26	54.18	2.70	16.38	11.66	1.13	71191.51
15	12.32	12.77	51.50	2.71	17.16	11.33	1.13	73951.86
16	9.33	12.66	58.90	2.65	17.79	11.16	1.14	74375.78
17	11.79	12.97	59.46	2.62	18.63	11.32	1.14	72342.70
18	8.20	12.68	52.08	2.09	18.35	10.99	1.14	74866.63
19	10.31	12.71	61.57	2.28	17.68	11.24	1.13	73456.34
20	14.55	12.89	58.70	2.78	17.19	11.39	1.13	72777.22
21	8.57	12.61	55.43	2.12	18.50	11.01	1.13	74488.24
22	10.47	12.56	57.71	2.07	18.60	10.96	1.13	74981.95
23	9.61	12.53	56.96	2.28	17.93	11.04	1.13	74647.09
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	10.46	12.67	57.87	2.49	18.27	11.04	1.14	74441.34
最 大 值	14.55	13.26	64.64	4.02	21.07	11.66	1.18	77994.95
發生時間	20	14	1	5	1	14		2
最 小 值	7.57	12.30	51.50	1.47	16.38	10.44	1.13	71191.51
發生時間	0	0	15	1	14	6		14
零點偏移(率)	-0.08 %	-0.06 %	-0.11 %	-0.02 %		0.03	-0.01	0.20 %
全幅偏移(率)	-1.35 %	-0.40 %	-0.15 %	-0.12 %		-0.02	-0.06	0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A

報表日期: 115年09月13日

項目 單位 小時\限標	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.98	10.78	56.87	3.04	20.21	9.08	1.23	75511.60
1	8.83	11.17	57.55	2.38	22.22	9.20	1.24	74683.29
2	9.30	10.97	53.87	2.89	20.72	8.86	1.23	77924.33
3	9.83	11.25	57.28	2.93	19.34	9.40	1.24	76775.42
4	8.88	11.72	62.77	3.15	19.07	10.13	1.24	75864.67
5	10.36	11.60	65.57	3.14	18.56	10.16	1.25	77590.99
6	8.68	11.65	66.02	3.18	18.99	10.14	1.26	76816.27
7	5.12	11.47	58.46	3.20	20.05	9.35	1.26	82566.84
8	4.93	11.11	53.39	2.63	19.31	9.56	1.24	78356.75
9	12.38	11.31	65.04	3.22	19.03	9.94	1.27	79709.00
10	5.77	11.78	65.05	2.77	18.11	10.49	1.27	76323.83
11	10.33	11.69	64.09	3.03	19.34	10.24	1.25	74873.81
12	8.44	11.25	57.51	2.87	20.13	9.66	1.22	74849.84
13	9.43	11.14	59.70	2.99	20.08	9.50	1.22	75603.06
14	8.85	11.91	54.84	2.87	19.11	9.40	1.19	74217.90
15	9.85	12.22	57.52	2.97	20.50	9.23	1.22	74072.80
16	9.49	12.21	47.20	2.75	20.56	8.56	1.24	74945.07
17	10.16	12.46	41.22	2.79	20.16	8.75	1.22	74648.75
18	9.19	12.61	48.85	2.87	19.47	9.08	1.21	73611.20
19	4.42	13.41	52.00	2.96	20.00	10.20	1.26	67861.15
20	9.27	12.46	40.30	2.77	20.08	9.01	1.24	74193.49
21	10.45	12.48	46.36	2.88	18.78	9.36	1.23	76271.36
22	9.74	12.10	53.04	3.09	18.38	9.63	1.20	74862.19
23	11.11	11.19	53.97	3.00	17.59	9.77	1.22	74977.76
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	8.91	11.75	55.77	2.93	19.57	9.53	1.24	75712.97
最 大 值	12.38	13.41	66.02	3.22	22.22	10.49	1.27	82566.84
發生時間	9	19	6	9	1	10		7
最 小 值	4.42	10.78	40.30	2.38	17.59	8.56	1.18	67861.15
發生時間	19	0	20	1	23	16		19
零點偏移(率)	-0.02 %	-0.00 %	-0.06 %	0.00 %		0.01	-0.01	-0.20 %
全幅偏移(率)	0.30 %	-0.17 %	-0.19 %	-0.14 %		0.23	0.00	-0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								