

P001\_樹林焚化廠CEMS系統日報表-A

報表日期: 115年02月02日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	10.34	12.03	48.30	2.48	16.03	11.22	1.05	83070.47
1	11.40	13.28	59.61	2.28	16.05	12.41	1.04	72883.40
2	10.32	13.00	51.17	3.10	15.32	11.76	1.03	79403.96
3	9.39	12.13	50.78	3.19	14.86	11.40	1.03	82919.75
4	12.89	13.35	43.26	3.39	14.75	11.66	1.03	81103.00
5	9.87	13.16	49.18	2.92	14.47	12.63	1.08	76558.37
6	9.72	12.25	55.30	1.83	16.49	11.77	1.09	78872.95
7	10.33	12.04	60.35	2.83	15.90	11.21	1.09	82262.74
8	9.96	11.98	60.54	3.36	14.33	11.88	1.10	79026.53
9	12.33	12.32	53.13	3.31	15.35	11.93	1.09	77990.89
10	11.34	12.47	61.46	3.28	14.86	11.74	1.09	80000.73
11	12.54	12.03	51.12	5.19	13.55	11.79	1.09	80692.13
12	10.55	12.25	49.08	3.27	15.01	11.96	1.11	78405.23
13	9.53	11.94	61.09	2.53	16.19	11.57	1.12	80662.07
14	10.53	12.14	44.20	3.70	14.63	11.86	1.10	79186.68
15	8.23	12.91	53.08	3.04	14.69	12.34	1.10	74958.08
16	9.79	12.14	43.07	2.03	15.24	11.98	1.10	77864.61
17	9.31	12.15	54.41	1.69	15.52	11.98	1.09	77796.89
18	9.82	11.37	62.75	1.40	16.55	11.21	1.10	83226.83
19	9.67	12.68	44.93	2.28	14.42	11.60	1.10	81320.98
20	9.30	13.89	56.11	1.90	15.56	12.09	1.09	76318.55
21	11.84	11.97	46.90	1.56	16.18	11.78	1.09	78442.05
22	9.46	11.35	57.67	0.87	17.18	11.15	1.09	83129.04
23	9.51	12.08	43.85	1.33	16.70	11.43	1.09	80853.85
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	10.33	12.37	52.56	2.61	15.41	11.76	1.08	79456.24
最大值	12.89	13.89	62.75	5.19	17.18	12.63	1.13	83226.83
發生時間	4	20	18	11	22	5		18
最小值	8.23	11.35	43.07	0.87	13.55	11.15	1.02	72883.40
發生時間	15	22	16	22	11	22		1
零點偏移(率)	-0.01 %	0.00 %	-0.02 %	-0.03 %		-0.15	-0.01	0.40 %
全幅偏移(率)	1.27 %	0.67 %	0.20 %	0.29 %		-0.06	0.00	0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002\_樹林焚化廠CEMS系統日報表-A

報表日期: 115年02月02日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	4.52	12.59	41.48	1.54	16.58	10.50	1.01	76462.61
1	1.68	11.83	46.62	1.41	16.58	10.47	1.01	76528.14
2	1.52	11.93	58.84	0.71	16.38	10.70	0.97	77442.57
3	1.24	11.81	54.98	1.08	15.56	10.69	0.95	77180.71
4	1.59	11.80	52.92	1.28	14.77	10.75	0.95	77049.37
5	0.86	11.91	60.50	1.13	15.55	10.85	0.98	75275.71
6	1.60	11.46	51.51	1.15	16.27	10.31	1.02	76547.30
7	1.58	11.47	41.52	1.14	17.30	10.21	1.02	77031.09
8	1.72	11.66	47.71	1.18	16.86	10.42	1.02	77326.96
9	1.64	12.08	36.86	1.05	15.83	10.90	1.01	79514.90
10	4.78	12.48	35.11	1.84	15.82	10.83	0.98	75893.95
11	7.67	12.83	56.37	1.41	15.24	11.28	0.97	79866.69
12	1.85	12.52	51.72	1.50	14.14	11.51	0.98	80004.52
13	5.89	12.56	52.76	1.60	14.60	11.50	1.00	78891.09
14	4.24	13.27	57.12	1.39	15.18	11.44	1.02	75729.74
15	5.21	12.16	39.45	1.49	15.50	10.95	1.02	77749.17
16	3.85	12.37	38.91	1.42	14.83	11.25	1.02	78189.47
17	1.66	12.91	47.68	1.67	14.16	11.73	1.02	77318.42
18	1.17	12.37	43.06	1.44	14.31	11.36	1.02	75268.71
19	1.54	11.36	39.81	1.37	16.48	10.12	1.02	76438.10
20	2.42	11.05	43.89	0.88	17.84	9.68	1.02	79244.64
21	4.45	11.61	43.99	1.41	17.47	9.81	1.03	79152.43
22	4.98	11.17	43.19	0.99	17.21	9.83	1.02	77304.32
23	5.44	11.18	35.55	1.22	17.71	9.69	1.02	76953.77
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	3.05	12.02	46.73	1.30	15.92	10.70	1.00	77431.85
最大值	7.67	13.27	60.50	1.84	17.84	11.73	1.03	80004.52
發生時間	11	14	5	10	20	17		12
最小值	0.86	11.05	35.11	0.71	14.14	9.68	0.94	75268.71
發生時間	5	20	10	2	12	20		18
零點偏移(率)	-0.06 %	0.00 %	-0.06 %	-0.01 %		-0.06	-0.01	0.10 %
全幅偏移(率)	1.80 %	0.33 %	0.01 %	-0.29 %		-0.04	0.00	0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

## P003\_樹林焚化廠CEMS系統日報表-A

報表日期: 115年02月02日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.05	12.47	42.39	2.06	15.93	9.91	1.43	73855.15
1	9.50	11.36	46.20	2.24	16.38	9.89	1.43	73912.68
2	9.68	11.10	45.56	2.64	16.20	9.90	1.43	74276.77
3	9.55	11.38	47.05	2.54	15.85	9.97	1.43	74030.19
4	10.82	11.10	43.75	3.14	15.54	9.91	1.43	74246.95
5	9.33	12.60	41.40	2.00	15.76	9.70	1.43	73017.14
6	9.43	12.56	42.31	2.17	17.32	9.46	1.43	74462.52
7	7.09	11.47	43.07	2.78	15.31	9.68	1.43	75416.75
8	9.68	10.61	35.31	2.89	16.87	8.87	1.43	72759.99
9	10.14	10.51	33.03	2.62	17.05	8.94	1.43	72389.96
10	9.19	10.38	31.14	2.23	17.23	8.90	1.44	72349.98
11	8.68	12.37	34.92	3.11	16.69	8.76	1.46	72797.96
12	9.61	10.97	41.63	2.51	15.99	9.59	1.44	72458.51
13	9.17	11.02	51.23	1.96	17.48	9.47	1.43	74902.51
14	9.20	11.05	53.57	1.88	16.32	9.91	1.43	74899.09
15	9.15	11.50	52.86	2.05	15.44	10.37	1.43	71978.31
16	9.89	11.10	44.51	1.84	16.09	9.95	1.43	75208.84
17	9.02	11.19	43.81	2.29	14.75	10.19	1.43	74463.86
18	9.78	10.79	42.75	1.91	15.90	9.81	1.43	74738.44
19	9.04	11.03	43.04	1.81	16.32	9.81	1.43	73660.49
20	8.46	11.10	50.42	1.85	15.64	10.06	1.43	73487.74
21	8.83	11.44	55.74	2.02	16.34	10.27	1.43	76767.70
22	10.32	11.38	51.56	2.07	17.06	10.10	1.43	76895.05
23	8.99	11.08	47.34	1.83	16.96	9.73	1.43	76696.37
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	9.32	11.32	44.36	2.27	16.27	9.71	1.43	74153.04
最大值	10.82	12.60	55.74	3.14	17.48	10.37	1.46	76895.05
發生時間	4	5	21	4	13	15		22
最小值	7.09	10.38	31.14	1.81	14.75	8.76	1.42	71978.31
發生時間	7	10	10	19	17	11		15
零點偏移(率)	-0.10 %	0.00 %	-0.03 %	-0.01 %		-0.07	-0.01	0.00 %
全幅偏移(率)	-1.42 %	-0.08 %	-0.12 %	-0.05 %		0.18	0.00	0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								