

P001 樹林焚化廠CEMS系統日報表-A

報表日期: 114年07月05日

項目 單位 小時\限標	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	0.77	10.85	72.03	1.23	17.61	11.67	1.26	79446.03
1	6.56	11.84	60.05	2.95	17.13	11.90	1.27	77990.28
2	6.97	11.49	63.87	3.48	16.64	12.04	1.27	76929.41
3	5.41	10.51	62.11	3.59	16.22	11.97	1.28	78350.53
4	5.73	11.20	60.38	3.43	16.21	12.21	1.29	76221.00
5	9.81	7.12	61.13	3.63	16.31	11.61	1.29	79750.34
6	3.01	6.43	68.25	2.10	17.82	11.48	1.29	80572.73
7	6.55	6.68	66.30	2.89	17.24	11.52	1.29	80988.93
8	3.24	8.95	56.79	4.29	14.85	12.07	1.28	78008.87
9	2.06	6.73	64.61	3.14	15.73	12.15	1.28	76767.10
10	7.04	8.28	56.18	4.87	15.35	11.98	1.29	77467.35
11	10.39	10.07	44.96	4.82	14.24	12.07	1.29	75810.54
12	3.66	6.36	51.31	2.11	13.43	12.30	1.29	72821.66
13	13.25	4.47	54.95	3.44	13.19	12.30	1.29	71221.55
14	14.09	7.92	55.07	2.85	14.01	12.10	1.29	73883.86
15	5.57	7.51	49.96	2.11	14.08	12.13	1.29	73768.99
16	9.95	9.96	56.07	2.24	14.97	12.12	1.29	74846.46
17	5.12	9.11	61.34	1.30	16.06	11.87	1.29	76592.47
18	13.73	10.37	52.82	2.14	15.43	11.97	1.29	78473.55
19	1.14	9.73	55.24	1.36	17.28	11.84	1.28	77992.32
20	4.69	9.64	50.04	1.45	15.74	11.92	1.27	78773.35
21	0.99	9.36	49.80	1.89	14.98	12.07	1.29	78356.33
22	8.44	10.62	56.58	1.80	16.27	11.92	1.29	78321.27
23	8.32	10.23	62.10	2.35	15.70	12.12	1.28	76988.94
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	6.52	8.98	58.00	2.73	15.69	11.97	1.28	77097.66
最 大 值	14.09	11.84	72.03	4.87	17.82	12.30	1.30	80988.93
發生時間	14	1	0	10	6	12		7
最 小 值	0.77	4.47	44.96	1.23	13.19	11.48	1.25	71221.55
發生時間	0	13	11	0	13	6		13
零點偏移(率)	-0.05 %	-0.00 %	-0.19 %	-0.01 %		-0.18		0.20 %
全幅偏移(率)	0.00 %	0.09 %	-0.28 %	0.56 %		-0.07		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002 樹林焚化廠CEMS系統日報表-A

報表日期: 114年07月05日

項目 單位 小時\限標	#2-HCl_C ppm	#2-CO_C ppm	#2-NOx_C ppm	#2-SO2_C ppm	#2-H2O %	#2-O2_C %	#2-OPAC %	#2-FLOW_C m3/Hour
0	6.75	9.35	66.14	1.57	17.46	11.02	0.98	81153.81
1	8.35	9.68	62.52	2.26	18.13	10.89	0.99	80856.03
2	8.81	9.12	62.56	2.63	16.27	11.13	0.98	80376.61
3	9.60	9.09	60.42	2.76	16.07	11.11	0.97	80830.07
4	8.17	9.07	58.35	2.48	16.26	11.07	0.97	81150.72
5	9.83	9.10	60.67	2.62	16.97	10.98	0.97	81975.29
6	15.36	11.33	58.48	3.16	16.81	10.81	0.99	83045.01
7	8.36	10.41	56.34	2.64	17.19	10.84	1.00	80729.15
8	7.40	9.77	56.67	2.46	16.17	11.16	1.00	78684.63
9	8.57	9.48	57.81	3.11	16.27	11.08	1.01	79427.61
10	12.26	11.59	61.38	3.66	14.76	11.61	0.99	78032.81
11	8.80	12.58	63.06	3.41	15.78	11.35	0.99	78918.96
12	7.73	9.98	58.60	3.12	16.19	11.16	0.99	79890.23
13	9.62	13.55	62.47	4.17	14.53	11.42	1.00	76723.09
14	13.30	13.38	61.22	4.04	14.71	11.30	1.00	78067.48
15	15.21	9.14	61.35	3.61	15.78	11.15	1.00	78346.65
16	6.01	8.46	60.36	3.06	15.57	11.61	1.00	78361.39
17	7.18	8.69	62.37	3.23	16.24	11.43	1.00	78133.43
18	7.42	8.36	62.28	2.78	17.20	11.05	1.00	80259.54
19	5.85	8.37	62.05	3.04	17.19	11.00	1.01	80553.47
20	6.63	8.18	55.95	2.97	16.72	11.12	1.01	80782.69
21	5.56	8.25	59.33	2.65	16.44	11.22	1.01	79199.48
22	8.74	8.20	60.23	2.34	17.65	10.94	1.01	81449.12
23	11.00	10.79	56.42	2.60	17.34	11.02	1.01	81454.16
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	9.02	9.83	60.29	2.93	16.40	11.14	0.99	79933.39
最 大 值	15.36	13.55	66.14	4.17	18.13	11.61	1.02	83045.01
發生時間	6	13	0	13	1	10		6
最 小 值	5.56	8.18	55.95	1.57	14.53	10.81	0.97	76723.09
發生時間	21	20	20	0	13	6		13
零點偏移(率)	-0.04 %	-0.06 %	-0.11 %	-0.04 %		-0.08		-0.10 %
全幅偏移(率)	0.13 %	-0.69 %	0.39 %	0.19 %		-0.20		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

