

## P001\_樹林焚化廠CEMS系統日報表-A

報表日期: 115年04月10日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	6.12	13.75	55.52	0.88	21.50	10.41	1.18	75617.93
1	5.11	11.95	52.60	1.39	20.49	11.00	1.18	72163.75
2	5.30	11.27	58.49	1.52	20.57	10.66	1.18	75364.89
3	7.27	11.32	51.04	1.49	19.54	10.79	1.18	75143.50
4	10.38	11.63	50.99	2.12	17.86	11.13	1.18	74115.12
5	7.76	11.63	59.38	1.64	17.06	11.32	1.18	70319.71
6	8.10	11.66	58.49	1.99	17.79	11.24	1.21	72791.16
7	13.32	12.80	60.42	2.54	17.34	11.26	1.22	73445.88
8	14.53	13.30	57.80	3.62	15.82	11.73	1.20	70943.34
9	10.61	14.04	62.84	3.71	15.81	12.18	1.18	71018.76
10	8.04	13.90	62.65	3.19	16.33	12.11	1.18	71318.27
11	6.29	13.74	62.08	2.33	18.70	11.69	1.18	72589.66
12	4.26	13.73	52.72	2.04	17.99	11.81	1.16	72280.61
13	2.10	13.66	53.28	1.12	18.60	11.69	1.16	72690.42
14	6.10	13.45	55.04	1.54	18.93	11.42	1.15	74783.65
15	8.27	13.70	61.82	1.71	17.52	11.86	1.15	72218.63
16	7.12	13.31	53.48	2.87	18.05	11.49	1.15	74822.21
17	11.11	13.57	55.97	3.26	17.15	11.80	1.16	73104.28
18	11.37	13.28	56.34	3.46	17.07	11.62	1.18	73356.65
19	10.37	13.20	58.93	2.41	18.54	11.19	1.18	72467.28
20	16.57	12.79	55.79	2.93	18.82	10.87	1.18	73993.56
21	18.55	14.46	47.47	4.00	16.88	11.30	1.18	72106.60
22	12.89	13.47	56.85	3.64	18.61	11.07	1.18	72578.76
23	11.80	13.88	49.85	3.07	18.75	11.33	1.20	70584.84
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	9.31	13.06	56.24	2.44	18.15	11.37	1.18	72909.14
最大值	18.55	14.46	62.84	4.00	21.50	12.18	1.23	75617.93
發生時間	21	21	9	21	0	9		0
最小值	2.10	11.27	47.47	0.88	15.81	10.41	1.15	70319.71
發生時間	13	2	21	0	9	0		5
零點偏移(率)	-0.10 %	-0.00 %	-0.03 %	-0.02 %		-0.10	-0.01	0.20 %
全幅偏移(率)	0.88 %	0.98 %	-0.13 %	0.52 %		-0.12	0.04	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

## P002\_樹林焚化廠CEMS系統日報表-A

報表日期: 115年04月10日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	10.61	12.50	36.54	0.27	19.73	10.88	1.04	78664.90
1	6.54	12.79	41.71	0.66	20.13	11.16	1.05	73955.31
2	7.50	12.33	37.49	1.15	18.06	11.92	1.04	63957.31
3	4.80	11.02	48.71	1.56	18.00	10.78	1.02	60340.38
4	7.24	13.44	62.72	0.97	17.52	11.65	1.03	66975.88
5	10.08	13.88	57.89	2.16	18.25	10.58	1.04	80470.65
6	7.74	11.70	45.79	2.29	18.82	10.22	1.03	82663.71
7	8.44	12.40	58.19	1.44	17.25	11.09	1.02	80071.53
8	9.14	12.21	60.26	1.08	18.53	10.73	1.03	80861.76
9	10.92	12.41	57.21	1.17	18.32	10.84	1.02	77697.95
10	9.94	12.18	60.37	1.63	18.63	10.37	1.03	80691.72
11	9.51	11.80	67.30	1.14	18.43	10.42	1.03	80450.78
12	14.20	12.06	55.97	2.47	15.97	10.66	1.03	74852.57
13	13.06	12.42	51.34	2.60	16.01	11.10	1.02	75450.06
14	7.35	12.50	64.75	2.63	16.48	10.90	1.02	77558.50
15	10.56	12.06	49.69	4.66	16.26	10.74	1.02	76228.83
16	9.78	12.06	59.06	4.80	17.08	10.60	1.02	78585.03
17	8.90	11.95	65.66	3.14	17.74	10.65	1.02	79967.81
18	10.08	12.24	53.29	1.35	18.65	10.82	1.03	79531.71
19	8.64	12.28	48.03	2.10	17.51	10.93	1.02	80462.84
20	10.26	12.30	42.18	2.56	17.50	10.90	1.03	80973.96
21	8.79	12.19	43.14	2.11	17.28	10.91	1.02	80958.01
22	9.64	12.28	54.72	2.73	17.20	10.94	1.02	79980.89
23	9.54	12.50	58.96	1.93	17.90	10.95	1.02	80321.86
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	9.30	12.31	53.37	2.02	17.80	10.86	1.03	77153.08
最大值	14.20	13.88	67.30	4.80	20.13	11.92	1.06	82663.71
發生時間	12	5	11	16	1	2		6
最小值	4.80	11.02	36.54	0.27	15.97	10.22	1.01	60340.38
發生時間	3	3	0	0	12	6		3
零點偏移(率)	-0.12 %	-0.00 %	-0.07 %	-0.01 %		-0.13	-0.01	-0.10 %
全幅偏移(率)	1.47 %	0.56 %	-0.12 %	0.93 %		-0.35	0.00	0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003\_樹林焚化廠CEMS系統日報表-A

報表日期: 115年04月10日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	7.37	11.53	47.29	1.07	18.55	9.24	1.34	75635.49
1	3.58	11.36	54.31	1.50	19.98	9.76	1.36	72733.11
2	2.68	11.57	41.83	1.55	21.42	8.62	1.36	74395.40
3	3.46	10.65	38.13	1.32	20.55	8.55	1.35	75532.36
4	8.02	10.55	46.09	1.71	20.60	8.74	1.36	75664.10
5	8.37	10.82	41.66	1.71	19.87	8.74	1.34	75401.63
6	10.43	10.93	42.49	1.80	20.15	8.77	1.31	75685.89
7	7.57	10.80	49.16	1.78	18.37	9.29	1.33	75540.06
8	8.57	12.61	31.97	3.98	21.66	7.53	1.34	75402.98
9	2.78	10.29	50.15	2.35	18.86	8.67	1.33	75469.91
10	4.22	10.31	54.89	3.22	19.38	8.77	1.31	75693.11
11	9.43	10.55	58.24	3.86	19.51	9.08	1.32	75386.32
12	5.94	11.56	56.16	3.35	19.88	9.03	1.35	75265.74
13	5.18	11.86	43.43	3.04	20.58	8.35	1.34	75270.76
14	3.44	12.49	58.41	4.04	17.55	9.36	1.31	72802.22
15	3.06	11.13	53.71	2.61	17.54	8.93	1.31	73310.28
16	11.66	11.24	45.80	3.68	16.91	8.76	1.33	74677.88
17	8.52	11.23	35.11	0.11	17.10	8.84	1.33	73451.71
18	9.63	11.15	42.36	0.07	18.22	8.81	1.32	74217.63
19	9.06	11.16	47.25	0.07	18.24	8.86	1.30	73569.51
20	9.43	11.33	44.42	0.08	19.34	8.83	1.29	74098.97
21	10.00	11.66	45.55	1.14	18.67	9.29	1.32	73455.26
22	9.57	11.43	40.00	3.48	18.95	8.98	1.30	74377.75
23	9.54	11.70	35.00	1.57	19.64	8.39	1.29	70739.33
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	7.15	11.25	45.98	2.05	19.23	8.84	1.33	74490.73
最大值	11.66	12.61	58.41	4.04	21.66	9.76	1.36	75693.11
發生時間	16	8	14	14	8	1		10
最小值	2.68	10.29	31.97	0.07	16.91	7.53	1.27	70739.33
發生時間	2	9	8	18	16	8		23
零點偏移(率)	-0.09 %	0.00 %	-0.03 %	0.00 %		-0.11	-0.01	0.00 %
全幅偏移(率)	-2.44 %	0.15 %	-0.56 %	0.15 %		0.16	0.00	0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								