

P001 樹林焚化廠CEMS系統日報表-A 報表日期: 114年08月11日

報表日期: 114年08月11日

項目 單位 小時\限標	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.05	8.41	48.50	2.51	15.57	11.73	1.27	70702.01
1	9.57	9.09	51.62	2.42	16.51	11.85	1.27	69292.07
2	9.24	8.68	56.82	2.56	15.51	11.60	1.25	72598.81
3	8.58	9.06	53.65	3.47	12.97	12.21	1.25	69776.05
4	9.96	8.87	50.43	3.27	13.77	11.98	1.25	70941.59
5	7.26	9.09	65.13	2.68	15.18	12.02	1.24	69166.61
6	8.98	8.71	54.84	3.02	14.34	11.77	1.24	71501.95
7	9.13	9.14	58.36	3.42	13.01	12.27	1.25	68113.70
8	10.70	9.75	47.45	3.39	13.56	12.08	1.25	68498.81
9	10.19	9.15	51.16	4.14	13.54	12.28	1.23	69744.62
10	13.71	10.71	58.12	3.72	13.87	12.63	1.20	68054.67
11	10.15	11.64	54.65	2.83	14.82	11.74	1.20	73131.13
12	6.88	8.93	57.17	2.82	13.87	11.97	1.20	68306.16
13	5.54	9.34	62.81	2.27	14.62	12.41	1.21	67127.34
14	5.37	9.32	60.34	1.97	15.53	12.18	1.22	69124.43
15	6.17	9.27	64.23	2.06	15.31	12.18	1.21	69187.30
16	9.19	8.87	53.06	2.71	15.00	11.78	1.23	71529.36
17	7.32	9.00	52.17	2.33	15.10	11.90	1.25	70451.58
18	6.31	9.11	53.24	2.03	15.20	11.81	1.25	71130.68
19	4.58	8.95	53.94	2.13	14.60	11.91	1.23	71098.13
20	5.30	8.96	54.75	1.89	15.42	11.77	1.23	70781.17
21	9.01	9.17	52.99	1.92	16.38	11.41	1.24	73192.71
22	5.44	9.13	61.31	1.88	15.69	12.00	1.25	68841.47
23	6.16	9.04	61.52	2.01	15.35	12.06	1.25	68980.38
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	8.03	9.22	55.76	2.64	14.78	11.98	1.24	70053.03
最 大 值	13.71	11.64	65.13	4.14	16.51	12.63	1.28	73192.71
發生時間	10	11	5	9	1	10		21
最 小 值	4.58	8.41	47.45	1.88	12.97	11.41	1.20	67127.34
發生時間	19	0	8	22	3	21		13
零點偏移(率)	0.00 %	-0.01 %	-0.06 %	-0.01 %		0.00		0.10 %
全幅偏移(率)	0.00 %	0.10 %	-0.91 %	-0.03 %		0.09		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A 報表日期: 114年08月11日

報表日期: 114年08月11日

項目 單位 小時\限標	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.50	9.24	60.17	2.24	17.35	9.73	1.42	78012.75
1	9.56	7.58	61.68	2.41	18.63	9.59	1.42	78286.51
2	9.50	7.71	60.37	2.54	18.11	9.38	1.45	79461.36
3	8.14	7.50	53.46	2.23	17.12	9.54	1.46	77620.54
4	8.06	7.34	53.95	2.37	16.64	9.64	1.44	77063.66
5	9.72	7.74	51.95	2.92	15.50	9.69	1.43	76104.29
6	9.56	9.49	55.04	2.67	16.48	9.49	1.44	76659.05
7	10.50	7.23	52.27	2.72	16.48	9.60	1.43	71991.92
8	7.42	7.13	55.21	2.28	16.29	9.83	1.45	75203.45
9	9.66	6.97	56.01	2.37	16.53	9.68	1.41	76029.66
10	8.25	6.88	56.90	2.12	17.25	9.46	1.43	77025.47
11	10.10	7.23	57.35	2.82	16.40	9.66	1.43	75862.01
12	8.11	10.08	57.11	2.14	16.71	9.36	1.44	74798.36
13	8.16	11.43	55.08	1.88	17.92	9.31	1.43	75154.85
14	9.40	7.57	56.86	2.23	16.80	9.75	1.43	72497.63
15	8.42	7.60	54.21	1.99	17.43	9.60	1.39	73240.15
16	7.74	7.94	61.29	1.69	18.44	9.79	1.45	76926.01
17	9.33	8.11	45.15	1.79	17.49	9.70	1.47	79857.78
18	8.23	8.40	51.52	1.95	17.74	9.61	1.46	80720.92
19	9.02	7.29	45.51	1.67	16.88	9.83	1.46	79909.38
20	8.99	8.61	52.99	1.49	17.87	9.88	1.44	79440.02
21	9.28	7.41	45.85	1.81	16.92	9.86	1.44	80232.58
22	9.11	9.47	53.34	2.07	16.03	10.64	1.43	74239.70
23	9.73	7.69	53.73	1.86	17.67	10.05	1.42	78748.69
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	8.98	8.07	54.46	2.18	17.11	9.69	1.44	76878.61
最 大 值	10.50	11.43	61.68	2.92	18.63	10.64	1.48	80720.92
發生時間	7	13	1	5	1	22		18
最 小 值	7.42	6.88	45.15	1.49	15.50	9.31	1.39	71991.92
發生時間	8	10	17	20	5	13		7
零點偏移(率)	-0.08 %	-0.04 %	-0.04 %	-0.01 %		-0.28		-0.20 %
全幅偏移(率)	0.02 %	-0.01 %	0.12 %	0.00 %		0.11		-0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								