

P001\_樹林焚化廠CEMS系統日報表-A

報表日期: 115年04月06日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.50	13.82	54.91	2.54	18.06	10.92	1.25	73979.25
1	7.48	11.48	54.23	2.47	19.48	10.58	1.25	74916.68
2	7.63	12.26	45.79	2.40	18.79	10.87	1.25	74089.23
3	11.33	12.58	42.89	2.65	16.90	10.94	1.25	75178.02
4	8.26	12.09	41.45	1.95	17.55	10.89	1.24	75289.82
5	8.08	12.74	49.03	1.67	20.05	10.53	1.25	73730.92
6	5.52	11.26	46.42	2.77	18.13	10.63	1.25	76213.74
7	13.47	11.57	38.09	2.69	19.16	10.35	1.25	77304.66
8	13.31	11.61	37.83	2.35	16.90	11.18	1.25	72859.49
9	14.85	11.77	48.05	3.02	17.73	11.11	1.26	72935.90
10	8.11	11.57	59.75	1.76	18.37	11.07	1.26	72587.07
11	11.82	12.13	55.97	2.12	19.98	10.56	1.25	74669.08
12	10.29	11.42	47.17	3.18	18.63	10.75	1.25	74030.18
13	6.53	12.57	45.30	2.21	18.82	11.77	1.25	66527.24
14	11.19	11.72	44.39	2.98	18.55	11.08	1.25	72400.23
15	6.28	12.47	57.04	1.78	18.34	11.79	1.25	67135.07
16	12.69	13.37	44.53	2.65	18.03	10.75	1.27	74616.42
17	5.58	11.37	45.78	1.43	18.76	10.61	1.28	74949.70
18	4.92	11.00	53.01	1.37	18.39	10.71	1.25	75040.76
19	5.28	11.33	51.82	1.59	18.44	10.70	1.25	74778.51
20	5.55	12.23	37.43	1.83	19.29	10.38	1.25	75535.67
21	4.85	11.90	42.24	1.52	19.56	10.45	1.25	75487.25
22	3.28	14.69	50.60	1.44	18.99	10.62	1.24	75150.86
23	5.25	13.44	39.79	1.44	20.72	10.27	1.24	75807.94
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.38	12.18	47.23	2.16	18.65	10.81	1.25	73967.24
最大值	14.85	14.69	59.75	3.18	20.72	11.79	1.31	77304.66
發生時間	9	22	10	12	23	15		7
最小值	3.28	11.00	37.43	1.37	16.90	10.27	1.23	66527.24
發生時間	22	18	20	18	3	23		13
零點偏移(率)	-0.03 %	0.01 %	-0.04 %	-0.00 %		-0.07	-0.01	0.20 %
全幅偏移(率)	-1.52 %	-0.04 %	-0.22 %	-0.11 %		-0.04	0.00	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002\_樹林焚化廠CEMS系統日報表-A

報表日期: 115年04月06日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	11.99	14.72	56.66	0.60	19.55	10.06	1.02	81876.16
1	10.66	11.95	58.35	0.61	20.87	9.90	1.03	82891.38
2	10.88	13.51	42.82	0.57	20.83	9.51	1.02	80610.28
3	11.53	13.08	40.01	0.61	19.91	9.60	1.02	81040.63
4	9.89	12.50	45.74	0.54	19.84	9.72	1.02	80688.51
5	9.76	12.13	45.16	0.63	19.52	9.80	1.01	77179.04
6	13.18	11.91	32.29	0.97	19.54	9.76	1.00	73530.00
7	10.53	11.71	54.04	1.05	18.34	10.17	1.02	79890.77
8	9.92	11.70	53.80	0.65	19.31	10.19	1.02	79592.74
9	12.22	11.62	51.85	0.77	19.37	10.02	1.03	79942.30
10	12.21	11.70	57.97	1.01	19.79	10.07	1.04	79981.92
11	10.02	11.84	46.61	0.65	19.65	10.11	1.06	76357.79
12	7.75	12.22	54.22	0.35	19.60	10.47	1.05	73926.93
13	10.23	13.42	49.02	0.29	21.75	9.76	1.04	80529.19
14	11.36	12.75	45.82	1.18	19.70	9.83	1.04	82869.41
15	8.75	12.23	51.32	1.15	19.24	10.15	1.04	79230.53
16	10.41	12.11	37.33	0.58	20.88	9.42	1.04	81743.21
17	11.42	11.80	64.89	0.63	19.53	10.33	1.04	84134.46
18	10.26	12.28	55.83	0.90	19.31	10.47	1.05	81765.32
19	9.66	11.81	57.21	0.74	19.58	10.27	1.05	82422.80
20	9.84	11.98	44.86	0.36	21.44	9.61	1.06	81776.07
21	11.59	11.74	37.03	1.20	20.38	9.41	1.06	84617.40
22	12.21	11.93	57.43	0.81	19.55	10.12	1.06	83310.08
23	11.07	12.70	49.35	0.20	21.51	9.79	1.06	81770.70
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	10.72	12.31	49.57	0.71	19.96	9.94	1.04	80486.57
最大值	13.18	14.72	64.89	1.20	21.75	10.47	1.07	84617.40
發生時間	6	0	17	21	13	12		21
最小值	7.75	11.62	32.29	0.20	18.34	9.41	0.99	73530.00
發生時間	12	9	6	23	7	21		6
零點偏移(率)	-0.07 %	-0.06 %	-0.02 %	-0.00 %		-0.13	-0.01	-0.10 %
全幅偏移(率)	-1.26 %	0.67 %	0.18 %	0.47 %		-0.42	0.00	0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003\_樹林焚化廠CEMS系統日報表-A

報表日期: 115年04月06日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.32	13.48	49.20	3.00	17.96	9.80	1.34	74453.52
1	8.88	13.43	50.16	1.24	19.08	9.78	1.34	76246.16
2	8.99	11.54	47.37	0.68	17.58	9.62	1.34	73677.38
3	7.79	11.10	54.31	0.61	19.48	9.61	1.35	74283.09
4	9.54	11.00	49.70	0.62	18.91	9.62	1.34	73972.78
5	9.93	11.00	52.65	0.66	18.75	9.61	1.32	74032.36
6	13.75	11.04	53.40	0.97	18.24	9.75	1.32	73726.11
7	7.57	12.79	46.67	3.41	16.93	10.49	1.31	73234.20
8	8.12	11.42	44.00	2.87	17.92	9.73	1.34	74696.83
9	10.57	11.63	45.09	3.09	18.46	9.58	1.35	74556.13
10	9.66	11.71	43.08	3.04	18.92	9.33	1.32	74342.05
11	8.98	12.14	37.17	2.84	18.63	9.24	1.33	73611.36
12	9.55	12.20	50.15	2.76	20.62	8.86	1.36	73945.32
13	8.64	12.06	54.74	2.72	19.95	9.01	1.36	73665.95
14	9.85	12.05	56.11	2.84	19.67	9.19	1.36	70844.78
15	9.96	11.45	45.18	2.59	20.32	9.01	1.36	74165.71
16	9.75	11.42	45.70	2.65	20.53	9.52	1.36	78396.49
17	8.94	11.70	47.00	2.67	18.68	10.03	1.36	79100.43
18	9.40	11.85	53.80	2.75	19.72	9.92	1.36	79465.39
19	8.50	11.64	55.92	2.93	18.47	10.21	1.36	77299.19
20	10.76	11.82	50.07	3.48	18.38	10.05	1.36	78157.59
21	9.51	12.59	53.91	2.98	18.00	10.29	1.36	76368.86
22	9.94	14.07	54.05	2.88	17.99	10.19	1.36	77504.13
23	9.08	14.19	56.24	2.96	17.97	10.42	1.35	77253.78
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	9.46	12.05	49.82	2.38	18.80	9.70	1.35	75291.65
最大值	13.75	14.19	56.24	3.48	20.62	10.49	1.38	79465.39
發生時間	6	23	23	20	12	7		18
最小值	7.57	11.00	37.17	0.61	16.93	8.86	1.31	70844.78
發生時間	7	4	11	3	7	12		14
零點偏移(率)	-0.12 %	-0.03 %	-0.08 %	0.00 %		-0.12	-0.01	0.00 %
全幅偏移(率)	0.33 %	-0.43 %	0.36 %	0.68 %		0.17	0.00	0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								