

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 112年04月08日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	7.83	3.17	58.64	4.08	14.23	12.34	1.45	71198.26
1	8.17	3.85	61.95	4.04	14.42	12.32	1.46	71103.47
2	4.24	7.04	62.46	4.60	13.42	13.40	1.48	62437.65
3	2.21	3.43	53.14	3.70	14.19	12.69	1.47	68568.27
4	0.46	11.55	67.69	5.70	12.45	14.32	1.61	56146.37
5	0.11	5.24	58.32	4.33	13.14	13.58	1.59	56582.09
6	0.44	3.55	60.64	3.14	14.41	12.57	1.51	68858.80
7	3.90	3.63	56.11	3.25	14.30	12.24	1.48	72245.49
8	5.28	3.90	59.70	3.86	13.37	12.54	1.47	69754.06
9	9.10	4.81	54.77	4.40	12.92	12.52	1.46	70205.69
10	9.60	8.25	52.68	5.03	12.49	12.76	1.41	66608.74
11	9.49	4.97	60.21	4.29	13.33	12.47	1.41	70128.89
12	9.62	7.63	54.75	4.79	12.92	12.54	1.41	70064.72
13	9.77	14.26	58.22	5.79	12.15	12.72	1.46	69432.12
14	10.50	5.77	66.14	5.66	12.90	12.75	1.42	68501.73
15	9.97	7.57	61.08	5.13	12.79	13.05	1.44	66087.28
16	7.42	3.77	59.57	3.93	13.81	12.47	1.45	70387.49
17	9.84	3.13	71.77	3.82	14.07	12.48	1.45	70239.73
18	7.16	3.03	59.24	3.35	14.34	12.11	1.46	72605.59
19	5.09	3.74	66.97	4.02	13.53	12.86	1.47	66988.24
20	2.24	3.10	62.34	3.07	14.40	12.47	1.49	70364.23
21	5.00	3.00	58.07	3.42	14.06	12.26	1.47	71981.95
22	8.10	3.97	60.80	4.64	12.69	12.50	1.46	70805.25
23	8.97	3.22	59.84	4.19	13.37	12.53	1.46	69676.76
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	6.44	5.23	60.21	4.26	13.49	12.69	1.47	68373.87
最大值	10.50	14.26	71.77	5.79	14.42	14.32	1.91	72605.59
發生時間	14	13	17	13	1	4		18
最小值	0.11	3.00	52.68	3.07	12.15	12.11	1.37	56146.37
發生時間	5	21	10	20	13	18		4
零點偏移(率)	-0.14 %	0.00 %	-0.19 %	-0.01 %		0.02	0.00	0.00 %
全幅偏移(率)	4.37 %	3.33 %	0.67 %	0.38 %		0.32	0.00	0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 112年04月08日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.07	4.59	46.83	2.09	18.69	9.96	1.45	85911.00
1	6.04	4.42	43.00	1.83	20.54	9.60	1.45	85152.75
2	10.82	4.34	41.39	2.95	18.99	10.07	1.46	85039.38
3	10.17	4.18	42.48	3.11	18.41	9.95	1.46	86237.71
4	10.10	3.44	63.48	2.19	19.76	9.86	1.46	86986.81
5	7.33	4.57	50.75	1.92	18.96	10.20	1.46	87477.83
6	7.15	4.17	60.27	1.79	19.47	10.59	1.43	82855.58
7	9.53	4.00	43.57	2.66	17.76	10.45	1.43	84879.21
8	10.74	5.10	46.94	3.53	16.35	10.64	1.42	82903.03
9	10.58	7.78	49.76	5.29	14.19	11.15	1.45	80044.88
10	8.96	13.12	49.18	8.27	13.68	10.93	1.43	77552.43
11	5.40	9.22	42.14	3.62	14.90	10.86	1.44	76888.34
12	8.28	6.73	43.00	3.63	14.84	10.54	1.45	79794.45
13	9.40	7.84	42.20	3.97	15.93	10.37	1.44	80046.22
14	6.07	11.97	42.68	3.42	15.35	10.08	1.42	82071.38
15	7.06	7.61	41.33	2.96	16.63	9.74	1.42	84862.82
16	10.99	3.99	51.16	3.31	17.86	9.74	1.43	87872.02
17	7.63	3.29	55.54	2.67	17.10	10.49	1.42	81326.15
18	7.45	3.86	47.88	2.23	18.35	10.29	1.43	85172.17
19	8.91	8.61	45.11	2.92	16.53	10.43	1.42	83719.13
20	8.87	4.10	48.76	2.56	17.45	10.43	1.42	84247.09
21	6.93	3.60	47.70	2.53	17.03	10.38	1.45	84332.41
22	10.39	3.77	53.78	2.88	17.30	10.52	1.46	85600.21
23	8.84	5.28	44.15	2.38	17.58	10.25	1.47	86039.53
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.61	5.82	47.63	3.11	17.24	10.31	1.44	83625.52
最大值	10.99	13.12	63.48	8.27	20.54	11.15	1.49	87872.02
發生時間	16	10	4	10	1	9		16
最小值	5.40	3.29	41.33	1.79	13.68	9.60	1.41	76888.34
發生時間	11	17	15	6	10	1		11
零點偏移(率)	-0.17 %	-0.03 %	-0.08 %	0.00 %		0.02	0.00	0.00 %
全幅偏移(率)	-0.62 %	-1.50 %	0.36 %	-0.46 %		0.26	0.00	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 112年04月08日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.16	5.74	60.48	2.43	14.48	11.59	1.38	78746.48
1	4.28	3.78	62.15	1.51	17.17	11.27	1.38	83064.11
2	8.88	5.17	57.75	1.98	18.04	10.66	1.38	85760.00
3	9.82	5.13	50.62	2.53	16.40	10.85	1.38	82556.10
4	8.67	3.76	63.79	1.95	17.06	11.07	1.39	83208.98
5	8.24	4.10	56.90	1.82	17.69	10.76	1.41	85002.96
6	6.70	8.05	57.19	1.67	17.23	11.09	1.42	84336.40
7	7.85	13.42	44.96	2.64	15.00	10.94	1.39	81631.81
8	8.30	7.46	55.38	2.53	14.37	11.41	1.38	80992.22
9	12.48	9.70	62.32	3.17	13.68	11.57	1.38	81873.48
10	6.74	5.68	59.51	2.51	15.14	11.45	1.38	82277.46
11	10.87	20.36	56.35	2.77	14.61	11.30	1.38	84537.87
12	6.87	15.96	51.98	3.57	12.23	11.89	1.38	78169.64
13	10.58	5.59	54.79	3.58	13.93	11.46	1.36	79979.02
14	8.71	3.35	54.47	3.83	15.67	11.23	1.37	81141.97
15	7.11	4.26	54.06	2.42	14.61	11.53	1.38	78840.12
16	9.32	3.85	57.26	2.41	14.98	11.34	1.38	82221.87
17	8.26	3.20	60.06	2.45	15.02	11.30	1.38	83326.19
18	6.30	2.21	57.86	1.84	15.27	11.34	1.38	83681.30
19	7.29	2.67	60.09	1.96	15.71	11.25	1.40	86360.23
20	10.08	3.37	59.88	2.28	15.10	11.30	1.41	84899.18
21	7.69	3.20	56.80	1.80	16.06	11.09	1.42	86178.74
22	7.28	2.37	62.52	1.87	15.96	11.14	1.43	87155.31
23	8.50	5.24	56.51	1.77	15.99	11.11	1.43	86559.91
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.33	6.15	57.24	2.39	15.48	11.25	1.39	83020.89
最大值	12.48	20.36	63.79	3.83	18.04	11.89	1.43	87155.31
發生時間	9	11	4	14	2	12		22
最小值	4.28	2.21	44.96	1.51	12.23	10.66	1.36	78169.64
發生時間	1	18	7	1	12	2		12
零點偏移(率)	-0.09 %	-0.00 %	-0.01 %	0.00 %		0.03	0.00	0.00 %
全幅偏移(率)	2.93 %	0.85 %	-0.19 %	0.42 %		0.49	0.02	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								