

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 115年03月04日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	11.69	12.76	60.87	2.50	20.62	10.26	1.25	87432.52
1	9.46	12.94	51.36	2.95	19.52	10.62	1.25	85536.88
2	7.41	13.22	52.19	2.30	20.64	10.67	1.25	84321.73
3	7.46	13.24	53.45	2.60	20.37	10.53	1.25	86168.16
4	10.26	13.50	49.24	3.16	19.17	10.93	1.25	83893.62
5	5.63	13.72	43.33	1.53	16.88	10.91	1.25	86751.48
6	9.95	12.07	55.68	2.83	16.54	11.04	1.25	85683.65
7	4.99	12.21	54.22	3.77	16.34	11.18	1.25	83552.03
8	0.75	13.29	72.68	3.39	17.86	11.78	1.25	77518.82
9	3.46	11.71	45.14	3.24	18.71	10.46	1.25	88217.45
10	3.56	12.23	66.62	3.67	15.88	11.24	1.25	83708.78
11	4.21	12.60	62.02	3.70	15.18	11.56	1.25	81675.83
12	7.48	13.16	56.93	3.69	14.85	11.59	1.25	81232.28
13	6.86	13.09	53.28	3.73	14.93	11.54	1.25	80493.36
14	12.35	12.98	56.26	3.75	15.32	11.40	1.25	82782.98
15	10.12	13.01	56.30	3.44	16.25	11.28	1.25	83908.23
16	13.98	12.94	50.35	3.62	15.75	11.26	1.25	83645.53
17	5.74	12.86	54.97	3.21	15.95	11.21	1.25	84466.58
18	12.91	12.76	58.64	3.22	17.30	10.92	1.27	85350.75
19	11.49	12.76	51.42	3.68	15.69	11.05	1.28	85583.51
20	9.13	12.94	51.44	3.12	15.80	11.31	1.29	82036.79
21	9.18	13.06	53.87	3.15	15.75	11.42	1.29	82038.65
22	7.49	13.03	51.20	3.00	15.86	11.36	1.29	80454.60
23	8.48	13.15	45.22	2.90	16.92	11.05	1.29	83509.42
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.08	12.88	54.45	3.17	17.00	11.11	1.26	83748.48
最大值	13.98	13.72	72.68	3.77	20.64	11.78	1.29	88217.45
發生時間	16	5	8	7	2	8		9
最小值	0.75	11.71	43.33	1.53	14.85	10.26	1.24	77518.82
發生時間	8	9	5	5	12	0		8
零點偏移(率)	-0.01 %	0.01 %	-0.02 %	-0.01 %		-0.05	-0.01	0.40 %
全幅偏移(率)	0.33 %	-0.77 %	-0.05 %	-0.49 %		0.11	0.10	0.40 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 115年03月04日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	7.83	12.08	56.68	0.89	17.92	10.49	1.02	81644.49
1	12.26	11.96	45.86	1.01	18.88	10.21	1.02	78608.58
2	6.16	12.04	53.44	0.57	20.26	9.81	1.02	82818.02
3	11.19	12.12	46.53	1.18	18.98	10.21	1.02	82929.03
4	8.65	12.26	52.90	1.38	17.56	10.62	1.02	80910.05
5	11.01	12.88	66.84	1.77	16.93	11.09	1.02	81178.71
6	5.21	13.91	57.57	2.19	14.52	11.66	0.99	81649.29
7	9.98	13.37	54.86	2.00	14.74	11.67	0.99	78879.79
8	5.97	12.57	52.07	2.37	15.93	11.23	0.99	80833.16
9	8.85	12.21	56.37	2.56	15.38	11.16	1.00	78630.65
10	6.94	11.88	51.08	2.60	15.56	10.77	0.98	77333.22
11	10.05	12.11	63.34	2.23	15.27	11.12	0.98	77919.67
12	9.12	11.91	50.14	2.54	14.36	10.96	0.97	75792.17
13	8.49	12.13	55.37	3.16	15.67	10.78	0.98	78094.97
14	13.48	11.71	54.47	2.94	15.79	10.62	0.99	78448.80
15	6.25	11.78	55.61	1.34	16.68	10.59	0.98	78835.61
16	11.53	11.64	55.64	1.97	16.28	10.51	0.99	80515.19
17	10.61	11.62	56.32	2.69	16.13	10.48	0.99	80032.17
18	8.86	11.76	59.00	1.64	17.13	10.15	1.01	81692.05
19	6.03	11.79	49.63	1.33	17.31	10.30	1.02	79867.54
20	10.62	11.69	54.80	1.30	17.25	10.31	1.03	79111.39
21	10.28	11.69	55.45	2.22	15.93	10.51	1.04	78709.05
22	7.93	11.85	55.64	1.20	16.73	10.57	1.04	77990.38
23	9.64	11.87	45.21	1.20	19.00	9.84	1.03	81140.19
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	9.04	12.12	54.37	1.85	16.67	10.65	1.01	79731.84
最大值	13.48	13.91	66.84	3.16	20.26	11.67	1.05	82929.03
發生時間	14	6	5	13	2	7		3
最小值	5.21	11.62	45.21	0.57	14.36	9.81	0.97	75792.17
發生時間	6	17	23	2	12	2		12
零點偏移(率)	-0.04 %	-0.07 %	-0.01 %	-0.01 %		-0.05	-0.01	0.10 %
全幅偏移(率)	0.02 %	-0.70 %	0.34 %	-0.02 %		0.04	0.00	0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 115年03月04日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	5.08	12.09	66.55	2.78	17.91	10.66	1.39	73717.76
1	7.60	11.49	51.37	3.06	19.25	9.79	1.39	81718.88
2	6.10	11.70	60.73	3.01	19.20	10.11	1.38	79864.53
3	8.56	12.02	65.14	3.01	17.89	10.48	1.39	78116.47
4	7.51	12.14	61.62	3.09	15.82	10.96	1.39	74435.43
5	3.75	12.01	61.15	2.83	16.05	10.78	1.38	73618.26
6	5.05	11.92	54.17	3.23	15.72	10.46	1.39	76204.80
7	2.96	11.61	48.96	2.86	16.61	10.51	1.41	73816.49
8	3.17	12.00	45.12	3.06	16.22	10.46	1.41	77043.47
9	2.94	11.55	48.82	2.86	15.58	10.39	1.40	75171.01
10	2.84	12.64	43.12	3.68	14.89	10.19	1.41	73221.24
11	2.73	11.25	47.72	2.54	15.55	10.01	1.41	75901.23
12	10.38	11.67	57.02	3.09	15.15	10.19	1.42	74482.21
13	8.57	12.66	55.47	2.15	14.46	10.35	1.41	71772.21
14	13.18	11.91	59.15	2.69	15.25	10.14	1.42	73861.38
15	9.24	11.24	54.76	2.33	15.47	9.85	1.41	75067.18
16	6.14	11.04	50.69	1.46	16.52	9.53	1.41	76077.51
17	10.62	10.86	42.77	1.66	17.23	9.06	1.41	74869.65
18	9.51	11.50	41.47	2.12	16.68	8.90	1.41	75319.74
19	6.99	12.48	50.54	2.91	15.83	9.18	1.41	73445.91
20	10.92	11.52	51.16	2.39	17.39	9.13	1.40	74086.07
21	10.06	11.87	47.59	2.89	16.92	9.09	1.39	74042.44
22	8.15	11.78	51.71	2.59	18.20	9.17	1.40	72885.44
23	9.59	12.50	42.90	3.15	19.25	8.66	1.41	77228.40
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	7.15	11.81	52.49	2.73	16.63	9.92	1.40	75248.65
最大值	13.18	12.66	66.55	3.68	19.25	10.96	1.43	81718.88
發生時間	14	13	0	10	1	4		1
最小值	2.73	10.86	41.47	1.46	14.46	8.66	1.37	71772.21
發生時間	11	17	18	16	13	23		13
零點偏移(率)	0.00 %	-0.01 %	-0.11 %	-0.01 %		-0.06	-0.01	0.00 %
全幅偏移(率)	1.44 %	0.40 %	-0.10 %	0.01 %		-0.06	0.00	0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								