

## P001\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年04月07日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	7.44	3.49	56.94	2.42	17.97	11.83	1.45	71279.22
1	3.55	3.88	64.33	2.31	18.04	12.26	1.49	68710.46
2	0.66	4.23	69.34	2.58	16.73	12.93	1.46	63762.12
3	0.17	9.39	68.91	3.39	15.50	13.78	1.64	58796.03
4	0.18	6.58	64.27	2.97	15.95	13.41	1.56	61088.46
5	0.14	6.40	62.14	3.05	17.03	12.40	1.47	67045.75
6	0.51	3.09	57.32	2.65	16.62	11.64	1.43	74504.92
7	2.84	3.98	52.78	4.04	13.83	12.34	1.43	71751.33
8	5.67	4.34	61.08	3.41	16.18	12.11	1.43	71312.48
9	3.38	3.28	60.23	2.67	17.23	11.94	1.44	71265.89
10	3.92	3.47	59.26	3.00	16.61	12.28	1.46	69273.95
11	4.29	4.00	61.39	3.21	16.31	12.28	1.46	69205.35
12	3.57	3.64	59.35	3.03	16.98	12.19	1.46	69841.88
13	4.52	3.01	59.86	2.54	18.44	11.39	1.45	74685.56
14	5.70	3.16	57.01	2.99	16.67	11.87	1.46	72618.36
15	9.13	3.26	56.94	3.17	16.25	11.85	1.46	72613.70
16	10.22	3.13	56.94	3.49	15.83	11.85	1.44	73217.73
17	9.47	3.16	65.76	3.65	15.51	12.14	1.43	71832.80
18	8.34	5.11	65.41	3.81	15.59	12.61	1.42	67893.22
19	7.51	3.16	65.19	2.91	16.67	12.03	1.42	71872.32
20	6.94	3.17	54.77	3.50	14.71	12.07	1.43	72750.17
21	5.81	4.13	59.62	4.33	13.14	12.56	1.45	69675.38
22	8.79	5.36	63.53	4.63	13.18	12.49	1.46	70629.33
23	8.28	3.06	62.52	3.86	14.28	12.32	1.45	71005.60
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	5.04	4.14	61.04	3.23	16.05	12.27	1.46	69859.67
最大值	10.22	9.39	69.34	4.63	18.44	13.78	1.95	74685.56
發生時間	16	3	2	22	13	3		13
最小值	0.14	3.01	52.78	2.31	13.14	11.39	1.39	58796.03
發生時間	5	13	7	1	21	13		3
零點偏移(率)	-0.06 %	-0.02 %	-0.02 %	-0.01 %		-0.03	0.00	0.00 %
全幅偏移(率)	-0.59 %	-4.96 %	-0.50 %	-1.14 %		0.21	0.00	0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

## P002\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年04月07日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	3.58	6.29	48.00	1.20	19.68	10.48	1.44	83105.36
1	1.00	4.73	51.02	1.12	19.61	11.04	1.45	77733.91
2	1.41	6.45	55.81	1.63	18.94	10.91	1.47	78060.80
3	2.71	4.57	38.48	1.61	19.34	9.86	1.42	85860.20
4	6.03	4.68	44.57	1.95	18.93	9.97	1.45	85104.40
5	4.75	5.09	53.04	1.53	19.26	10.39	1.43	84861.36
6	8.69	4.22	55.18	2.01	18.93	10.56	1.43	77751.57
7	5.75	4.11	47.22	1.79	19.44	10.37	1.42	83379.63
8	6.57	3.83	46.18	1.80	20.13	10.03	1.44	86605.86
9	7.11	3.84	53.72	1.56	20.11	10.37	1.44	83761.49
10	9.94	9.44	48.65	3.35	18.18	10.18	1.42	86078.31
11	6.95	8.60	50.24	1.58	18.03	10.42	1.42	83437.66
12	8.81	23.20	50.31	2.26	16.82	10.76	1.43	83229.46
13	8.93	15.07	59.94	1.23	17.15	10.19	1.44	80644.36
14	9.54	13.99	50.31	1.33	18.79	9.95	1.43	83386.61
15	9.94	14.04	51.67	1.98	18.74	9.98	1.44	83373.82
16	9.62	9.76	50.60	2.91	17.40	10.01	1.45	83330.73
17	9.18	3.37	63.94	2.28	18.95	10.15	1.45	86236.34
18	9.88	5.40	46.17	2.64	20.20	9.62	1.45	88470.36
19	9.85	6.39	45.58	2.45	19.56	9.89	1.46	87761.59
20	9.43	4.40	46.73	2.86	17.20	10.53	1.46	83802.15
21	9.33	3.67	51.33	2.69	16.92	10.43	1.45	83419.70
22	8.65	5.05	51.11	2.56	17.33	10.20	1.45	82610.89
23	8.92	4.34	56.43	2.56	17.07	10.21	1.45	81490.53
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	7.36	7.27	50.68	2.04	18.61	10.27	1.44	83479.05
最大值	9.94	23.20	63.94	3.35	20.20	11.04	1.49	88470.36
發生時間	10	12	17	10	18	1		18
最小值	1.00	3.37	38.48	1.12	16.82	9.62	1.38	77733.91
發生時間	1	17	3	1	12	18		1
零點偏移(率)	-0.10 %	-0.09 %	-0.02 %	-0.01 %		-0.06	0.00	0.00 %
全幅偏移(率)	-3.38 %	0.03 %	-0.36 %	0.03 %		-0.04	0.00	0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

## P003\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年04月07日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	4.07	6.70	53.16	1.80	18.43	10.51	1.39	83146.54
1	3.93	10.94	52.92	1.74	17.84	10.84	1.39	82641.24
2	4.70	7.65	57.82	1.95	19.23	10.02	1.38	90086.73
3	9.53	4.63	51.82	2.26	17.82	10.34	1.39	89189.78
4	6.98	6.63	52.98	2.20	18.05	10.34	1.37	88995.41
5	4.88	9.14	60.77	2.06	19.21	10.37	1.37	86960.84
6	6.72	7.67	47.88	1.96	17.76	10.49	1.36	87737.80
7	校正	無效	校正	校正	替代	校正	1.35	84515.70
8	3.70	15.54	46.78	1.70	18.26	10.69	1.37	84666.11
9	4.86	5.85	52.73	1.47	17.00	11.15	1.37	82650.48
10	7.38	3.84	58.28	1.85	16.43	11.08	1.37	82158.07
11	6.53	5.30	55.89	2.37	15.89	11.31	1.36	79359.97
12	7.38	4.04	57.94	2.03	15.85	11.19	1.37	82967.64
13	10.03	6.58	59.07	2.81	14.13	11.51	1.36	78602.15
14	12.05	11.25	60.62	2.91	15.83	11.41	1.38	79157.55
15	9.20	5.66	56.62	2.42	16.12	11.16	1.38	85432.03
16	11.77	6.71	59.04	2.64	15.93	11.17	1.38	84241.82
17	8.47	4.70	62.64	2.20	15.45	11.38	1.38	84105.68
18	7.50	3.94	62.90	1.67	17.40	11.12	1.38	83464.90
19	5.42	4.74	65.42	1.70	16.64	11.54	1.38	81473.61
20	10.70	6.25	51.82	1.77	16.84	10.73	1.38	86641.75
21	12.15	10.54	53.84	2.25	14.72	11.20	1.39	81810.66
22	11.16	6.17	56.81	2.43	14.61	11.32	1.40	80868.44
23	9.31	6.16	54.82	2.27	14.93	11.08	1.38	81249.07
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	23	23	23	23	23	23	24	24
平均值	7.76	6.98	56.20	2.11	16.71	10.95	1.38	83838.50
最大值	12.15	15.54	65.42	2.91	19.23	11.54	1.43	90086.73
發生時間	21	8	19	14	2	19		2
最小值	3.70	3.84	46.78	1.47	14.13	10.02	1.32	78602.15
發生時間	8	10	8	9	13	2		13
零點偏移(率)	-0.02 %	-0.00 %	-0.18 %	-0.04 %		0.02	0.00	0.00 %
全幅偏移(率)	-3.27 %	0.59 %	0.25 %	0.03 %		0.33	0.02	0.20 %
有效比率	95.83 %	95.83 %	95.83 %	95.83 %	95.83 %	95.83 %	100.00 %	100.00 %
備註								