

P001 樹林焚化廠CEMS系統日報表-A

報表日期: 114年05月26日

項目 單位 小時\限標	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.45	4.08	46.93	1.79	14.09	11.80	1.42	79020.97
1	8.48	2.20	42.14	1.56	14.73	11.87	1.53	78086.26
2	7.56	1.08	68.17	2.87	15.09	11.92	1.33	77190.66
3	3.63	3.64	67.34	2.31	16.12	10.98	1.46	77182.84
4	3.62	1.22	67.68	3.64	14.11	11.40	1.84	79583.40
5	2.69	7.50	54.40	3.74	14.43	11.50	4.16	74745.52
6	4.36	2.79	43.64	4.56	13.58	11.67	1.50	73453.67
7	3.89	1.69	44.88	2.09	14.88	11.46	1.27	76412.87
8	5.95	2.04	64.85	2.38	13.76	11.88	1.16	76787.56
9	5.56	1.84	54.85	2.18	13.96	11.99	1.17	76370.77
10	7.69	1.57	70.07	1.79	15.10	11.96	1.04	78797.65
11	8.90	1.51	70.44	2.16	14.45	12.13	1.00	78464.33
12	8.08	1.37	61.64	2.38	13.69	12.09	1.34	78683.45
13	6.52	1.51	56.26	2.21	13.43	12.28	1.64	76703.61
14	2.58	1.69	64.38	2.84	13.97	11.87	1.60	77802.64
15	0.98	2.41	52.11	3.81	12.71	12.35	1.84	76744.19
16	0.45	5.35	48.84	3.07	13.62	12.14	1.53	77763.27
17	1.06	6.35	57.69	3.76	12.65	12.30	1.32	75094.86
18	6.11	1.22	68.00	3.22	14.58	12.14	1.42	76175.23
19	7.15	4.75	56.02	4.82	13.66	11.78	1.40	79719.98
20	3.27	3.66	63.37	3.71	14.08	11.93	1.39	77287.62
21	3.80	2.34	69.65	3.16	14.45	11.82	1.39	78118.99
22	2.55	2.73	66.25	3.19	14.23	12.04	1.39	76256.10
23	3.90	2.22	57.96	2.27	15.29	12.10	1.39	76472.28
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	4.93	2.78	59.07	2.90	14.19	11.89	1.51	77204.95
最 大 值	9.45	7.50	70.44	4.82	16.12	12.35	5.71	79719.98
發生時間	0	5	11	19	3	15		19
最 小 值	0.45	1.08	42.14	1.56	12.65	10.98	0.47	73453.67
發生時間	16	2	1	1	17	3		6
零點偏移(率)	-0.09 %	0.01 %	-0.02 %	-0.00 %		0.02		0.20 %
全幅偏移(率)	0.00 %	-0.16 %	-0.36 %	-0.15 %		0.16		0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002 樹林焚化廠CEMS系統日報表-A

報表日期: 114年05月26日

項目 單位 小時\限標	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.04	2.81	47.44	2.13	16.06	10.17	1.02	82780.20
1	5.22	3.16	39.61	1.89	17.26	9.95	1.02	82167.68
2	8.82	1.41	38.20	1.91	16.37	9.59	1.02	82533.71
3	7.94	5.89	33.86	1.61	16.33	9.95	1.02	80444.53
4	2.46	4.64	49.01	0.85	17.49	10.43	1.02	78786.55
5	6.28	2.74	48.96	1.11	18.13	9.50	1.01	85813.48
6	5.43	9.05	46.87	0.62	19.71	9.47	0.99	89436.02
7	5.64	2.76	47.20	0.92	18.55	9.26	1.01	90532.33
8	8.18	1.51	43.52	1.23	17.23	10.24	1.00	87616.14
9	7.30	3.24	34.94	1.01	17.11	10.07	0.98	87377.68
10	3.42	7.88	60.24	0.79	18.96	9.88	0.97	86594.27
11	0.48	4.29	53.91	2.47	13.92	11.93	1.01	71934.06
12	0.48	4.12	44.23	1.28	16.65	10.89	1.02	81362.11
13	1.20	1.87	48.75	0.95	16.89	10.04	1.00	86193.83
14	1.86	3.87	38.40	1.58	15.70	10.31	0.98	82622.10
15	0.20	2.21	50.27	1.95	15.92	10.77	0.98	83458.20
16	0.99	5.59	50.96	1.73	16.26	10.62	0.99	84595.61
17	2.25	2.77	61.13	1.03	18.15	9.82	0.99	89505.25
18	3.39	3.53	58.78	0.74	18.60	10.01	1.00	87572.16
19	8.90	1.20	68.29	1.47	17.33	10.17	1.01	89099.47
20	7.19	2.19	65.47	1.83	16.02	10.84	1.00	84526.66
21	6.06	1.86	54.32	1.83	16.61	10.75	1.00	81291.41
22	4.61	3.68	53.07	0.88	18.99	10.05	1.00	87306.72
23	7.82	2.77	53.55	1.14	19.20	9.81	0.99	88273.76
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	4.80	3.54	49.62	1.37	17.23	10.19	1.00	84659.33
最 大 值	9.04	9.05	68.29	2.47	19.71	11.93	1.03	90532.33
發生時間	0	6	19	11	6	11		7
最 小 值	0.20	1.20	33.86	0.62	13.92	9.26	0.97	71934.06
發生時間	15	19	3	6	11	7		11
零點偏移(率)	0.00 %	-0.00 %	-0.03 %	0.00 %		-0.01		0.10 %
全幅偏移(率)	-0.19 %	0.23 %	0.26 %	0.40 %		0.07		0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A 報表日期: 114年05月26日

報表日期: 114年05月26日

項目 單位 小時\限標	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	4.07	2.74	63.32	2.77	16.02	9.54	1.45	75871.72
1	1.15	1.78	45.79	0.92	18.35	8.85	1.43	76483.82
2	0.34	5.71	52.84	1.75	15.75	9.54	1.43	69282.59
3	1.49	4.88	54.88	2.49	15.50	9.43	1.44	77019.26
4	2.61	4.57	56.33	2.21	15.58	9.59	1.45	77587.73
5	5.02	5.52	55.37	2.28	16.38	9.43	1.45	78898.56
6	9.52	4.44	47.81	2.58	16.20	9.40	1.45	79921.49
7	5.40	4.63	52.94	1.91	19.46	9.22	1.46	78034.09
8	6.44	5.72	56.73	1.96	19.25	8.93	1.47	84172.58
9	6.79	4.18	54.41	1.73	18.18	9.43	1.48	84354.23
10	10.52	2.49	62.56	2.03	16.27	9.94	1.48	80801.41
11	0.93	1.33	60.53	0.78	16.47	10.34	1.47	65426.63
12	2.03	2.87	58.53	1.10	17.58	9.61	1.48	74039.64
13	0.23	2.06	48.15	1.02	18.22	8.62	1.47	77638.23
14	1.69	8.42	51.92	1.79	15.66	9.62	1.48	78568.25
15	0.78	4.10	58.81	1.44	16.13	9.97	1.48	77287.15
16	0.54	4.13	58.61	1.52	15.50	9.94	1.48	78837.28
17	0.19	7.61	58.13	1.87	15.30	10.08	1.48	76406.15
18	3.20	4.22	56.80	1.47	19.39	8.95	1.47	76522.50
19	11.35	6.66	58.60	2.74	17.16	9.39	1.48	82685.83
20	4.63	6.27	55.65	1.96	18.14	9.40	1.48	82282.60
21	4.57	7.15	54.86	1.74	18.38	9.32	1.48	83750.24
22	1.77	2.50	60.44	1.39	19.51	9.31	1.48	80174.65
23	1.21	6.98	44.48	1.29	19.58	8.71	1.48	85240.94
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	3.60	4.62	55.35	1.78	17.25	9.44	1.47	78386.98
最 大 值	11.35	8.42	63.32	2.77	19.58	10.34	1.49	85240.94
發生時間	19	14	0	0	23	11		23
最 小 值	0.19	1.33	44.48	0.78	15.30	8.62	1.43	65426.63
發生時間	17	11	23	11	17	13		11
零點偏移(率)	-0.01 %	-0.04 %	-0.10 %	-0.01 %		0.01		0.00 %
全幅偏移(率)	0.02 %	-0.29 %	-0.09 %	0.01 %		0.11		0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								