

P002 樹林焚化廠CEMS系統日報表-A

報表日期: 114年02月01日

項目 單位 小時\限標	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	11.90	3.82	55.10	2.26	14.96	11.07	1.08	84007.87
1	16.38	4.36	54.50	3.22	14.47	11.07	1.06	84352.14
2	9.22	2.87	55.72	2.71	13.52	11.45	1.06	82242.35
3	7.19	2.53	41.51	1.96	15.06	10.89	1.06	82253.61
4	5.99	6.63	41.91	2.03	14.60	11.00	1.06	83278.07
5	12.76	1.38	52.02	2.86	14.22	11.23	1.06	82986.64
6	8.47	3.91	48.96	1.49	14.47	11.00	1.06	79803.76
7	4.71	1.65	51.23	1.11	14.39	11.01	1.06	82397.76
8	1.95	1.76	51.45	0.77	13.96	11.13	1.08	82375.74
9	1.27	2.09	50.55	0.67	13.99	11.30	1.09	82244.82
10	2.98	1.82	67.25	1.25	14.97	11.38	1.06	78027.26
11	2.13	2.26	64.78	1.25	15.22	11.14	1.06	79483.36
12	6.17	7.20	51.00	1.42	15.32	10.95	1.07	84427.09
13	1.48	3.47	46.84	1.46	14.72	11.32	1.06	81794.06
14	4.11	2.39	56.09	1.53	15.18	12.28	1.10	73666.19
15	3.26	4.97	45.13	0.87	19.03	10.13	1.08	87769.55
16	3.36	0.30	31.10	1.77	16.79	10.48	1.06	87605.53
17	3.65	2.34	49.32	1.78	15.97	10.82	1.05	84516.01
18	3.60	2.80	48.55	1.14	16.07	10.70	1.04	81500.37
19	3.73	1.87	50.28	0.87	16.85	10.70	1.05	82669.49
20	3.63	5.05	33.22	1.13	16.60	10.73	1.05	84321.91
21	3.76	2.83	44.45	1.18	16.65	11.09	1.04	82420.17
22	3.68	2.24	47.28	2.43	16.47	10.84	1.03	85205.96
23	3.60	7.14	38.34	1.18	16.08	10.74	1.04	83696.69
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	5.37	3.24	49.02	1.60	15.40	11.02	1.06	82626.93
最 大 值	16.38	7.20	67.25	3.22	19.03	12.28	1.25	87769.55
發生時間	1	12	10	1	15	14		15
最 小 值	1.27	0.30	31.10	0.67	13.52	10.13	1.03	73666.19
發生時間	9	16	16	9	2	15		14
零點偏移(率)	-0.01 %	-0.00 %	-0.06 %	0.00 %		-0.04		0.00 %
全幅偏移(率)	0.14 %	0.46 %	-0.88 %	0.34 %		-0.14		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A 報表日期: 114年02月01日

報表日期: 114年02月01日

項目 單位 小時\限標	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	12.14	3.66	45.02	1.46	16.18	10.49	1.52	82566.72
1	12.38	6.02	48.62	2.29	15.90	10.51	1.52	82475.99
2	8.38	2.28	50.31	2.62	15.36	10.64	1.52	82349.26
3	8.67	6.58	48.24	3.38	14.43	10.91	1.52	81148.53
4	11.24	6.37	49.02	2.87	13.85	10.99	1.53	80877.90
5	9.03	3.69	50.39	0.79	13.32	11.30	1.54	78487.04
6	11.31	1.90	57.24	1.59	16.51	10.24	1.56	85013.70
7	11.34	10.21	60.23	1.50	15.66	10.28	1.52	81376.35
8	10.28	2.88	62.76	2.27	15.33	10.57	1.53	83117.94
9	9.00	4.34	58.30	2.55	15.12	10.56	1.53	83095.79
10	8.75	4.00	67.81	1.43	16.27	10.53	1.53	82612.56
11	8.90	7.19	58.10	0.85	16.88	10.34	1.53	83283.12
12	7.11	4.31	60.74	0.85	16.87	10.21	1.52	83679.08
13	4.38	3.17	57.43	0.70	16.38	10.53	1.51	81940.77
14	5.25	2.30	55.38	0.65	17.08	10.36	1.52	82176.98
15	4.07	4.70	47.04	0.45	17.99	10.06	1.52	83738.99
16	5.83	4.67	40.12	0.82	16.07	10.52	1.51	81719.52
17	8.00	1.88	47.15	1.73	15.14	10.86	1.51	79097.91
18	5.77	4.61	48.42	1.42	14.95	10.89	1.51	79318.25
19	5.39	1.02	58.04	1.07	16.32	10.90	1.51	78960.30
20	3.67	3.53	44.82	0.72	16.72	10.27	1.51	83885.53
21	3.08	2.25	53.24	0.68	17.58	10.34	1.51	81872.14
22	5.23	1.92	48.74	1.39	15.41	10.74	1.52	81004.43
23	4.88	1.73	55.68	1.38	15.74	10.97	1.52	79807.48
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	7.67	3.97	53.03	1.48	15.88	10.58	1.52	81816.93
最 大 值	12.38	10.21	67.81	3.38	17.99	11.30	1.57	85013.70
發生時間	1	7	10	3	15	5		6
最 小 值	3.08	1.02	40.12	0.45	13.32	10.06	1.50	78487.04
發生時間	21	19	16	15	5	15		5
零點偏移(率)	-0.03 %	0.00 %	-0.02 %	-0.00 %		-0.05		0.00 %
全幅偏移(率)	0.37 %	0.09 %	-0.05 %	0.29 %		-0.16		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								