

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 112年05月16日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	7.65	3.49	46.74	6.03	14.11	12.88	1.58	68891.61
1	7.33	2.69	60.94	5.24	15.42	12.69	1.63	71129.57
2	10.55	8.84	39.63	7.02	14.37	12.33	1.54	71142.57
3	9.62	5.44	54.36	6.21	13.98	12.92	1.51	66954.77
4	8.09	4.05	68.34	5.44	15.19	13.08	1.64	67876.61
5	9.04	7.16	53.13	5.23	14.56	12.84	1.69	69860.62
6	9.37	5.89	52.07	5.55	14.54	12.63	1.67	70305.10
7	8.30	6.63	57.89	5.72	13.84	13.08	1.61	66554.56
8	6.87	3.36	57.49	4.75	15.56	12.39	1.58	71955.12
9	6.69	5.29	50.74	4.96	14.69	12.74	1.60	69796.71
10	8.64	8.60	61.36	5.55	14.92	12.54	1.56	70866.31
11	7.28	13.84	43.49	8.08	11.97	12.90	1.48	66722.84
12	9.46	6.07	46.84	8.18	13.09	12.76	1.43	66100.43
13	9.99	10.55	47.10	8.44	12.78	12.85	1.46	66487.34
14	7.18	6.10	44.08	6.88	12.89	12.73	1.43	66388.47
15	3.38	4.57	61.68	5.38	14.13	13.23	1.53	65472.56
16	7.62	5.83	54.47	5.13	15.23	12.26	1.56	74018.84
17	10.24	7.45	52.84	5.42	15.07	12.31	1.56	73576.26
18	9.62	13.29	51.40	6.39	13.26	12.80	1.54	69995.82
19	7.72	6.04	52.85	5.94	13.75	12.72	1.52	70095.06
20	9.45	2.76	53.46	5.38	14.39	12.56	1.47	70290.31
21	10.84	6.38	52.01	6.40	13.03	12.81	1.45	67069.29
22	9.37	12.84	51.91	8.12	12.15	12.71	1.46	68830.52
23	9.82	2.44	53.37	6.12	14.78	12.20	1.51	72869.02
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.50	6.65	52.84	6.15	14.07	12.71	1.54	69302.10
最大值	10.84	13.84	68.34	8.44	15.56	13.23	1.72	74018.84
發生時間	21	11	4	13	8	15		16
最小值	3.38	2.44	39.63	4.75	11.97	12.20	1.42	65472.56
發生時間	15	23	2	8	11	23		15
零點偏移(率)	-0.06 %	-0.04 %	-0.02 %	-0.07 %		-0.02	0.00	0.00 %
全幅偏移(率)	-0.53 %	0.48 %	-0.14 %	0.18 %		-0.08	-0.03	0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 112年05月16日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	5.38	2.94	48.60	1.91	19.49	9.33	1.41	86784.68
1	5.32	2.32	46.37	2.07	19.61	9.60	1.41	86973.93
2	3.23	3.75	55.12	2.17	19.18	9.73	1.41	82720.61
3	4.08	2.57	44.24	2.35	19.13	9.13	1.41	84973.44
4	8.09	1.33	47.68	2.35	19.86	9.41	1.40	87544.45
5	4.82	2.43	50.24	1.67	20.38	9.76	1.40	86504.26
6	2.22	5.47	60.46	1.57	18.62	10.55	1.37	83012.22
7	0.48	4.24	55.47	1.22	20.21	10.03	1.38	83755.81
8	0.78	5.10	55.45	1.14	20.79	9.82	1.40	85506.52
9	0.97	6.71	44.74	1.21	21.00	9.17	1.38	88683.14
10	2.78	4.76	39.51	1.57	19.89	9.36	1.39	87238.26
11	5.60	4.87	46.00	1.85	18.86	9.41	1.40	84785.96
12	4.19	3.78	50.44	2.03	17.39	9.73	1.38	82190.87
13	6.83	5.94	55.14	5.93	15.52	9.58	1.38	81307.07
14	8.63	1.09	51.06	3.20	16.72	9.59	1.39	79960.84
15	8.57	2.86	40.09	3.61	16.46	9.30	1.41	78840.86
16	8.30	4.96	61.81	2.84	16.14	10.08	1.41	84858.19
17	9.94	11.34	52.86	5.35	16.03	10.18	1.38	78643.60
18	2.91	4.65	51.11	1.90	18.59	10.37	1.38	75720.98
19	7.14	3.62	51.88	1.95	19.55	9.47	1.38	85956.19
20	9.67	2.49	52.78	2.69	17.81	9.85	1.38	82712.63
21	11.33	2.72	54.21	3.41	17.07	9.91	1.37	82821.48
22	9.11	1.87	55.86	2.64	18.75	9.84	1.35	81942.66
23	8.75	2.12	52.85	2.01	20.49	9.68	1.34	84568.09
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	5.80	3.91	51.00	2.44	18.65	9.70	1.39	83666.95
最大值	11.33	11.34	61.81	5.93	21.00	10.55	1.42	88683.14
發生時間	21	17	16	13	9	6		9
最小值	0.48	1.09	39.51	1.14	15.52	9.13	1.34	75720.98
發生時間	7	14	10	8	13	3		18
零點偏移(率)	-0.07 %	-0.06 %	-0.02 %	-0.06 %		0.00	0.00	-0.20 %
全幅偏移(率)	-1.77 %	0.27 %	-0.39 %	0.27 %		0.15	-0.03	-0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 112年05月16日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	6.37	3.05	48.65	1.85	17.56	10.48	1.37	83773.93
1	5.68	2.58	53.64	1.95	18.50	10.31	1.38	85637.99
2	7.48	2.58	55.79	2.14	17.65	10.49	1.38	84465.32
3	6.75	2.70	51.24	2.15	17.59	10.30	1.38	84876.14
4	6.40	2.39	51.67	2.05	18.66	10.05	1.38	87783.04
5	4.16	2.61	52.05	1.75	19.45	10.20	1.38	85903.40
6	5.12	4.06	46.63	1.80	18.77	10.24	1.38	84725.57
7	4.41	5.11	51.00	2.37	18.81	10.11	1.38	90303.59
8	3.13	7.11	49.87	2.17	19.60	9.81	1.38	87799.48
9	4.37	6.03	47.77	2.14	18.99	10.05	1.38	88189.98
10	6.26	6.50	49.76	2.26	18.88	10.03	1.40	87777.70
11	6.18	6.31	54.07	2.27	17.22	10.45	1.38	84904.31
12	9.83	7.21	62.68	3.14	15.20	11.00	1.38	79990.78
13	10.79	9.86	46.58	4.30	13.89	10.54	1.34	74503.37
14	10.35	7.50	45.79	5.03	14.05	10.28	1.34	77041.64
15	3.27	3.48	46.29	2.73	14.60	10.37	1.35	75388.33
16	5.55	3.75	63.75	3.22	14.28	11.24	1.38	77069.74
17	6.74	3.39	55.46	3.34	14.19	11.04	1.38	75470.10
18	5.24	2.45	64.34	2.59	16.33	10.68	1.38	79124.02
19	3.63	2.84	60.80	2.24	18.42	10.26	1.38	82243.12
20	6.41	4.25	57.95	2.49	16.37	10.76	1.37	82528.15
21	9.36	3.28	59.33	3.08	15.29	10.99	1.37	80271.58
22	8.80	2.57	59.70	2.77	16.52	10.65	1.38	81696.90
23	5.65	1.92	67.79	2.41	17.94	10.68	1.37	82552.51
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	6.33	4.31	54.28	2.59	17.03	10.46	1.37	82667.53
最大值	10.79	9.86	67.79	5.03	19.60	11.24	1.41	90303.59
發生時間	13	13	23	14	8	16		7
最小值	3.13	1.92	45.79	1.75	13.89	9.81	1.31	74503.37
發生時間	8	23	14	5	13	8		13
零點偏移(率)	-0.02 %	-0.10 %	-0.03 %	-0.08 %		0.00	0.00	0.00 %
全幅偏移(率)	0.21 %	0.73 %	-0.81 %	0.18 %		-0.16	0.02	0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								