

P001\_樹林焚化廠CEMS系統日報表-A

報表日期: 115年04月24日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.22	11.78	34.16	1.78	18.20	10.96	1.18	76508.96
1	8.22	12.85	26.91	2.41	18.56	11.09	1.18	75056.04
2	7.68	11.70	49.84	1.89	20.19	10.91	1.18	75299.40
3	7.37	12.50	45.36	1.85	19.48	10.64	1.18	77289.84
4	17.06	11.35	57.65	3.46	18.12	11.04	1.19	76544.32
5	11.79	12.93	51.44	2.82	17.22	11.51	1.23	75661.21
6	6.75	12.37	55.61	0.65	19.10	10.78	1.23	76465.37
7	9.80	12.75	57.25	2.04	18.25	11.09	1.23	74906.14
8	4.17	12.04	55.87	2.42	17.29	11.17	1.23	75383.14
9	8.57	11.96	62.71	1.65	16.50	11.44	1.23	74267.49
10	12.88	11.66	59.02	1.55	16.82	11.40	1.23	74369.30
11	11.59	12.34	59.77	1.60	16.76	11.92	1.23	70215.43
12	16.78	12.12	56.65	2.05	16.18	11.60	1.23	73149.41
13	8.96	12.30	64.40	1.88	15.63	11.62	1.23	73787.80
14	3.86	12.32	57.65	1.53	16.24	11.69	1.24	73293.19
15	7.17	12.04	61.50	2.38	16.32	11.66	1.24	73125.50
16	9.63	11.99	56.61	2.65	16.59	11.71	1.25	72304.94
17	7.88	11.95	58.71	1.73	17.85	11.34	1.25	74265.97
18	8.92	12.19	46.48	2.52	16.67	11.29	1.23	75915.18
19	9.68	12.09	56.70	3.83	14.72	11.82	1.22	73186.65
20	6.84	11.90	59.11	2.07	16.11	11.63	1.20	73208.34
21	7.46	12.53	64.37	3.22	14.77	12.00	1.18	71100.04
22	7.70	12.82	53.48	1.80	18.19	11.32	1.18	73516.16
23	15.49	12.55	45.27	2.95	15.71	11.59	1.19	73325.31
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	9.35	12.21	54.02	2.20	17.14	11.38	1.22	74256.05
最大值	17.06	12.93	64.40	3.83	20.19	12.00	1.25	77289.84
發生時間	4	5	13	19	2	21		3
最小值	3.86	11.35	26.91	0.65	14.72	10.64	1.18	70215.43
發生時間	14	4	1	6	19	3		11
零點偏移(率)	-0.04 %	-0.00 %	-0.01 %	-0.00 %		-0.08	-0.01	0.30 %
全幅偏移(率)	0.95 %	-0.87 %	-0.29 %	-0.19 %		-0.04	-0.06	0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

## P002\_樹林焚化廠CEMS系統日報表-A

報表日期: 115年04月24日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	7.22	11.92	52.13	1.80	17.95	10.40	0.91	80001.55
1	8.71	12.14	56.69	1.69	18.52	10.61	0.92	78454.81
2	11.40	12.06	50.51	2.82	18.00	10.28	0.91	80998.38
3	6.11	12.81	53.81	3.25	16.63	10.58	0.91	79157.52
4	7.81	12.15	59.53	2.80	16.36	10.73	0.92	79324.18
5	8.45	11.96	54.21	3.11	17.79	10.58	0.92	81125.51
6	10.48	11.49	62.95	3.65	18.20	10.07	0.94	80185.79
7	9.72	11.66	58.19	2.00	17.77	10.38	0.93	79894.96
8	8.49	12.30	51.25	2.63	16.77	10.92	0.93	78936.76
9	9.88	12.16	61.04	2.35	16.96	10.91	0.93	80767.60
10	11.20	12.34	60.33	2.52	16.77	11.04	0.93	79583.41
11	9.16	12.23	68.13	2.77	15.70	10.99	0.93	79481.87
12	11.37	12.77	45.64	3.06	15.13	10.96	0.93	74277.66
13	10.87	13.14	61.24	3.05	15.49	11.36	0.93	73668.26
14	10.46	12.28	56.76	2.75	15.44	11.00	0.94	75800.76
15	8.45	11.87	53.56	3.51	16.34	10.74	0.94	78532.04
16	10.19	12.10	53.56	2.33	16.13	10.96	0.94	78327.72
17	10.37	12.03	58.47	2.14	16.20	10.91	0.94	77670.94
18	5.85	11.93	50.10	1.71	16.59	10.66	0.94	79386.69
19	8.12	12.16	49.34	2.10	15.43	10.96	0.94	75780.00
20	9.90	12.77	60.36	3.11	14.54	11.30	0.94	73675.57
21	9.45	12.05	58.81	3.06	14.98	10.89	0.94	76229.86
22	10.17	11.89	58.65	3.24	17.13	10.50	0.94	80434.32
23	9.05	11.64	58.67	2.43	17.88	10.34	0.94	80814.26
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	9.29	12.16	56.41	2.66	16.61	10.75	0.93	78437.93
最大值	11.40	13.14	68.13	3.65	18.52	11.36	0.95	81125.51
發生時間	2	13	11	6	1	13		5
最小值	5.85	11.49	45.64	1.69	14.54	10.07	0.90	73668.26
發生時間	18	6	12	1	20	6		13
零點偏移(率)	-0.01 %	-0.07 %	-0.03 %	-0.01 %		-0.09	-0.01	-0.10 %
全幅偏移(率)	-0.31 %	-1.07 %	0.99 %	-0.07 %		0.02	0.00	0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

## P003\_樹林焚化廠CEMS系統日報表-A

報表日期: 115年04月24日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	4.17	11.40	51.64	2.84	18.38	9.79	1.31	72869.44
1	2.94	11.52	45.02	2.54	20.27	9.41	1.32	72129.36
2	1.98	12.34	52.43	2.69	19.55	10.25	1.31	66473.41
3	3.00	12.69	35.11	2.68	20.13	9.11	1.31	74625.29
4	5.99	11.29	45.71	2.85	19.85	9.25	1.31	77101.66
5	5.43	11.41	40.12	2.72	19.84	9.31	1.30	75710.02
6	5.92	12.05	54.97	2.63	20.05	8.99	1.31	78052.98
7	3.60	12.00	40.57	2.62	20.38	9.13	1.35	77224.09
8	3.89	11.39	57.19	1.98	19.79	9.62	1.36	80351.84
9	4.91	11.39	50.67	1.85	19.20	9.95	1.36	78635.07
10	4.47	11.69	59.46	1.95	18.04	10.40	1.36	76625.91
11	5.11	11.57	54.09	1.92	16.81	10.31	1.37	76075.35
12	6.02	11.23	51.47	1.91	17.38	10.00	1.36	75054.78
13	4.93	11.29	57.69	2.05	16.60	10.09	1.34	74171.90
14	6.26	11.22	52.68	2.05	17.04	9.96	1.34	75042.16
15	5.09	11.72	63.38	2.58	18.36	10.35	1.35	75087.82
16	7.51	11.56	48.67	2.56	17.56	9.84	1.36	78262.11
17	8.38	11.73	57.84	2.84	16.81	10.17	1.35	76946.75
18	9.33	11.68	60.35	2.90	16.65	10.23	1.36	76603.10
19	8.83	11.97	61.23	2.76	16.55	10.29	1.35	75983.44
20	8.32	11.60	61.48	2.82	17.59	9.99	1.36	78177.83
21	8.30	13.13	54.70	4.20	16.74	9.75	1.36	78772.35
22	6.70	11.23	42.08	2.32	17.29	9.34	1.36	74967.92
23	5.00	11.79	36.60	2.49	19.60	8.62	1.36	75616.01
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	5.67	11.70	51.46	2.53	18.35	9.76	1.34	75856.69
最大值	9.33	13.13	63.38	4.20	20.38	10.40	1.39	80351.84
發生時間	18	21	15	21	7	10		8
最小值	1.98	11.22	35.11	1.85	16.55	8.62	1.29	66473.41
發生時間	2	14	3	9	19	23		2
零點偏移(率)	-0.13 %	-0.00 %	-0.01 %	-0.00 %		-0.11	-0.01	0.10 %
全幅偏移(率)	0.21 %	-0.90 %	0.32 %	0.09 %		0.22	0.04	0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								