

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 115年06月06日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.16	11.78	58.57	3.84	16.68	11.59	1.20	79919.62
1	10.11	11.83	58.89	4.50	16.32	11.61	1.20	80085.35
2	7.19	11.48	56.20	3.95	19.40	10.53	1.20	86217.68
3	10.25	10.94	58.00	3.79	19.45	10.47	1.20	87070.45
4	8.85	11.48	58.89	3.79	17.94	11.00	1.20	83545.22
5	14.29	13.02	53.63	2.75	18.08	11.10	1.20	85260.24
6	9.51	12.56	51.68	1.68	18.43	10.74	1.20	85132.06
7	6.80	12.37	56.05	1.51	18.51	10.77	1.20	84991.32
8	10.88	12.52	55.73	1.72	18.46	10.92	1.20	83478.33
9	8.59	12.34	53.81	1.94	17.90	10.84	1.20	84965.48
10	11.92	12.25	61.79	1.56	18.61	10.71	1.19	85441.62
11	6.76	12.43	55.79	1.61	17.78	10.95	1.20	84118.03
12	8.49	12.14	66.43	1.42	19.18	10.85	1.21	83106.12
13	11.57	10.89	55.48	2.09	18.22	10.55	1.20	86934.00
14	7.84	10.86	53.21	1.60	19.08	10.44	1.20	86522.41
15	7.76	11.97	58.90	1.86	18.16	11.33	1.20	80303.56
16	10.34	10.89	41.98	1.30	19.20	10.45	1.21	86863.89
17	7.39	11.00	48.46	1.56	18.21	10.70	1.23	85720.95
18	9.20	10.96	62.17	1.47	19.17	10.54	1.22	86340.62
19	10.52	10.80	49.49	1.39	19.78	10.03	1.23	89570.30
20	7.99	10.57	51.71	1.13	20.44	9.82	1.23	90212.66
21	9.24	10.76	56.42	2.03	20.04	10.20	1.23	87299.55
22	7.66	11.07	53.17	2.27	19.70	10.54	1.23	85112.99
23	9.07	11.03	62.21	1.80	20.70	10.35	1.23	85279.79
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	9.18	11.58	55.78	2.19	18.73	10.71	1.21	85145.51
最大值	14.29	13.02	66.43	4.50	20.70	11.61	1.27	90212.66
發生時間	5	5	12	1	23	1		20
最小值	6.76	10.57	41.98	1.13	16.32	9.82	1.18	79919.62
發生時間	11	20	16	20	1	20		0
零點偏移(率)	-0.22 %	0.00 %	-0.03 %	0.00 %		-0.01	-0.01	0.10 %
全幅偏移(率)	-1.63 %	-0.46 %	0.61 %	-0.13 %		0.01	-0.06	0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 115年06月06日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	0.50	12.91	59.93	0.69	19.41	11.08	0.99	76476.43
1	0.46	12.27	46.77	1.28	20.14	10.57	0.98	82345.28
2	0.71	12.61	50.59	2.66	18.70	10.72	0.98	82852.03
3	0.52	12.05	58.48	1.72	19.04	10.55	0.99	84100.50
4	0.95	12.09	63.14	1.71	19.01	10.60	0.99	83523.48
5	0.62	12.04	57.95	1.72	18.94	10.59	0.99	83846.24
6	1.37	11.48	60.10	1.34	19.65	10.37	0.99	88479.94
7	1.09	12.19	60.29	1.19	19.23	10.70	1.00	82375.41
8	0.49	12.31	61.92	1.71	17.90	10.98	1.02	81632.10
9	0.56	12.24	59.37	1.99	17.81	10.91	1.02	82537.22
10	0.70	12.03	58.16	1.21	18.70	10.64	1.02	83916.81
11	0.70	12.23	61.25	1.46	18.17	10.87	1.01	82364.38
12	0.51	12.74	50.57	1.39	18.04	11.21	1.00	78819.55
13	0.93	12.45	52.80	1.99	17.95	11.00	0.99	81194.49
14	0.78	12.76	57.33	1.88	18.42	11.19	0.99	79469.62
15	0.62	13.12	56.78	1.59	19.10	11.34	1.01	77343.90
16	0.39	12.40	47.33	2.19	18.62	10.87	1.02	81570.96
17	0.42	14.30	51.01	2.28	18.50	11.16	1.02	79652.32
18	0.40	12.31	53.18	1.10	19.05	10.84	1.02	80754.07
19	0.29	12.21	48.40	1.38	17.96	10.94	1.02	81545.31
20	0.28	12.36	47.87	2.38	18.21	10.98	1.02	80945.77
21	0.49	11.91	56.98	1.58	19.18	10.48	1.01	84451.65
22	0.55	12.03	55.63	0.52	19.73	10.57	1.01	82369.81
23	0.67	12.52	56.00	0.55	20.14	10.81	0.99	80511.10
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	0.62	12.40	55.49	1.56	18.82	10.83	1.00	81794.93
最大值	1.37	14.30	63.14	2.66	20.14	11.34	1.03	88479.94
發生時間	6	17	4	2	1	15		6
最小值	0.28	11.48	46.77	0.52	17.81	10.37	0.97	76476.43
發生時間	20	6	1	22	9	6		0
零點偏移(率)	-0.14 %	-0.01 %	-0.07 %	-0.00 %		0.00	-0.01	-0.20 %
全幅偏移(率)	-0.96 %	-1.08 %	0.39 %	-1.34 %		0.13	0.00	-0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 115年06月06日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	5.75	11.51	57.99	2.82	20.52	9.33	1.43	76326.33
1	2.98	11.36	48.00	2.34	20.66	9.25	1.42	76046.95
2	8.43	11.01	50.53	3.04	20.18	9.16	1.39	76648.00
3	4.93	11.43	50.45	2.68	19.44	9.18	1.38	76410.44
4	7.32	12.06	55.72	3.02	18.72	9.48	1.36	78165.73
5	5.02	11.51	61.55	2.79	18.53	10.08	1.37	75862.05
6	4.20	11.50	63.90	2.81	18.16	10.14	1.36	75116.67
7	10.18	11.39	61.41	3.24	18.57	9.94	1.36	76617.90
8	4.04	11.71	44.44	2.82	17.88	10.36	1.36	76068.75
9	3.62	11.76	44.32	2.76	18.08	10.34	1.36	75794.96
10	2.83	11.41	47.71	2.81	18.39	10.03	1.39	77367.81
11	5.45	13.53	66.83	3.05	19.29	9.85	1.38	77463.25
12	4.83	12.35	59.04	2.81	18.66	9.61	1.37	75037.85
13	6.12	11.21	57.84	2.84	16.59	9.75	1.40	73525.79
14	4.97	10.95	62.29	2.64	17.99	9.62	1.43	75336.26
15	2.78	11.10	55.33	2.43	18.04	9.56	1.41	73389.74
16	7.24	11.96	41.00	2.77	19.84	8.90	1.37	74931.92
17	5.06	11.96	49.73	2.62	18.56	9.68	1.35	73014.23
18	8.32	11.47	64.42	2.81	17.93	10.08	1.36	76673.69
19	3.65	11.72	60.21	2.74	19.56	10.12	1.36	73314.69
20	3.91	10.91	47.56	2.48	20.37	9.15	1.37	77748.59
21	3.33	11.13	48.98	2.48	19.39	9.39	1.36	77774.40
22	6.14	11.06	53.92	2.87	20.08	9.35	1.38	78364.57
23	4.25	11.12	50.00	2.67	20.05	9.34	1.38	75277.58
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	5.22	11.55	54.30	2.76	18.98	9.65	1.38	75928.26
最大值	10.18	13.53	66.83	3.24	20.66	10.36	1.45	78364.57
發生時間	7	11	11	7	1	8		22
最小值	2.78	10.91	41.00	2.34	16.59	8.90	1.34	73014.23
發生時間	15	20	16	1	13	16		17
零點偏移(率)	-0.05 %	0.01 %	-0.01 %	0.00 %		-0.04	-0.01	-0.10 %
全幅偏移(率)	-1.23 %	-0.10 %	1.71 %	0.20 %		0.27	0.00	0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								