

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 112年05月27日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	7.15	3.01	56.38	3.12	19.04	10.74	1.32	69803.28
1	7.64	3.01	46.53	3.36	17.64	11.34	1.30	66459.08
2	11.09	2.59	61.81	3.49	17.63	10.98	1.30	69587.58
3	8.33	2.60	48.15	3.60	16.97	11.04	1.30	68623.25
4	10.23	3.22	52.11	3.94	16.79	11.07	1.32	68710.39
5	6.25	4.11	55.03	6.32	15.44	11.42	1.33	63651.11
6	7.12	1.79	49.16	4.08	15.35	11.37	1.33	65981.79
7	10.24	2.03	55.96	3.98	16.60	11.18	1.33	67022.73
8	6.20	1.74	61.26	3.12	18.69	10.81	1.33	68563.13
9	6.43	2.67	45.13	3.32	17.79	10.55	1.33	70734.92
10	6.24	1.92	62.63	3.11	18.52	10.86	1.30	69687.36
11	5.33	2.16	59.78	3.51	16.35	11.30	1.30	69168.40
12	5.96	3.84	39.78	4.00	15.12	11.46	1.33	65838.79
13	12.21	7.46	48.41	5.41	13.74	11.65	1.32	64466.52
14	5.38	7.11	54.29	4.85	13.74	11.98	1.30	64097.86
15	4.65	2.42	63.71	3.42	16.03	11.59	1.33	66877.45
16	3.95	2.09	59.13	3.19	16.33	11.59	1.34	67542.08
17	9.41	2.13	50.73	3.66	16.59	11.18	1.30	70044.10
18	5.41	1.85	62.84	3.23	16.47	11.41	1.31	69388.85
19	4.00	2.03	59.18	2.76	18.25	11.40	1.34	69509.10
20	9.38	2.59	43.65	2.98	18.38	10.57	1.33	73787.75
21	5.78	2.19	47.65	3.50	15.80	11.28	1.33	66523.46
22	8.57	2.04	57.37	3.59	16.76	11.01	1.32	68126.52
23	7.87	2.55	56.62	3.47	17.24	10.88	1.33	69828.92
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	7.28	2.88	54.05	3.71	16.72	11.19	1.32	68084.35
最大值	12.21	7.46	63.71	6.32	19.04	11.98	1.36	73787.75
發生時間	13	13	15	5	0	14		20
最小值	3.95	1.74	39.78	2.76	13.74	10.55	1.28	63651.11
發生時間	16	8	12	19	13	9		5
零點偏移(率)	-0.05 %	-0.01 %	-0.02 %	-0.01 %		-0.02	0.00	0.00 %
全幅偏移(率)	-0.29 %	-0.49 %	-0.03 %	0.38 %		-0.10	0.00	0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 112年05月27日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	6.11	2.55	47.74	1.59	20.18	9.73	1.43	81891.22
1	5.50	3.02	50.27	1.40	20.73	9.55	1.42	82427.07
2	7.84	2.89	44.78	1.82	19.93	9.42	1.41	82798.21
3	8.13	3.76	43.41	2.26	17.87	9.80	1.39	81290.48
4	8.06	2.74	50.66	2.72	16.00	10.26	1.38	79193.89
5	8.67	3.30	42.81	3.51	15.95	9.88	1.38	76656.58
6	2.38	1.61	46.03	2.04	17.13	9.61	1.38	81332.85
7	8.51	4.58	48.15	3.49	17.45	9.47	1.38	79169.05
8	8.39	1.89	57.06	2.51	19.04	9.59	1.40	79639.24
9	7.44	3.21	34.17	2.43	17.44	9.69	1.41	80768.28
10	9.82	2.11	47.05	2.77	16.44	9.91	1.41	78212.14
11	8.34	5.29	45.53	2.72	16.00	9.85	1.39	79141.69
12	9.70	2.82	48.10	2.75	16.33	9.86	1.38	80462.70
13	9.61	3.89	47.67	3.21	14.36	10.21	1.38	79092.65
14	6.02	3.24	52.47	3.24	16.03	9.81	1.38	79169.76
15	0.80	2.53	46.59	1.62	17.29	9.58	1.40	80127.80
16	2.45	2.50	50.60	1.80	17.50	9.51	1.39	84008.59
17	4.44	2.52	46.16	1.96	18.26	9.33	1.39	83977.04
18	2.67	1.56	57.49	1.39	19.62	9.79	1.40	83103.57
19	4.93	1.98	50.78	1.51	19.68	9.70	1.39	85123.85
20	6.03	4.73	48.53	1.84	19.07	9.64	1.40	82567.23
21	10.41	2.29	47.01	2.99	16.30	9.90	1.38	81304.01
22	6.42	2.02	51.31	1.95	18.72	9.50	1.38	83938.02
23	9.34	2.73	52.86	1.95	18.55	9.85	1.38	84679.58
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	6.75	2.91	48.22	2.31	17.74	9.73	1.39	81253.15
最大值	10.41	5.29	57.49	3.51	20.73	10.26	1.43	85123.85
發生時間	21	11	18	5	1	4		19
最小值	0.80	1.56	34.17	1.39	14.36	9.33	1.37	76656.58
發生時間	15	18	9	18	13	17		5
零點偏移(率)	-0.03 %	0.00 %	-0.02 %	-0.06 %		0.02	0.00	0.00 %
全幅偏移(率)	2.39 %	0.08 %	-0.12 %	0.26 %		-0.08	-0.03	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 112年05月27日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	7.74	4.64	59.00	2.48	18.65	10.56	1.41	82642.61
1	6.96	4.57	56.38	2.33	19.79	10.44	1.42	83900.25
2	9.97	5.47	54.27	2.62	17.45	10.66	1.42	82461.98
3	10.10	3.58	61.09	2.86	16.90	10.74	1.43	84430.43
4	7.20	4.79	62.34	2.84	15.80	11.08	1.42	81359.05
5	11.84	6.46	60.50	3.57	15.34	11.28	1.43	80027.94
6	11.22	6.31	62.35	3.24	15.42	11.18	1.43	82302.75
7	8.56	2.67	57.97	3.31	16.10	11.06	1.39	77041.78
8	11.23	3.09	65.57	3.21	18.44	10.55	1.40	87421.82
9	13.06	3.75	57.23	3.23	16.55	11.31	1.39	80325.86
10	12.26	8.16	62.60	4.55	14.14	11.41	1.37	77387.12
11	5.41	5.93	64.98	3.96	13.60	11.65	1.40	80243.67
12	10.10	11.46	59.48	6.03	13.45	11.74	1.43	78096.47
13	13.01	6.96	52.73	4.72	14.34	11.05	1.40	76325.10
14	11.36	6.73	61.35	4.67	13.91	11.50	1.38	74881.17
15	5.30	4.17	57.40	3.08	15.49	11.06	1.41	76709.08
16	6.89	1.51	62.83	3.03	17.16	10.90	1.39	80092.83
17	6.58	1.77	61.36	2.95	16.22	10.88	1.37	79855.10
18	1.83	1.33	66.65	2.61	16.78	11.31	1.38	76393.01
19	1.13	2.05	55.58	2.79	17.94	11.47	1.38	78433.91
20	7.62	2.46	52.93	2.96	16.41	10.81	1.38	83598.20
21	9.13	2.68	63.99	3.41	15.35	11.19	1.38	80889.99
22	7.26	2.69	60.25	3.22	15.77	11.10	1.38	80481.68
23	9.86	4.67	61.14	3.09	17.66	10.65	1.43	83419.84
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.57	4.50	60.00	3.37	16.19	11.07	1.40	80363.40
最大值	13.06	11.46	66.65	6.03	19.79	11.74	1.45	87421.82
發生時間	9	12	18	12	1	12		8
最小值	1.13	1.33	52.73	2.33	13.45	10.44	1.35	74881.17
發生時間	19	18	13	1	12	1		14
零點偏移(率)	-0.19 %	-0.01 %	-0.03 %	-0.08 %		-0.02	0.00	0.00 %
全幅偏移(率)	3.35 %	0.11 %	-0.53 %	0.29 %		-0.27	0.02	0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								