

P001 樹林焚化廠CEMS系統日報表-A

報表日期: 113年01月19日

項目 單位 小時\限標	#1-HCl_C ppm	#1-CO_C ppm	#1-NOx_C ppm	#1-SO2_C ppm	#1-H2O %	#1-O2_C %	#1-OPAC %	#1-FLOW_C m3/Hour
0	8.23	7.48	61.83	0.66	17.45	11.70	1.06	80340.04
1	10.87	9.39	34.87	0.97	18.61	10.73	1.04	87582.26
2	8.71	8.85	46.41	0.96	16.51	11.78	1.04	80498.03
3	9.59	9.11	60.23	0.83	16.46	11.60	1.06	82555.15
4	9.54	10.60	42.81	1.41	15.24	11.87	1.07	81124.07
5	8.04	3.04	43.52	2.19	15.66	11.59	1.06	76912.84
6	8.68	6.48	59.57	1.21	15.40	12.12	1.09	78752.12
7	9.17	6.36	39.70	1.29	16.08	11.50	1.06	83774.78
8	9.56	8.13	43.97	1.28	15.21	12.00	1.07	81043.71
9	9.10	7.95	40.57	1.26	15.17	12.02	1.05	80659.09
10	9.72	7.63	46.31	1.19	15.26	12.04	1.07	80388.54
11	8.53	7.67	43.06	1.33	15.19	11.92	1.05	81068.39
12	9.69	6.54	46.75	1.36	14.92	12.18	1.07	78873.48
13	9.31	9.82	45.08	2.15	13.69	12.49	1.08	77070.74
14	9.08	12.83	52.04	2.62	13.31	12.89	1.06	74316.90
15	8.36	7.92	55.72	1.60	14.10	12.69	1.09	74951.60
16	8.78	9.98	68.61	1.32	14.42	12.63	1.09	75315.20
17	8.21	6.86	56.61	0.52	16.35	11.63	1.05	82230.23
18	9.71	6.12	42.13	0.62	16.95	11.16	1.05	86024.88
19	8.95	6.15	38.05	0.94	16.16	11.67	1.07	82260.13
20	9.17	9.11	47.32	0.88	16.37	11.71	1.09	82047.88
21	9.56	9.93	46.83	0.73	16.13	11.69	1.09	82020.84
22	8.77	7.82	57.86	1.36	14.92	11.89	1.08	81157.69
23	11.93	10.09	45.41	1.77	15.28	12.10	1.06	79020.67
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	9.22	8.16	48.55	1.27	15.62	11.90	1.07	80416.22
最 大 值	11.93	12.83	68.61	2.62	18.61	12.89	1.10	87582.26
發生時間	23	14	16	14	1	14		1
最 小 值	8.04	3.04	34.87	0.52	13.31	10.73	1.03	74316.90
發生時間	5	5	1	17	14	1		14
零點偏移(率)	-0.05 %	0.00 %	-0.09 %	-0.05 %		-0.09		0.10 %
全幅偏移(率)	0.02 %	-0.14 %	0.10 %	0.34 %		-0.07		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A 報表日期: 113年01月19日

報表日期: 113年01月19日

項目 單位 小時\限標	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.41	10.87	49.63	1.69	16.85	10.47	1.08	83677.19
1	8.31	8.52	43.05	1.69	16.06	10.50	1.08	79691.07
2	3.76	7.01	42.51	1.36	15.05	10.20	1.08	79133.09
3	2.16	8.27	44.32	1.19	15.58	10.02	1.09	78229.62
4	4.89	11.87	40.50	1.83	16.09	9.96	1.07	72359.25
5	2.67	12.11	42.54	1.56	14.83	10.01	1.05	74069.45
6	3.69	10.95	48.02	1.44	14.75	10.43	1.05	75614.17
7	10.11	11.15	42.23	2.34	15.21	10.17	1.07	77332.25
8	6.95	11.38	43.36	3.44	14.35	10.94	1.09	76535.54
9	6.88	11.23	48.38	1.59	14.93	10.96	1.09	73994.68
10	1.29	12.73	42.57	1.26	14.79	10.65	1.09	73641.99
11	4.21	16.84	38.31	2.64	14.52	11.37	1.09	67149.90
12	8.32	4.64	50.54	3.82	12.76	11.89	1.07	70488.87
13	2.84	9.89	51.97	2.24	13.39	12.10	1.08	70692.37
14	3.24	14.77	47.28	2.59	12.20	11.92	1.08	70754.73
15	8.89	7.25	49.84	3.19	12.34	11.89	1.06	70133.46
16	5.48	20.43	50.78	1.67	13.40	11.80	1.09	71274.17
17	4.44	12.92	54.09	1.30	12.55	12.26	1.09	70857.81
18	1.68	8.31	54.16	0.39	13.56	12.01	1.09	72738.31
19	3.05	9.23	63.33	0.84	15.20	11.66	1.09	75592.53
20	9.09	3.26	51.51	1.21	15.26	10.87	1.09	82302.96
21	9.43	4.35	56.07	1.02	16.92	10.27	1.10	82665.52
22	12.61	5.19	53.80	1.82	14.28	11.25	1.09	77670.58
23	10.43	4.63	58.81	1.49	15.17	10.86	1.10	79781.05
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	5.95	9.91	48.65	1.82	14.58	11.02	1.08	75265.86
最 大 值	12.61	20.43	63.33	3.82	16.92	12.26	1.10	83677.19
發生時間	22	16	19	12	21	17		0
最 小 值	1.29	3.26	38.31	0.39	12.20	9.96	1.04	67149.90
發生時間	10	20	11	18	14	4		11
零點偏移(率)	-0.01 %	-0.00 %	-0.08 %	-0.04 %		0.02		-0.10 %
全幅偏移(率)	0.02 %	0.03 %	-0.12 %	0.03 %		-0.04		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								