

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 112年06月10日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.32	2.32	42.37	4.01	16.13	11.14	1.28	71002.17
1	8.50	2.24	51.13	4.19	18.33	10.95	1.28	70067.53
2	9.30	3.73	44.98	3.92	18.34	10.34	1.28	73152.82
3	9.64	1.32	57.43	4.16	18.46	10.56	1.28	72553.69
4	8.59	1.94	54.30	3.59	18.71	10.77	1.27	71339.58
5	9.86	2.05	45.18	3.78	18.44	10.56	1.24	74888.56
6	3.23	1.54	64.60	2.78	18.28	11.48	1.25	67034.46
7	3.86	1.52	60.86	2.52	19.68	10.63	1.28	73460.94
8	3.81	2.34	62.64	2.36	20.53	10.88	1.29	70729.28
9	10.28	2.21	46.68	3.01	20.27	10.21	1.26	75264.94
10	10.92	4.21	49.45	4.09	17.30	11.02	1.29	71963.71
11	8.84	4.73	46.61	3.56	16.74	11.14	1.29	71845.01
12	10.11	6.13	49.29	4.29	15.54	11.26	1.26	70491.96
13	8.17	3.29	49.61	3.69	15.98	11.40	1.25	68087.13
14	7.42	2.95	54.93	3.84	16.49	11.55	1.25	67810.63
15	8.62	1.87	47.84	4.02	17.77	10.67	1.25	74037.01
16	4.85	2.80	49.59	3.88	15.67	11.80	1.25	67852.87
17	7.54	2.41	57.53	3.61	16.13	11.46	1.28	71007.04
18	7.17	1.94	53.21	3.19	17.47	11.03	1.28	71770.20
19	6.15	1.77	55.52	3.09	17.76	10.82	1.28	71804.22
20	8.83	3.81	47.16	4.06	15.48	11.60	1.28	69056.84
21	10.14	3.28	57.79	3.85	15.75	11.47	1.28	71356.28
22	9.64	2.28	51.97	3.52	16.79	11.28	1.28	71948.40
23	7.65	1.94	59.16	3.07	17.60	11.06	1.28	72566.64
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	7.98	2.69	52.49	3.59	17.49	11.05	1.27	71295.50
最大值	10.92	6.13	64.60	4.29	20.53	11.80	1.38	75264.94
發生時間	10	12	6	12	8	16		9
最小值	3.23	1.32	42.37	2.36	15.48	10.21	1.23	67034.46
發生時間	6	3	0	8	20	9		6
零點偏移(率)	-0.01 %	0.00 %	-0.02 %	-0.00 %		0.05	0.00	0.00 %
全幅偏移(率)	4.21 %	0.38 %	0.19 %	0.26 %		-0.05	0.00	0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 112年06月10日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.05	2.05	52.04	2.76	17.40	9.52	1.50	79503.42
1	3.05	1.56	64.83	1.04	20.21	9.80	1.50	77689.92
2	9.46	5.66	33.80	4.54	18.68	8.34	1.47	82039.08
3	8.99	1.41	50.24	3.22	18.06	9.77	1.46	72783.24
4	3.86	1.87	59.19	1.27	19.77	9.46	1.47	79848.52
5	6.25	2.16	45.47	1.66	20.95	8.73	1.47	85917.67
6	7.47	2.44	49.35	1.63	19.27	9.45	1.46	92263.73
7	6.60	1.66	59.38	1.65	19.32	9.72	1.46	79964.37
8	5.64	2.79	40.53	1.47	20.67	8.81	1.46	83951.38
9	6.48	2.18	50.45	1.84	18.38	9.56	1.48	83293.06
10	5.14	3.22	54.13	2.21	16.00	10.33	1.47	78389.91
11	2.36	2.34	48.30	2.15	14.98	10.26	1.48	76645.97
12	7.39	5.97	58.26	2.49	16.22	9.89	1.46	79346.48
13	16.59	5.76	57.44	4.65	14.32	10.15	1.47	79310.14
14	9.45	4.34	56.05	3.68	16.80	9.82	1.47	80699.20
15	7.45	2.11	54.82	2.18	19.02	9.56	1.46	86009.03
16	7.97	1.80	56.56	2.24	16.77	10.16	1.46	80915.38
17	5.26	1.50	53.64	1.45	18.74	9.96	1.47	78498.10
18	5.24	1.83	57.46	1.25	19.02	9.82	1.48	82471.19
19	9.78	2.06	54.03	1.63	18.81	9.74	1.48	86005.59
20	6.44	1.38	56.25	1.61	17.73	9.99	1.46	83310.08
21	6.00	3.67	48.77	1.59	17.65	9.71	1.46	82225.57
22	11.15	2.97	57.20	2.13	17.69	9.80	1.46	82807.85
23	6.71	2.14	54.10	1.32	19.15	9.50	1.46	85187.44
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	7.20	2.70	53.01	2.15	18.15	9.66	1.47	81628.18
最大值	16.59	5.97	64.83	4.65	20.95	10.33	1.51	92263.73
發生時間	13	12	1	13	5	10		6
最小值	2.36	1.38	33.80	1.04	14.32	8.34	1.45	72783.24
發生時間	11	20	2	1	13	2		3
零點偏移(率)	-0.01 %	-0.00 %	-0.02 %	-0.02 %		0.02	0.00	0.00 %
全幅偏移(率)	-0.02 %	-0.05 %	0.30 %	0.14 %		-0.01	0.00	0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 112年06月10日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.04	2.46	56.45	3.06	16.64	10.53	1.27	79517.34
1	4.82	2.50	54.80	2.70	17.47	10.43	1.27	79501.48
2	7.02	2.20	58.86	3.14	18.48	10.01	1.29	81950.42
3	10.22	5.02	47.93	3.90	16.41	10.09	1.28	81334.85
4	7.86	2.07	63.35	3.23	18.25	10.12	1.27	81515.12
5	9.55	2.51	52.16	3.04	17.57	10.34	1.25	82833.98
6	7.90	4.32	54.15	3.21	16.95	10.25	1.26	82776.81
7	1.37	3.35	51.95	2.36	16.90	10.44	1.27	68376.69
8	5.58	4.21	58.01	2.78	18.22	9.86	1.28	82191.90
9	10.53	5.26	43.22	6.08	15.47	10.26	1.26	79462.93
10	12.97	4.76	55.56	3.98	16.23	10.38	1.27	75888.90
11	7.74	7.56	52.21	5.63	14.67	11.14	1.30	75741.40
12	14.57	4.44	55.13	5.65	14.93	10.53	1.28	76306.58
13	10.30	6.98	47.81	4.32	14.33	10.50	1.24	76320.42
14	8.63	4.76	50.80	3.72	15.36	10.54	1.24	76477.11
15	12.07	4.94	58.32	3.54	15.84	10.75	1.25	82269.57
16	11.47	3.63	53.53	3.12	15.94	11.11	1.29	84358.63
17	9.02	1.80	61.76	2.78	15.97	11.11	1.30	82893.72
18	7.75	4.72	52.32	2.58	17.45	10.35	1.28	86587.98
19	8.02	2.32	57.25	2.63	17.58	10.49	1.28	81847.13
20	10.23	4.87	49.19	2.80	15.77	10.85	1.29	80283.61
21	8.82	3.75	59.16	3.00	15.49	10.80	1.26	79299.16
22	12.64	5.06	54.61	3.71	14.71	10.96	1.25	79195.02
23	8.60	3.71	54.46	2.82	16.12	10.61	1.27	81160.01
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	9.03	4.05	54.29	3.49	16.36	10.52	1.27	79920.45
最大值	14.57	7.56	63.35	6.08	18.48	11.14	1.33	86587.98
發生時間	12	11	4	9	2	11		18
最小值	1.37	1.80	43.22	2.36	14.33	9.86	1.23	68376.69
發生時間	7	17	9	7	13	8		7
零點偏移(率)	-0.06 %	0.00 %	-0.02 %	-0.04 %		0.00	0.00	0.00 %
全幅偏移(率)	3.38 %	0.60 %	-0.34 %	0.35 %		0.21	0.00	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								