

P001 樹林焚化廠CEMS系統日報表-A 報表日期: 114年06月27日

報表日期: 114年06月27日

項目 單位 小時\限標	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	3.13	2.38	57.79	1.14	17.80	11.48	1.29	79944.16
1	1.91	2.70	58.21	2.33	18.65	11.32	1.29	80410.38
2	2.84	2.82	44.43	3.60	16.76	11.33	1.26	82276.01
3	0.82	2.65	48.52	3.04	15.93	11.66	1.27	80722.44
4	2.18	2.23	55.81	2.61	16.65	11.48	1.29	81462.07
5	2.53	2.20	58.14	1.63	15.90	11.60	1.29	80232.57
6	2.15	2.35	60.01	1.27	16.74	11.50	1.30	80746.67
7	5.25	2.80	57.50	1.52	16.85	11.50	1.29	80602.24
8	2.03	2.44	57.35	1.32	16.92	11.45	1.29	80993.12
9	1.70	2.23	59.38	1.65	15.95	11.86	1.29	78503.37
10	0.38	2.17	67.14	1.02	16.95	11.57	1.29	80040.18
11	0.16	3.65	50.70	1.78	14.82	12.04	1.29	77416.60
12	2.02	4.90	55.32	1.88	15.86	12.02	1.29	77375.77
13	2.25	2.58	53.97	1.70	16.09	11.91	1.29	77680.29
14	0.59	2.38	59.19	1.14	16.98	11.64	1.29	79379.99
15	0.16	3.50	57.24	2.18	13.95	13.38	1.28	68648.61
16	1.72	2.78	53.84	2.24	14.27	12.58	1.28	75719.45
17	5.78	4.25	50.68	2.57	14.81	11.83	1.29	80243.28
18	5.74	3.71	59.93	2.26	15.32	11.63	1.29	81094.33
19	3.27	3.06	54.35	2.11	14.59	11.95	1.28	78792.45
20	3.87	4.57	52.28	1.83	15.63	11.71	1.28	80401.05
21	13.31	2.85	50.67	2.91	15.89	11.70	1.28	80039.95
22	3.59	6.67	41.86	2.90	14.72	12.00	1.27	79475.21
23	7.58	2.72	56.21	2.28	16.22	11.86	1.29	78899.49
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	3.12	3.11	55.02	2.04	16.01	11.79	1.28	79212.49
最 大 值	13.31	6.67	67.14	3.60	18.65	13.38	1.31	82276.01
發生時間	21	22	10	2	1	15		2
最 小 值	0.16	2.17	41.86	1.02	13.95	11.32	1.25	68648.61
發生時間	11	10	22	10	15	1		15
零點偏移(率)	-0.02 %	-0.00 %	-0.02 %	-0.00 %		-0.01		0.10 %
全幅偏移(率)	0.00 %	0.82 %	0.02 %	0.19 %		0.00		0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002 樹林焚化廠CEMS系統日報表-A

報表日期: 114年06月27日

項目 單位 小時\限標	#2-HCl_C ppm	#2-CO_C ppm	#2-NOx_C ppm	#2-SO2_C ppm	#2-H2O %	#2-O2_C %	#2-OPAC %	#2-FLOW_C m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	10.48	1.93	55.34	2.79	17.28	11.00	1.06	81151.80
1	5.51	7.23	60.40	3.53	16.60	11.11	1.06	79021.79
2	11.26	2.70	58.54	3.13	16.81	10.70	1.05	79865.18
3	6.94	1.95	59.68	2.13	17.30	10.77	1.04	79963.57
4	9.90	4.23	61.74	3.03	15.59	11.24	1.05	81048.74
5	8.27	1.98	64.75	2.05	17.72	10.75	1.05	83011.55
6	12.06	5.51	59.73	3.61	15.45	11.33	1.08	81428.57
7	4.28	2.54	59.37	2.38	16.80	11.05	1.10	81001.28
8	7.14	2.15	59.68	2.40	16.61	11.09	1.10	79474.61
9	6.28	2.12	60.54	2.69	16.48	11.05	1.10	78915.88
10	6.36	1.94	61.48	2.69	16.47	11.21	1.11	79030.27
11	4.92	6.87	63.23	3.08	16.03	11.26	1.10	78376.10
12	7.78	6.11	65.56	2.86	15.96	11.45	1.10	76866.00
13	8.55	1.88	61.74	2.66	17.07	11.14	1.09	79134.94
14	9.37	2.41	53.50	2.54	17.75	10.39	1.09	79796.68
15	3.42	3.36	63.59	3.74	14.61	12.37	1.08	69047.29
16	4.52	4.65	63.10	3.63	14.76	12.04	1.06	77445.34
17	11.09	3.91	63.70	2.93	16.51	10.74	1.09	83021.33
18	6.94	1.55	61.57	2.54	16.32	10.88	1.10	81150.73
19	6.99	2.95	59.85	2.65	16.06	10.84	1.09	80487.33
20	7.79	4.24	61.23	2.61	16.86	10.63	1.09	83165.00
21	10.05	0.65	59.94	1.94	16.89	10.96	1.10	81618.59
22	10.31	1.78	53.45	2.13	17.40	10.83	1.10	82662.22
23	9.32	1.59	51.91	1.86	17.78	10.71	1.10	82918.51
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	7.90	3.18	60.15	2.73	16.55	11.06	1.08	79983.47
最 大 值	12.06	7.23	65.56	3.74	17.78	12.37	1.15	83165.00
發生時間	6	1	12	15	23	15		20
最 小 值	3.42	0.65	51.91	1.86	14.61	10.39	1.04	69047.29
發生時間	15	21	23	23	15	14		15
零點偏移(率)	-0.08 %	-0.01 %	-0.20 %	-0.01 %		-0.05		-0.10 %
全幅偏移(率)	-1.00 %	1.02 %	-0.16 %	0.42 %		-0.11		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

