

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 112年05月19日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.20	7.35	52.04	5.08	14.81	12.58	1.30	65485.18
1	7.09	5.09	65.43	4.85	14.79	12.94	1.29	63202.44
2	8.44	2.27	55.86	4.86	15.45	12.33	1.32	68116.74
3	7.04	1.81	57.41	4.56	15.99	12.09	1.26	69372.35
4	9.59	3.92	59.75	5.57	14.15	12.72	1.27	64797.92
5	9.53	3.66	61.71	6.12	14.24	12.78	1.27	62110.45
6	8.62	6.65	56.63	6.22	14.56	12.64	1.27	64923.70
7	8.17	2.04	59.30	6.01	16.81	12.02	1.28	69847.89
8	7.18	2.45	47.25	4.58	17.52	11.72	1.28	70850.02
9	8.61	3.05	59.34	5.77	15.29	12.39	1.28	66005.40
10	10.54	4.40	51.82	5.52	15.57	12.10	1.28	66086.65
11	6.43	3.98	57.14	5.43	14.70	12.66	1.28	64929.47
12	4.49	7.78	61.75	5.99	13.25	13.42	1.30	59539.26
13	4.35	5.28	62.43	6.21	14.19	12.96	1.31	61465.54
14	2.05	5.22	58.07	8.66	14.33	12.49	1.33	66387.52
15	7.77	4.16	52.81	4.78	14.19	12.72	1.33	64819.99
16	6.74	3.90	53.22	6.02	14.55	12.39	1.30	67351.10
17	1.61	3.27	57.63	4.65	14.28	12.42	1.28	66378.88
18	2.02	2.14	81.19	3.81	16.52	12.58	1.26	65091.14
19	3.03	2.29	50.58	3.82	16.26	12.11	1.27	69578.21
20	5.32	4.97	45.74	4.81	14.81	12.52	1.26	66178.89
21	8.62	10.24	55.10	6.70	12.56	13.04	1.25	61883.47
22	8.64	3.31	50.91	7.06	12.67	12.95	1.24	62381.22
23	9.40	1.66	55.40	5.47	14.73	12.51	1.25	65951.87
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	6.85	4.20	57.02	5.52	14.84	12.55	1.28	65530.64
最大值	10.54	10.24	81.19	8.66	17.52	13.42	1.33	70850.02
發生時間	10	21	18	14	8	12		8
最小值	1.61	1.66	45.74	3.81	12.56	11.72	1.23	59539.26
發生時間	17	23	20	18	21	8		12
零點偏移(率)	-0.06 %	0.00 %	-0.01 %	-0.02 %		-0.02	0.00	0.00 %
全幅偏移(率)	-0.87 %	-0.14 %	0.22 %	-0.07 %		-0.11	-0.06	0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 112年05月19日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	5.51	2.07	57.41	1.62	19.18	9.91	1.41	85020.73
1	5.80	2.36	62.19	1.69	19.27	10.56	1.38	78474.67
2	0.61	1.68	62.64	1.42	18.66	10.78	1.38	76675.98
3	0.32	1.72	45.82	1.33	19.63	9.83	1.37	85804.76
4	3.25	1.75	61.49	1.76	19.25	9.56	1.39	89760.04
5	8.61	2.58	57.91	2.07	18.80	9.78	1.39	87326.59
6	4.50	2.28	62.46	1.60	21.30	9.48	1.42	88456.10
7	8.98	1.62	55.99	2.24	19.17	9.78	1.43	88203.05
8	7.91	2.48	55.73	2.09	19.35	10.24	1.42	82089.12
9	7.37	2.52	56.62	2.15	18.62	10.10	1.41	82489.14
10	2.62	1.81	70.00	1.60	19.75	10.60	1.43	78897.35
11	5.38	3.73	36.94	1.96	18.82	9.80	1.42	83994.74
12	0.65	2.19	60.85	2.08	17.10	10.75	1.41	76430.18
13	23.46	9.45	62.39	8.16	15.40	10.81	1.42	76041.27
14	2.23	1.58	40.99	8.11	14.33	11.14	1.44	81055.73
15	1.84	2.99	43.03	5.08	15.36	10.61	1.43	79745.98
16	5.60	1.47	49.06	1.82	18.40	9.57	1.47	79530.31
17	9.53	2.77	57.18	1.69	20.51	9.01	1.46	84968.31
18	3.74	1.44	75.45	1.27	20.57	10.18	1.43	82111.65
19	6.84	2.02	54.78	1.29	20.97	9.34	1.43	91479.63
20	9.79	3.28	45.69	2.96	17.05	9.49	1.43	81039.68
21	10.03	2.25	47.92	2.96	16.06	9.71	1.43	79624.32
22	10.52	4.47	50.80	1.60	21.27	8.59	1.44	90749.54
23	7.78	2.77	44.56	1.70	19.67	9.28	1.44	86576.67
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	6.37	2.64	54.91	2.51	18.69	9.95	1.42	83189.40
最大值	23.46	9.45	75.45	8.16	21.30	11.14	1.61	91479.63
發生時間	13	13	18	13	6	14		19
最小值	0.32	1.44	36.94	1.27	14.33	8.59	1.36	76041.27
發生時間	3	18	11	18	14	22		13
零點偏移(率)	-0.05 %	-0.01 %	-0.02 %	-0.01 %		0.00	0.00	-0.20 %
全幅偏移(率)	0.72 %	-0.03 %	0.22 %	0.01 %		0.13	-0.03	-0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 112年05月19日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	4.33	6.94	62.64	2.66	17.56	11.15	1.34	80336.12
1	9.15	7.56	52.94	3.26	18.38	10.07	1.32	84164.39
2	8.19	3.25	56.64	2.75	20.18	9.28	1.33	88444.11
3	6.14	4.49	49.87	2.41	18.10	9.90	1.35	85092.17
4	7.12	4.32	56.74	2.90	18.23	10.02	1.34	86307.88
5	9.54	2.26	56.38	2.76	17.73	10.27	1.33	84420.46
6	9.29	3.18	60.26	3.17	17.99	10.23	1.33	84875.78
7	9.18	3.13	51.53	3.03	17.49	10.15	1.33	83857.59
8	9.79	2.76	59.48	2.75	18.10	10.14	1.34	86967.66
9	8.12	4.66	63.14	2.74	16.95	10.79	1.35	79859.07
10	5.91	5.30	54.92	2.47	16.77	10.45	1.33	81041.59
11	4.09	4.20	61.78	2.62	16.63	10.64	1.34	77496.94
12	3.05	3.65	63.43	3.08	15.42	11.31	1.32	73087.39
13	5.81	2.58	63.34	2.99	16.15	11.16	1.33	73416.75
14	10.64	6.50	62.72	3.51	15.38	10.64	1.32	79658.76
15	7.21	5.46	59.77	3.16	14.68	10.76	1.33	80364.43
16	8.46	2.19	59.31	2.78	16.37	10.58	1.37	79011.51
17	4.82	1.93	67.98	2.59	18.06	10.44	1.35	83222.53
18	4.75	2.86	54.00	2.63	19.22	10.47	1.36	84347.95
19	6.56	2.92	46.53	2.60	18.57	10.10	1.37	89178.91
20	9.06	12.45	39.04	4.15	17.29	9.75	1.36	82044.53
21	8.49	1.73	56.27	2.59	17.24	10.13	1.36	82461.85
22	10.47	2.35	52.95	2.70	16.76	10.18	1.36	83951.25
23	8.94	1.31	61.21	2.81	17.17	10.43	1.36	81889.00
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	7.46	4.08	57.20	2.88	17.35	10.38	1.34	82312.44
最大值	10.64	12.45	67.98	4.15	20.18	11.31	1.38	89178.91
發生時間	14	20	17	20	2	12		19
最小值	3.05	1.31	39.04	2.41	14.68	9.28	1.30	73087.39
發生時間	12	23	20	3	15	2		12
零點偏移(率)	-0.02 %	-0.01 %	-0.03 %	-0.01 %		-0.02	0.00	0.00 %
全幅偏移(率)	-0.30 %	-0.77 %	-0.34 %	-0.17 %		-0.10	0.02	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								