

P001 樹林焚化廠CEMS系統日報表-A 報表日期: 115年09月16日

報表日期: 115年09月16日

項目 單位 小時\限標	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.48	12.15	47.13	4.07	20.05	10.09	1.12	79259.99
1	9.31	7.76	48.62	3.51	18.37	11.07	1.12	74046.86
2	8.68	7.88	56.24	2.37	19.01	10.92	1.14	75499.12
3	8.71	8.41	55.27	2.17	19.76	10.53	1.13	77839.44
4	6.25	12.45	58.77	1.84	19.37	10.88	1.13	75534.07
5	14.64	12.50	60.10	3.18	19.63	10.66	1.15	74631.28
6	9.32	12.85	57.52	2.86	18.90	10.68	1.15	76386.63
7	8.02	12.64	46.07	3.14	19.23	10.90	1.13	76278.53
8	10.61	12.70	51.94	2.45	18.69	11.06	1.13	76289.41
9	10.30	12.52	48.60	2.65	17.50	11.07	1.13	76397.50
10	8.60	12.46	52.69	3.09	18.35	10.87	1.14	77060.68
11	11.08	14.74	53.52	3.62	18.13	10.78	1.15	77002.78
12	9.50	12.55	51.90	1.38	17.27	11.07	1.14	76140.95
13	11.31	12.81	53.17	1.85	16.51	11.42	1.13	73953.18
14	7.74	12.40	51.38	1.83	17.08	11.02	1.13	75875.85
15	7.63	13.01	57.57	1.73	16.34	11.55	1.14	72974.27
16	9.62	12.48	58.24	1.21	18.84	10.85	1.16	75680.69
17	10.38	12.36	50.89	1.48	18.53	10.75	1.15	76426.70
18	9.68	12.29	50.86	2.25	17.44	10.82	1.14	76931.26
19	10.83	12.95	57.07	2.30	16.00	11.57	1.13	72535.32
20	8.22	12.83	59.83	1.76	16.69	11.19	1.13	75126.10
21	10.30	13.25	62.16	1.83	16.56	11.17	1.13	75203.43
22	9.89	12.74	60.71	2.09	15.90	11.39	1.13	73781.84
23	9.27	12.76	62.85	1.81	17.31	11.07	1.13	75282.70
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	9.56	12.15	54.71	2.35	17.98	10.97	1.14	75672.44
最 大 值	14.64	14.74	62.85	4.07	20.05	11.57	1.19	79259.99
發生時間	5	11	23	0	0	19		0
最 小 值	6.25	7.76	46.07	1.21	15.90	10.09	1.11	72535.32
發生時間	4	1	7	16	22	0		19
零點偏移(率)	-0.01 %	-0.07 %	-0.05 %	-0.02 %		0.02	-0.01	0.20 %
全幅偏移(率)	-0.30 %	0.25 %	0.17 %	-0.12 %		-0.04	-0.06	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002 樹林焚化廠CEMS系統日報表-A 報表日期: 115年09月16日

報表日期: 115年09月16日

項目 單位 小時\限標	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	1.59	11.05	57.99	0.85	18.32	10.82	0.93	83724.13
1	1.40	11.37	54.99	0.79	19.93	10.83	0.93	82109.91
2	1.36	11.26	55.49	0.97	19.00	10.86	0.94	83354.70
3	1.14	11.25	57.67	0.76	19.43	10.85	0.94	82906.81
4	1.22	11.07	52.03	1.07	18.69	10.54	0.93	86400.91
5	2.77	11.65	48.31	1.29	18.33	10.55	0.93	86317.47
6	1.86	12.36	42.29	1.28	19.08	10.52	0.95	85941.96
7	11.45	12.28	54.06	1.59	18.23	10.83	0.94	83813.32
8	1.50	12.69	52.81	1.02	17.89	11.04	0.94	83087.66
9	6.88	12.86	55.76	1.72	17.64	11.02	0.95	83111.91
10	4.84	12.25	55.08	1.19	18.47	10.79	0.95	84379.74
11	1.35	12.51	57.18	1.53	16.69	11.22	0.94	82655.86
12	0.82	12.49	63.21	1.25	16.13	11.28	0.94	82206.57
13	2.01	12.77	54.86	1.66	16.01	11.46	0.94	80871.20
14	2.04	12.47	54.76	0.59	18.97	10.81	0.94	83426.21
15	0.90	12.50	51.90	1.49	16.67	11.14	0.94	82657.99
16	1.14	12.64	52.59	1.02	18.14	10.64	0.94	85649.52
17	2.73	12.37	50.66	1.17	17.48	10.84	0.94	85088.61
18	2.13	12.58	52.95	0.78	18.20	10.43	0.94	86904.38
19	10.35	12.31	54.99	1.51	16.68	11.06	0.94	84107.65
20	5.84	12.15	55.06	1.62	17.36	10.86	0.94	85109.71
21	2.30	12.39	53.82	1.15	17.76	10.86	0.94	84192.47
22	1.92	12.23	57.20	1.40	16.89	10.97	0.94	83720.16
23	1.32	12.12	59.16	1.12	17.95	10.78	0.94	84892.71
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	2.95	12.15	54.37	1.20	17.91	10.88	0.94	84026.31
最 大 值	11.45	12.86	63.21	1.72	19.93	11.46	0.97	86904.38
發生時間	7	9	12	9	1	13		18
最 小 值	0.82	11.05	42.29	0.59	16.01	10.43	0.92	80871.20
發生時間	12	0	6	14	13	18		13
零點偏移(率)	-0.13 %	-0.01 %	-0.03 %	-0.01 %		0.02	-0.01	-0.20 %
全幅偏移(率)	1.62 %	-1.13 %	0.38 %	-0.11 %		0.13	0.00	-0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A

報表日期: 115年09月16日

項目 單位 小時\限標	#3-HCl_C ppm	#3-CO_C ppm	#3-NOx_C ppm	#3-SO2_C ppm	#3-H2O %	#3-O2_C %	#3-OPAC %	#3-FLOW_C m3/Hour
0	9.25	11.22	54.23	3.40	19.47	9.62	1.24	77745.20
1	9.53	11.47	48.47	3.20	20.31	9.72	1.27	76650.25
2	9.06	11.76	58.67	3.38	19.98	9.55	1.28	76182.38
3	10.19	10.39	43.65	2.20	20.37	8.54	1.26	77175.16
4	8.82	10.74	46.30	3.28	21.24	8.52	1.25	78047.24
5	8.82	11.07	43.00	3.20	19.07	9.35	1.25	73218.48
6	9.44	11.40	49.21	3.00	18.44	9.85	1.28	72076.02
7	8.78	11.57	56.41	2.90	17.51	10.29	1.24	74702.13
8	8.79	11.62	58.46	2.00	17.95	9.97	1.24	77294.77
9	8.81	11.30	58.28	1.97	18.26	9.84	1.23	76750.67
10	6.82	11.33	60.27	2.04	18.29	9.92	1.26	74707.29
11	6.39	11.10	54.87	1.87	19.27	9.43	1.27	75228.54
12	5.57	12.35	54.39	1.86	18.72	9.48	1.25	76087.55
13	10.19	12.10	58.69	1.95	17.89	9.57	1.23	76201.26
14	3.32	12.40	58.86	2.03	17.33	9.98	1.24	72911.36
15	7.98	12.94	55.57	1.91	19.29	9.47	1.24	77083.25
16	9.03	12.28	57.00	1.94	18.50	9.63	1.27	76536.87
17	8.26	12.58	58.86	1.86	17.85	9.71	1.28	75555.55
18	8.46	12.32	57.31	1.91	17.48	9.78	1.27	76204.60
19	11.54	11.66	59.34	3.05	17.63	9.93	1.24	74589.83
20	7.07	11.52	57.11	2.73	16.60	9.96	1.23	72746.31
21	8.51	11.31	59.31	2.83	17.14	9.97	1.27	74228.13
22	9.34	11.30	55.42	2.89	18.22	9.74	1.27	75513.72
23	8.55	11.11	56.68	2.94	18.22	9.71	1.27	75948.09
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	8.44	11.62	55.01	2.51	18.54	9.65	1.26	75557.69
最 大 值	11.54	12.94	60.27	3.40	21.24	10.29	1.40	78047.24
發生時間	19	15	10	0	4	7		4
最 小 值	3.32	10.39	43.00	1.86	16.60	8.52	1.23	72076.02
發生時間	14	3	5	12	20	4		6
零點偏移(率)	-0.02 %	-0.01 %	-0.04 %	-0.01 %		0.01	-0.01	0.10 %
全幅偏移(率)	-0.10 %	0.17 %	-0.71 %	-0.03 %		0.11	0.00	0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								