

## P001\_樹林焚化廠CEMS系統日報表-A

報表日期: 115年04月04日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	10.82	10.36	54.66	1.84	16.24	11.45	1.23	72610.75
1	8.87	10.29	59.31	1.39	18.46	11.17	1.23	72864.00
2	11.30	10.59	56.40	1.69	17.15	11.67	1.23	71084.55
3	7.98	10.09	47.14	1.32	19.43	10.41	1.25	78463.73
4	9.64	10.17	54.90	1.40	18.39	10.95	1.24	74731.39
5	3.13	12.80	43.60	3.82	17.06	11.23	1.23	77263.97
6	9.43	12.69	56.46	3.03	18.79	10.73	1.25	76170.13
7	13.25	13.33	56.51	4.07	15.99	11.71	1.25	70782.12
8	9.40	13.58	48.95	2.34	18.62	11.21	1.25	71948.33
9	11.77	12.86	52.33	2.92	18.58	10.88	1.24	74597.71
10	8.96	13.26	50.32	2.58	16.53	11.38	1.25	72906.27
11	9.24	14.41	54.63	2.05	17.07	11.95	1.25	68150.33
12	6.97	13.55	49.23	2.27	17.62	11.19	1.24	73074.99
13	9.94	12.88	58.95	2.42	18.02	11.22	1.25	72781.52
14	10.59	13.08	53.64	2.72	16.50	11.35	1.25	73309.67
15	8.88	13.13	60.10	2.12	17.24	11.46	1.25	72094.13
16	11.30	12.93	46.17	2.85	18.42	10.87	1.25	75701.63
17	9.15	13.00	47.18	2.33	19.33	10.68	1.25	76260.02
18	10.85	12.58	54.94	2.46	18.87	10.69	1.25	76647.66
19	7.86	12.64	50.08	2.83	17.33	11.13	1.25	75059.28
20	9.53	12.70	53.71	2.95	16.80	11.24	1.25	74116.24
21	12.37	12.47	59.63	2.65	17.89	10.95	1.25	75474.55
22	8.90	12.37	56.29	2.57	18.19	10.83	1.22	75996.49
23	13.41	12.35	51.60	2.88	18.39	10.76	1.22	75965.13
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	9.73	12.42	53.20	2.48	17.79	11.13	1.24	74085.61
最大值	13.41	14.41	60.10	4.07	19.43	11.95	1.26	78463.73
發生時間	23	11	15	7	3	11		3
最小值	3.13	10.09	43.60	1.32	15.99	10.41	1.20	68150.33
發生時間	5	3	5	3	7	3		11
零點偏移(率)	-0.06 %	-0.09 %	-0.01 %	-0.00 %		-0.07	-0.01	0.20 %
全幅偏移(率)	-2.38 %	-0.40 %	-0.40 %	-0.29 %		0.05	0.10	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

## P002\_樹林焚化廠CEMS系統日報表-A

報表日期: 115年04月04日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	10.16	13.86	36.66	1.42	18.61	10.13	0.94	76310.22
1	9.53	15.25	49.85	1.44	18.55	11.23	0.94	67805.34
2	9.54	14.40	44.80	1.33	19.08	10.59	0.94	71579.91
3	9.67	13.94	47.52	1.57	18.56	10.29	0.94	81116.79
4	8.78	14.34	58.72	1.48	18.26	10.59	0.94	80154.81
5	9.95	13.72	52.23	1.40	19.25	10.04	0.94	80997.44
6	5.20	11.43	39.94	1.81	19.83	9.96	0.96	80302.76
7	13.10	12.39	36.56	1.24	19.43	9.66	0.95	80978.47
8	13.88	12.77	47.85	1.16	18.94	10.69	0.94	75333.03
9	13.80	12.58	46.59	0.54	20.69	9.84	0.94	80669.50
10	9.51	12.17	50.91	0.67	19.70	10.32	0.94	79274.14
11	12.44	12.37	51.73	1.45	18.73	10.57	0.94	83598.98
12	10.06	11.98	58.06	0.73	19.74	10.33	0.94	84479.37
13	12.63	12.31	53.78	1.50	18.89	10.31	0.94	82130.21
14	14.32	13.44	58.27	1.58	18.91	10.39	0.95	82457.84
15	11.25	11.93	53.30	1.58	18.79	10.36	0.97	81476.89
16	10.75	11.66	51.77	0.77	19.15	10.12	0.95	79827.71
17	9.00	11.49	41.84	0.76	19.45	9.82	0.95	81999.73
18	11.95	12.29	57.97	1.30	18.79	10.19	0.96	83727.17
19	10.58	12.00	51.21	1.41	18.21	10.46	0.97	83917.55
20	7.15	13.58	57.12	0.83	18.17	11.72	0.99	69639.51
21	9.91	12.11	48.77	0.94	20.64	9.83	0.99	84942.25
22	10.34	12.37	43.70	1.19	20.24	10.03	0.97	84156.86
23	9.36	11.86	48.77	1.19	20.00	9.97	0.97	85886.85
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	10.54	12.76	49.50	1.22	19.19	10.31	0.95	80115.14
最大值	14.32	15.25	58.72	1.81	20.69	11.72	1.02	85886.85
發生時間	14	1	4	6	9	20		23
最小值	5.20	11.43	36.56	0.54	18.17	9.66	0.93	67805.34
發生時間	6	6	7	9	20	7		1
零點偏移(率)	-0.11 %	0.00 %	-0.02 %	-0.01 %		-0.12	-0.01	-0.10 %
全幅偏移(率)	-0.92 %	1.60 %	0.24 %	0.28 %		-0.42	0.00	0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003\_樹林焚化廠CEMS系統日報表-A

報表日期: 115年04月04日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.53	14.22	48.75	0.66	18.77	9.37	1.32	77638.50
1	9.47	11.61	37.56	0.52	21.54	8.69	1.31	75943.09
2	8.43	12.69	31.77	1.11	20.44	8.28	1.31	75308.14
3	8.99	2.91	39.76	1.95	19.40	8.52	1.32	80251.37
4	9.54	5.35	54.65	0.92	18.54	9.32	1.32	75235.88
5	10.73	10.82	52.82	1.83	19.07	9.17	1.32	75251.93
6	11.53	11.09	48.78	1.71	19.43	9.18	1.33	76742.54
7	12.30	11.37	47.64	3.52	18.47	9.95	1.32	77374.65
8	10.83	11.36	51.23	3.09	17.71	9.78	1.32	75562.12
9	8.98	11.28	52.36	2.82	18.07	9.65	1.33	75630.93
10	9.15	11.52	50.19	2.91	18.10	9.73	1.33	76237.08
11	9.84	11.35	48.63	2.77	19.10	9.63	1.32	78256.58
12	8.59	11.31	55.90	2.96	20.68	9.53	1.31	77964.03
13	9.10	11.28	49.69	2.99	19.68	9.61	1.31	79256.35
14	9.78	13.08	52.94	3.16	18.50	9.82	1.31	77016.47
15	8.19	12.73	54.09	2.82	17.89	9.94	1.33	75629.39
16	9.15	14.76	57.51	2.17	17.23	10.10	1.35	78714.70
17	8.87	11.83	65.09	0.58	17.75	10.68	1.34	77121.07
18	8.53	11.71	57.32	0.75	16.63	10.60	1.34	77508.11
19	8.19	11.89	62.30	3.07	16.55	10.74	1.31	76426.69
20	6.85	11.84	61.25	2.86	17.17	10.59	1.33	78208.17
21	8.23	11.59	49.22	2.74	19.75	9.75	1.31	77946.44
22	9.01	14.07	56.83	3.00	19.09	10.00	1.32	81865.78
23	8.36	14.64	63.20	3.01	18.09	10.57	1.34	81176.86
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	9.26	11.51	52.06	2.25	18.65	9.72	1.32	77427.79
最大值	12.30	14.76	65.09	3.52	21.54	10.74	1.36	81865.78
發生時間	7	16	17	7	1	19		22
最小值	6.85	2.91	31.77	0.52	16.55	8.28	1.31	75235.88
發生時間	20	3	2	1	19	2		4
零點偏移(率)	-0.14 %	-0.02 %	-0.08 %	0.00 %		-0.12	-0.01	0.10 %
全幅偏移(率)	0.63 %	1.20 %	0.01 %	0.51 %		0.24	0.00	0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								