

## P001\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年06月09日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.79	2.17	43.83	3.59	16.73	10.85	1.27	70277.86
1	3.26	1.74	59.77	2.58	18.46	11.07	1.25	68723.76
2	2.87	2.07	61.73	2.56	19.74	11.11	1.24	67750.47
3	6.61	1.86	49.74	3.51	17.76	11.17	1.27	69637.54
4	2.68	2.22	62.83	2.79	18.06	11.97	1.29	65788.73
5	2.98	2.67	55.59	2.86	18.13	11.23	1.28	70121.02
6	2.94	2.17	67.52	2.86	19.07	11.12	1.29	70609.91
7	7.29	1.74	49.12	3.50	17.99	10.71	1.29	72979.71
8	5.25	2.04	45.69	3.43	16.44	11.57	1.28	68027.72
9	3.56	1.79	57.81	3.04	17.53	10.97	1.28	70988.53
10	8.40	2.94	41.83	4.44	15.08	11.69	1.29	67874.88
11	5.62	3.18	54.06	3.75	15.82	11.54	1.28	68014.34
12	5.35	2.12	52.01	3.17	16.95	11.42	1.28	69940.32
13	6.31	1.92	44.91	3.13	17.41	11.11	1.29	70323.38
14	5.04	1.93	52.06	3.11	17.12	11.03	1.33	70538.19
15	9.55	1.86	52.91	3.63	17.20	10.99	1.33	70086.11
16	10.18	2.79	47.16	3.98	16.27	11.07	1.32	70464.38
17	9.50	2.00	51.42	4.13	16.04	11.16	1.31	71042.37
18	9.36	3.89	47.75	4.95	14.67	11.53	1.30	68759.95
19	6.69	2.22	61.49	3.15	18.04	10.90	1.29	72537.49
20	7.70	7.42	42.23	4.01	16.00	11.27	1.28	69078.99
21	9.63	5.13	53.07	4.23	15.44	11.22	1.28	69687.86
22	7.86	4.04	45.36	4.00	16.08	11.37	1.26	68190.83
23	7.78	1.99	55.76	3.21	17.09	10.99	1.27	71199.84
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	6.47	2.66	52.32	3.48	17.05	11.21	1.29	69693.51
最大值	10.18	7.42	67.52	4.95	19.74	11.97	1.34	72979.71
發生時間	16	20	6	18	2	4		7
最小值	2.68	1.74	41.83	2.56	14.67	10.71	1.23	65788.73
發生時間	4	1	10	2	18	7		4
零點偏移(率)	0.00 %	-0.01 %	-0.02 %	-0.01 %		0.04	0.00	0.00 %
全幅偏移(率)	0.52 %	0.26 %	-0.38 %	0.04 %		0.01	0.00	0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

## P002\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年06月09日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.01	1.99	55.56	1.45	19.19	9.65	1.46	83867.24
1	6.55	3.98	41.78	0.94	22.05	9.25	1.46	84026.94
2	8.55	1.52	48.75	1.56	20.84	8.90	1.46	84736.07
3	5.76	6.79	32.63	1.47	21.39	8.30	1.46	81350.65
4	1.10	5.84	40.80	0.80	21.37	8.87	1.46	82148.06
5	0.54	2.62	35.84	0.61	21.62	9.17	1.46	80422.01
6	1.69	4.44	44.84	0.72	21.15	8.86	1.50	97051.48
7	2.03	3.73	44.34	1.33	18.61	9.45	1.51	80715.07
8	1.58	3.93	57.60	1.37	18.57	9.38	1.50	83873.35
9	3.86	2.69	48.93	1.89	17.14	9.67	1.49	81977.71
10	7.41	2.94	59.12	2.71	15.92	10.09	1.49	79522.97
11	5.56	2.63	53.64	1.88	17.75	9.76	1.46	82129.10
12	2.92	2.00	54.89	1.53	17.97	9.73	1.47	81505.44
13	2.86	4.95	57.76	1.34	18.75	9.61	1.46	82509.01
14	5.74	4.84	53.62	1.99	17.84	9.16	1.49	82526.62
15	8.67	2.60	55.11	2.72	15.93	9.67	1.49	78753.57
16	10.13	2.54	53.20	2.41	16.96	9.39	1.49	80859.38
17	9.31	1.70	48.83	2.05	17.59	9.33	1.47	81475.70
18	6.56	1.51	60.83	1.67	18.16	9.52	1.46	80096.49
19	1.11	2.94	50.29	0.82	20.52	9.05	1.47	83825.82
20	0.19	2.52	50.84	0.98	18.95	9.44	1.49	84881.71
21	2.02	8.13	58.23	2.11	15.56	9.97	1.49	79973.55
22	6.00	2.23	59.71	2.29	17.65	9.48	1.49	81628.69
23	9.51	2.09	45.11	5.03	17.83	9.18	1.49	80400.14
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	4.90	3.38	50.51	1.74	18.72	9.37	1.48	82510.70
最大值	10.13	8.13	60.83	5.03	22.05	10.09	1.51	97051.48
發生時間	16	21	18	23	1	10		6
最小值	0.19	1.51	32.63	0.61	15.56	8.30	1.45	78753.57
發生時間	20	18	3	5	21	3		15
零點偏移(率)	-0.02 %	-0.00 %	-0.10 %	-0.02 %		0.03	0.00	0.00 %
全幅偏移(率)	1.81 %	0.92 %	0.32 %	0.44 %		-0.04	0.00	0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

## P003\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年06月09日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.83	3.96	62.58	3.68	16.12	10.61	1.30	80899.55
1	8.69	2.16	54.00	3.52	18.81	10.12	1.29	85076.60
2	7.71	3.01	55.30	3.38	17.20	10.69	1.25	80750.41
3	6.75	2.29	65.39	3.69	17.51	10.53	1.25	80723.99
4	4.38	2.26	46.77	2.97	17.81	10.54	1.25	78838.40
5	4.23	6.20	54.73	6.34	19.72	9.78	1.26	82819.70
6	6.54	2.59	46.71	3.32	18.40	10.11	1.27	81619.79
7	5.62	8.50	47.67	2.68	17.27	10.17	1.27	81013.81
8	7.32	8.12	51.60	3.30	17.89	9.90	1.29	82871.62
9	11.14	3.26	55.04	3.81	16.33	10.32	1.34	82691.30
10	5.81	5.97	52.17	3.15	15.75	10.35	1.31	78991.35
11	6.79	3.47	53.44	3.11	16.20	10.20	1.30	77502.71
12	7.25	4.32	47.68	2.87	16.46	10.00	1.30	78308.92
13	5.41	2.55	54.68	2.59	16.63	9.94	1.31	78664.14
14	3.66	3.05	52.82	2.46	16.72	10.08	1.29	78596.25
15	5.44	3.17	54.57	2.90	15.91	10.26	1.27	77970.58
16	6.57	4.21	53.70	3.31	16.37	10.15	1.28	79592.21
17	9.19	5.61	52.96	3.04	16.64	10.13	1.30	78723.34
18	7.47	4.93	53.43	3.33	16.38	10.23	1.31	78258.05
19	8.05	5.10	54.21	3.03	18.26	9.75	1.28	83641.72
20	5.35	2.69	52.56	2.63	18.40	10.02	1.25	80330.43
21	7.89	10.21	49.82	3.85	14.97	10.34	1.25	76701.42
22	6.75	5.11	53.39	3.46	15.41	10.62	1.25	75343.70
23	8.12	4.84	54.37	3.11	16.77	10.14	1.27	80474.79
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	6.92	4.48	53.32	3.31	17.00	10.21	1.28	80016.87
最大值	11.14	10.21	65.39	6.34	19.72	10.69	1.36	85076.60
發生時間	9	21	3	5	5	2		1
最小值	3.66	2.16	46.71	2.46	14.97	9.75	1.24	75343.70
發生時間	14	1	6	14	21	19		22
零點偏移(率)	0.00 %	-0.00 %	-0.13 %	-0.10 %		0.00	0.00	0.00 %
全幅偏移(率)	3.80 %	0.97 %	-0.53 %	0.50 %		0.31	-0.03	0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								