

P001 樹林焚化廠CEMS系統日報表-A 報表日期: 114年04月02日

報表日期: 114年04月02日

項目 單位	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
小時\限標	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	7.65	3.46	53.72	1.21	18.27	10.38	1.30	78676.01
1	5.91	6.47	53.85	0.90	19.87	10.26	1.30	84471.63
2	9.02	2.75	63.06	0.90	19.13	10.33	1.31	84382.89
3	8.00	2.88	52.38	1.19	18.70	10.16	1.31	85369.01
4	8.57	3.28	61.12	1.21	17.83	10.54	1.33	85140.15
5	7.63	5.98	47.10	1.68	17.30	10.81	1.34	81790.39
6	6.85	5.54	50.71	1.89	16.73	10.85	1.34	80567.31
7	6.98	4.97	50.13	1.26	18.00	10.43	1.33	82593.38
8	5.03	7.60	50.82	1.49	17.64	10.29	1.31	83732.17
9	11.78	2.68	54.21	1.56	17.95	10.25	1.29	82783.86
10	11.53	2.93	44.96	1.80	17.21	10.18	1.29	81535.11
11	4.76	2.91	50.74	1.86	15.61	10.72	1.31	78218.52
12	4.74	2.59	55.62	1.02	18.05	10.38	1.34	79659.64
13	8.32	2.86	49.50	1.67	16.95	10.42	1.34	79444.46
14	10.26	3.74	48.44	1.81	16.40	10.29	1.33	80130.81
15	10.88	4.12	49.26	1.86	15.83	10.42	1.32	78648.94
16	6.76	2.82	47.82	0.97	17.32	10.18	1.35	81516.90
17	13.55	2.71	49.60	1.83	16.56	10.27	1.35	80478.61
18	7.05	2.77	57.51	1.01	17.49	11.07	1.34	74580.32
19	6.83	3.38	58.58	0.63	18.72	10.04	1.32	80629.30
20	12.26	6.15	53.12	1.41	17.49	9.91	1.31	83928.72
21	9.15	4.51	43.73	1.43	16.87	10.21	1.31	82875.79
22	13.82	3.59	42.28	1.98	15.64	10.69	1.30	79747.19
23	8.84	5.45	43.18	1.36	17.87	10.13	1.30	81312.73
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	8.59	4.01	51.31	1.41	17.48	10.38	1.32	81342.24
最 大 值	13.82	7.60	63.06	1.98	19.87	11.07	1.36	85369.01
發生時間	22	8	2	22	1	18		3
最 小 值	4.74	2.59	42.28	0.63	15.61	9.91	1.29	74580.32
發生時間	12	12	22	19	11	20		18
零點偏移(率)	-0.73 %	0.00 %	-0.14 %	0.00 %		0.00		0.30 %
全幅偏移(率)	1.02 %	0.41 %	0.47 %	0.00 %		0.17		0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002 樹林焚化廠CEMS系統日報表-A

報表日期: 114年04月02日

項目 單位	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO ₂ _C	#2-H ₂ O	#2-O ₂ _C	#2-OPAC	#2-FLOW_C
小時\限標	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.21	3.40	49.39	1.22	18.36	10.15	1.07	84818.87
1	8.94	12.64	61.19	1.96	18.43	10.39	1.07	84868.56
2	9.41	4.11	64.45	3.08	16.26	10.50	1.07	87949.10
3	8.99	5.17	54.05	2.88	16.93	10.43	1.07	88044.78
4	8.94	2.60	55.55	2.42	16.19	10.70	1.08	86550.21
5	9.30	2.50	59.11	2.93	15.92	10.75	1.08	85760.33
6	8.60	3.93	63.60	2.24	17.68	10.31	1.08	86387.02
7	7.90	8.67	50.95	2.35	15.90	10.63	1.06	86356.38
8	8.22	1.49	53.18	2.83	14.81	11.06	1.07	83369.20
9	8.82	2.43	58.29	2.16	16.15	10.91	1.08	84079.56
10	8.97	5.27	54.72	2.52	15.50	10.81	1.09	84447.87
11	8.94	2.87	54.22	2.48	15.24	10.99	1.11	84384.06
12	12.05	3.04	53.57	2.79	15.27	10.87	1.10	85025.35
13	9.14	7.96	56.51	2.56	14.83	10.84	1.07	83994.86
14	8.06	3.83	54.39	2.76	14.31	10.99	1.06	83090.28
15	8.45	6.50	55.67	2.34	15.00	10.76	1.06	82260.71
16	9.01	2.36	62.61	1.43	16.90	10.28	1.06	85440.82
17	9.17	1.96	60.30	1.46	17.80	10.17	1.09	87784.41
18	10.54	5.08	51.14	2.19	16.33	10.26	1.10	88835.24
19	8.61	3.03	52.30	1.64	16.91	10.25	1.09	86971.97
20	9.46	3.39	44.35	2.16	16.73	9.94	1.08	85267.26
21	8.45	2.75	46.59	2.69	15.42	10.19	1.06	84920.83
22	8.95	3.73	46.54	2.21	16.13	10.40	1.06	82839.30
23	8.21	3.65	54.15	2.08	16.55	10.26	1.06	85073.66
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	9.01	4.26	54.87	2.31	16.23	10.53	1.08	85355.03
最 大 值	12.05	12.64	64.45	3.08	18.43	11.06	1.12	88835.24
發生時間	12	1	2	2	1	8		18
最 小 值	7.90	1.49	44.35	1.22	14.31	9.94	1.06	82260.71
發生時間	7	8	20	0	14	20		15
零點偏移(率)	-0.20 %	0.00 %	-0.02 %	-0.03 %		0.03		0.10 %
全幅偏移(率)	-0.31 %	0.42 %	0.28 %	0.12 %		0.10		0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A

報表日期: 114年04月02日

項目 單位 小時\限標	#3-HCl_C ppm	#3-CO_C ppm	#3-NOx_C ppm	#3-SO2_C ppm	#3-H2O %	#3-O2_C %	#3-OPAC %	#3-FLOW_C m3/Hour
0	8.27	3.28	56.96	0.55	17.84	9.59	1.52	82706.01
1	1.97	3.53	54.58	0.45	18.49	9.88	1.52	80536.58
2	4.06	8.40	55.61	0.59	18.26	9.64	1.53	82875.96
3	7.97	6.76	61.82	0.90	17.62	9.73	1.52	86460.12
4	9.11	7.27	54.55	0.98	15.90	10.30	1.55	85492.88
5	6.21	6.37	61.53	1.40	15.09	10.45	1.55	83152.49
6	6.56	2.57	62.58	0.84	16.67	10.14	1.53	82037.54
7	8.77	6.56	58.06	0.69	17.11	9.90	1.53	84710.12
8	4.50	2.28	60.58	0.96	15.01	10.69	1.52	80971.61
9	10.59	2.45	53.93	1.61	15.87	10.24	1.52	78920.12
10	8.93	9.66	57.31	2.60	14.63	10.13	1.52	80480.78
11	8.14	8.88	65.33	1.67	14.19	10.65	1.54	79088.43
12	8.50	8.91	60.54	1.43	14.69	10.47	1.53	80058.72
13	6.84	6.99	58.66	1.34	15.34	10.21	1.54	78699.46
14	5.95	3.88	58.91	1.22	14.91	10.09	1.54	78233.55
15	8.79	3.48	59.00	1.28	15.46	9.95	1.53	78450.31
16	6.11	2.62	59.45	0.84	17.08	9.56	1.52	84964.02
17	10.43	2.47	57.43	1.09	16.39	9.89	1.53	84832.02
18	9.01	2.27	59.50	0.89	16.33	9.82	1.53	83564.61
19	11.26	3.99	56.62	1.19	16.12	9.93	1.53	83411.76
20	9.32	6.04	54.93	1.09	16.14	9.91	1.52	83431.01
21	10.33	6.55	55.45	1.20	16.15	9.72	1.52	83207.13
22	7.95	3.13	57.97	1.27	15.31	10.02	1.52	78394.22
23	4.70	1.83	61.74	0.98	15.96	10.44	1.53	77174.65
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	7.68	5.01	58.46	1.13	16.11	10.06	1.53	81743.92
最 大 值	11.26	9.66	65.33	2.60	18.49	10.69	1.57	86460.12
發生時間	19	10	11	10	1	8		3
最 小 值	1.97	1.83	53.93	0.45	14.19	9.56	1.52	77174.65
發生時間	1	23	9	1	11	16		23
零點偏移(率)	-0.08 %	-0.01 %	-0.10 %	-0.03 %		0.05		-0.10 %
全幅偏移(率)	0.01 %	-0.46 %	0.19 %	-0.09 %		0.39		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								