

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 112年01月21日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	10.17	4.08	57.37	2.51	16.69	12.11	1.46	73000.74
1	8.67	4.77	49.10	2.57	16.58	12.12	1.46	72803.99
2	8.36	3.00	51.01	2.33	17.80	11.86	1.46	74442.68
3	9.46	3.24	60.74	2.22	17.85	11.70	1.47	75182.98
4	9.59	4.53	57.50	2.26	17.54	11.72	1.47	75115.63
5	12.38	7.89	63.61	2.33	17.26	11.76	1.47	77894.46
6	8.72	3.21	64.93	2.19	17.17	11.80	1.46	74427.42
7	10.09	3.11	63.56	2.45	16.44	12.11	1.47	73053.64
8	10.37	11.76	54.09	2.86	15.40	12.32	1.46	71710.59
9	11.00	2.06	52.88	2.60	15.93	12.27	1.46	72040.07
10	9.99	4.35	58.52	2.17	17.28	11.79	1.50	74504.52
11	8.12	7.25	49.28	2.75	15.48	12.33	1.51	71575.02
12	8.23	2.65	53.47	2.51	16.50	12.34	1.51	71045.96
13	10.38	4.45	50.13	2.55	16.22	12.11	1.49	72142.35
14	6.32	2.79	56.63	2.43	16.68	12.44	1.48	69395.24
15	8.79	1.26	57.63	2.06	17.78	11.90	1.51	72899.60
16	10.00	1.57	56.54	2.16	17.69	11.91	1.51	72571.52
17	9.58	1.98	60.07	2.08	18.01	11.78	1.50	73128.56
18	9.49	2.63	55.73	2.20	17.54	12.09	1.47	70904.68
19	8.46	1.68	56.05	2.13	17.75	11.98	1.46	72106.64
20	8.31	1.12	55.27	2.10	17.40	11.92	1.48	71286.74
21	4.03	1.51	56.84	1.93	18.17	11.67	1.50	72741.98
22	8.41	1.96	55.92	2.02	18.10	11.74	1.47	72779.13
23	7.99	1.68	55.52	2.06	17.77	11.86	1.50	72095.83
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	9.04	3.52	56.35	2.31	17.13	11.98	1.48	72868.75
最大值	12.38	11.76	64.93	2.86	18.17	12.44	1.53	77894.46
發生時間	5	8	6	8	21	14		5
最小值	4.03	1.12	49.10	1.93	15.40	11.67	1.46	69395.24
發生時間	21	20	1	21	8	21		14
零點偏移(率)	-0.02 %	0.00 %	-0.00 %	-0.00 %		0.00	0.00	0.00 %
全幅偏移(率)	1.22 %	0.02 %	0.21 %	-0.06 %		0.28	-0.03	0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 112年01月21日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	10.26	3.48	51.24	2.29	14.79	11.12	1.37	65550.95
1	10.95	4.81	54.62	2.23	15.73	11.04	1.36	65607.17
2	10.76	2.57	54.07	2.46	15.26	10.89	1.36	65289.90
3	10.42	3.72	47.00	2.47	15.39	10.68	1.36	64176.63
4	12.01	7.13	51.11	2.64	14.75	10.67	1.36	64199.42
5	10.82	8.60	45.32	2.51	14.62	10.36	1.36	64239.37
6	9.16	3.40	47.40	2.54	14.31	10.69	1.43	62005.80
7	10.71	3.93	63.75	2.44	13.97	10.88	1.46	66721.16
8	11.68	3.45	54.03	2.59	13.32	11.09	1.46	61998.51
9	9.53	10.72	47.36	2.69	12.72	10.76	1.46	61169.91
10	10.70	1.88	50.02	2.30	14.83	10.92	1.48	61794.91
11	11.01	1.42	55.84	2.18	15.73	10.85	1.50	64712.13
12	10.50	0.89	58.32	2.06	16.26	10.78	1.49	65155.05
13	10.13	1.75	49.48	2.33	15.91	10.85	1.45	64466.53
14	8.11	4.19	44.85	2.25	16.23	11.04	1.43	56260.11
15	10.10	1.50	42.13	2.09	16.94	10.58	1.45	63577.70
16	10.80	4.86	57.83	2.13	16.62	11.18	1.46	62381.54
17	10.16	1.58	55.09	2.30	16.02	10.93	1.46	65371.73
18	9.99	0.93	51.84	2.10	16.26	11.03	1.46	63758.46
19	9.69	1.76	49.03	1.96	16.46	10.64	1.45	62094.80
20	9.75	1.02	45.09	2.39	15.34	10.74	1.45	63000.51
21	10.30	0.93	47.74	2.16	16.00	10.78	1.47	63175.18
22	7.53	2.97	48.08	2.36	15.43	11.25	1.45	57176.32
23	9.59	2.80	47.58	2.39	14.17	11.02	1.44	61291.55
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	10.19	3.35	50.78	2.33	15.29	10.87	1.43	63132.31
最大值	12.01	10.72	63.75	2.69	16.94	11.25	1.51	66721.16
發生時間	4	9	7	9	15	22		7
最小值	7.53	0.89	42.13	1.96	12.72	10.36	1.35	56260.11
發生時間	22	12	15	19	9	5		14
零點偏移(率)	-0.02 %	-0.00 %	-0.08 %	-0.00 %		-0.03	0.00	0.00 %
全幅偏移(率)	0.96 %	-0.27 %	0.36 %	0.13 %		0.29	-0.03	0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 112年01月21日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	13.50	6.00	59.32	3.29	12.48	11.59	1.72	79576.12
1	14.92	7.05	54.48	2.98	13.00	11.31	1.72	79800.89
2	13.76	1.39	63.77	3.29	12.77	11.71	1.72	82775.19
3	8.73	3.26	67.16	3.41	12.01	11.83	1.72	81779.73
4	13.62	5.13	62.57	3.70	11.56	11.75	1.72	79539.97
5	9.67	2.73	60.56	3.32	12.09	11.53	1.72	80711.20
6	7.08	6.57	57.02	2.96	12.84	11.59	1.74	80896.04
7	15.42	3.64	60.27	3.22	12.31	11.77	1.78	77446.42
8	11.79	13.19	56.91	3.14	12.36	11.98	1.79	79058.24
9	11.30	2.61	53.82	2.84	12.48	11.31	1.80	81766.08
10	8.98	2.73	54.24	2.50	13.27	11.20	1.81	80094.10
11	16.03	2.06	64.45	1.80	15.35	10.64	1.80	83530.36
12	8.46	8.21	53.13	2.28	14.25	11.18	1.78	81782.32
13	10.07	1.81	47.23	2.38	13.76	11.18	1.78	79158.33
14	9.43	1.05	49.44	2.35	14.23	11.06	1.80	78500.08
15	10.73	3.28	47.11	2.21	14.75	10.79	1.80	80018.79
16	14.70	0.83	49.59	2.58	14.55	10.81	1.80	79628.29
17	11.89	0.98	51.14	2.31	15.31	10.72	1.80	81442.72
18	9.95	1.72	54.54	2.22	14.85	10.92	1.80	81574.39
19	9.77	1.03	57.10	2.22	14.97	11.15	1.80	82073.26
20	8.06	10.79	53.40	3.04	15.69	10.98	1.80	82806.45
21	9.48	1.79	53.39	1.81	15.10	11.13	1.80	83809.98
22	10.77	2.97	55.28	2.33	13.93	11.32	1.80	82564.71
23	8.18	1.18	62.40	1.99	14.75	11.38	1.80	81833.02
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	11.10	3.83	56.18	2.67	13.69	11.28	1.78	80923.61
最大值	16.03	13.19	67.16	3.70	15.69	11.98	1.84	83809.98
發生時間	11	8	3	4	20	8		21
最小值	7.08	0.83	47.11	1.80	11.56	10.64	1.72	77446.42
發生時間	6	16	15	11	4	11		7
零點偏移(率)	0.00 %	0.00 %	-0.08 %	-0.02 %		0.01	0.00	0.00 %
全幅偏移(率)	3.61 %	0.72 %	-0.16 %	0.38 %		0.29	0.00	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								