

## P001\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年03月01日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	6.95	2.49	58.39	3.18	14.35	12.57	1.44	67407.87
1	7.13	8.12	50.89	3.59	14.22	12.70	1.44	66759.54
2	5.72	3.30	61.20	2.32	15.82	12.09	1.44	70541.51
3	4.98	3.46	64.45	3.21	14.07	12.49	1.44	69280.42
4	2.18	5.16	61.66	2.03	16.25	11.79	1.42	73548.36
5	2.92	12.00	37.09	3.38	13.74	12.43	1.40	69261.19
6	4.25	3.50	51.83	2.74	15.33	12.11	1.38	71165.86
7	6.31	3.66	58.89	3.58	13.56	12.42	1.39	70496.12
8	5.77	3.59	54.78	3.49	13.96	12.44	1.40	69273.20
9	7.58	3.66	53.96	3.38	14.27	12.27	1.42	70374.73
10	7.47	3.31	52.59	3.28	14.05	12.35	1.42	69877.05
11	5.96	3.78	54.49	3.24	14.22	12.45	1.39	68994.95
12	5.62	3.90	62.96	3.27	14.07	12.39	1.44	69649.96
13	9.58	5.40	52.46	3.67	13.95	12.49	1.45	68739.49
14	15.60	19.00	53.85	4.68	12.49	12.72	1.40	68331.42
15	14.99	9.74	56.30	4.30	13.13	12.58	1.40	69688.74
16	8.75	2.95	61.98	2.89	14.30	12.22	1.46	70598.81
17	8.98	3.31	48.24	3.08	14.18	12.31	1.43	70125.71
18	11.48	7.66	54.90	3.98	12.78	12.67	1.41	68224.28
19	10.25	4.87	55.80	3.92	13.08	12.52	1.39	69192.56
20	9.51	3.03	56.29	3.05	14.63	12.20	1.38	70897.64
21	8.93	3.09	60.83	2.99	14.64	12.34	1.38	69412.13
22	8.23	4.55	61.64	3.01	14.51	12.31	1.39	69680.13
23	8.30	6.59	51.95	3.80	12.95	12.62	1.38	68441.13
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	7.81	5.42	55.73	3.34	14.11	12.40	1.41	69581.78
最大值	15.60	19.00	64.45	4.68	16.25	12.72	1.47	73548.36
發生時間	14	14	3	14	4	14		4
最小值	2.18	2.49	37.09	2.03	12.49	11.79	1.37	66759.54
發生時間	4	0	5	4	14	4		1
零點偏移(率)	-0.01 %	-0.05 %	-0.02 %	0.00 %		-0.02	0.00	0.00 %
全幅偏移(率)	2.44 %	0.73 %	-0.48 %	0.25 %		0.08	0.00	0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

## P002\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年03月01日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.43	4.81	51.67	2.43	15.28	11.16	1.38	78807.28
1	3.41	1.97	59.77	1.51	17.30	10.92	1.42	80619.87
2	3.37	3.52	54.21	1.98	16.29	10.78	1.44	82693.56
3	5.23	2.14	54.34	2.04	16.56	10.48	1.45	81355.75
4	3.99	1.69	64.04	1.69	17.73	10.64	1.45	84530.50
5	5.80	5.58	46.64	2.00	17.11	10.51	1.44	84282.56
6	5.45	10.94	65.47	2.13	15.96	11.09	1.42	95847.06
7	5.41	3.45	52.75	2.32	15.49	11.04	1.43	82456.45
8	4.52	4.65	55.98	2.04	16.56	10.59	1.42	81766.84
9	6.37	4.44	50.95	2.35	15.98	10.57	1.39	82816.54
10	8.23	4.22	53.50	2.28	17.20	10.18	1.36	84919.07
11	5.54	3.30	47.59	2.17	16.57	10.48	1.38	81631.20
12	2.53	3.20	56.48	1.37	18.59	10.01	1.39	80702.04
13	4.51	4.39	42.51	1.90	18.00	10.03	1.36	85912.09
14	9.21	5.09	55.77	2.71	15.54	10.87	1.37	81847.76
15	5.40	4.13	50.67	1.80	17.47	10.18	1.33	83175.07
16	1.26	4.38	42.27	1.47	17.38	9.93	1.37	81205.80
17	7.87	5.62	52.10	2.44	15.46	10.23	1.38	78748.70
18	10.37	5.91	57.14	2.49	16.83	10.38	1.38	82699.94
19	8.31	3.80	55.75	1.96	18.23	10.45	1.38	81765.04
20	3.61	6.28	64.07	1.46	17.68	11.86	1.38	74459.31
21	4.69	6.64	38.58	2.02	17.78	10.39	1.36	85245.03
22	7.65	1.02	42.94	1.86	16.01	10.68	1.36	83538.30
23	7.49	2.29	60.15	1.69	16.32	10.65	1.35	82797.15
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	5.78	4.31	53.14	2.00	16.81	10.59	1.39	82659.29
最大值	10.37	10.94	65.47	2.71	18.59	11.86	1.45	95847.06
發生時間	18	6	6	14	12	20		6
最小值	1.26	1.02	38.58	1.37	15.28	9.93	1.33	74459.31
發生時間	16	22	21	12	0	16		20
零點偏移(率)	-0.02 %	-0.05 %	-0.02 %	0.00 %		-0.07	0.00	0.00 %
全幅偏移(率)	1.78 %	0.89 %	-0.68 %	0.29 %		0.05	-0.03	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年03月01日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	2.56	2.65	61.64	1.85	14.46	11.27	1.77	80611.27
1	4.34	3.78	58.93	1.57	15.55	11.20	1.76	80444.61
2	1.11	3.62	60.47	1.23	16.63	10.87	1.76	81778.31
3	1.88	3.58	59.87	1.42	15.93	10.85	1.77	82843.00
4	3.54	3.31	63.95	1.82	15.14	11.02	1.78	81631.03
5	3.56	5.14	62.58	1.53	16.51	10.80	1.77	83739.19
6	2.32	6.16	54.27	1.55	15.42	10.93	1.77	82696.82
7	5.43	4.42	57.60	1.92	17.01	10.53	1.85	80228.87
8	3.39	4.23	60.63	1.72	15.79	10.76	1.85	83354.35
9	5.52	3.32	55.65	1.89	15.39	10.80	1.84	82524.73
10	6.35	3.96	57.04	1.76	15.63	10.37	1.85	85373.18
11	4.63	6.92	60.81	2.10	15.99	10.46	1.86	84968.60
12	5.11	7.87	54.60	2.22	14.79	10.63	1.89	83385.81
13	4.63	4.18	58.74	1.90	16.59	10.38	1.88	82346.28
14	3.76	9.10	55.48	2.01	15.32	10.71	1.88	81018.15
15	5.63	3.71	64.16	2.01	15.58	10.84	1.89	84081.40
16	4.34	3.13	64.26	2.18	14.80	11.06	1.89	81571.48
17	8.21	9.06	58.40	2.80	14.20	10.88	1.87	81836.14
18	6.45	3.39	66.92	3.36	13.17	11.63	1.83	78490.24
19	5.94	1.63	68.73	2.16	17.41	10.96	1.83	82437.77
20	3.64	2.44	56.60	1.73	18.82	10.28	1.84	87452.15
21	1.46	1.66	61.31	1.57	17.92	10.78	1.84	83913.94
22	2.86	1.29	57.59	1.72	16.55	10.78	1.83	85404.13
23	5.02	3.52	62.83	2.56	14.39	11.23	1.84	82237.75
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	4.24	4.25	60.13	1.94	15.79	10.83	1.83	82682.05
最大值	8.21	9.10	68.73	3.36	18.82	11.63	1.97	87452.15
發生時間	17	14	19	18	20	18		20
最小值	1.11	1.29	54.27	1.23	13.17	10.28	1.75	78490.24
發生時間	2	22	6	2	18	20		18
零點偏移(率)	-0.01 %	-0.02 %	-0.02 %	-0.00 %		0.02	0.00	0.00 %
全幅偏移(率)	0.03 %	-4.25 %	-1.22 %	-0.73 %		0.25	0.02	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								