

P001 樹林焚化廠CEMS系統日報表-A

報表日期: 113年12月09日

項目 單位 小時\限標	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	10.86	3.05	50.35	2.79	13.08	12.18	0.99	78236.93
1	5.91	7.68	53.55	1.35	15.20	11.66	0.99	80006.43
2	7.53	2.58	43.98	2.77	13.91	11.55	1.02	78711.61
3	5.19	2.82	46.13	1.91	14.01	12.10	1.02	75320.70
4	4.57	2.77	63.08	1.06	15.45	12.11	1.02	77046.17
5	9.08	1.64	48.53	1.01	16.31	11.62	1.02	82299.74
6	8.29	1.53	56.62	1.00	15.55	11.82	1.02	81645.36
7	9.60	4.48	39.89	2.83	13.04	12.17	1.02	78937.68
8	6.93	2.37	33.48	1.22	13.77	12.15	1.02	73743.46
9	10.92	2.80	52.43	0.80	14.67	11.97	1.04	80843.76
10	9.93	2.33	52.67	1.40	13.09	12.30	1.03	77849.28
11	8.52	3.77	60.54	1.39	14.22	12.21	1.00	77227.60
12	10.20	4.93	49.12	2.87	12.96	12.31	1.02	78115.25
13	6.64	3.66	52.17	1.35	15.06	11.93	1.05	80672.22
14	0.48	2.53	56.56	3.07	12.14	13.58	1.05	70817.53
15	2.78	2.69	60.84	0.84	15.36	11.88	1.03	81635.32
16	8.48	2.87	56.11	1.37	14.51	11.86	1.02	82389.53
17	9.10	2.38	51.03	1.98	14.02	12.01	1.00	81175.23
18	8.42	2.30	50.20	2.48	12.86	12.25	0.99	79687.14
19	7.60	2.15	63.11	1.52	14.42	11.87	1.00	82253.93
20	8.66	3.13	58.58	1.27	14.63	11.98	1.02	81003.21
21	6.20	3.92	68.27	0.79	15.27	11.81	1.02	81697.27
22	7.07	4.95	44.51	1.07	15.04	11.75	1.03	82362.39
23	8.44	6.58	53.93	0.76	16.09	11.59	1.00	82773.98
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	7.56	3.33	52.74	1.62	14.36	12.03	1.02	79435.49
最 大 值	10.92	7.68	68.27	3.07	16.31	13.58	1.06	82773.98
發生時間	9	1	21	14	5	14		23
最 小 值	0.48	1.53	33.48	0.76	12.14	11.55	0.98	70817.53
發生時間	14	6	8	23	14	2		14
零點偏移(率)	-0.05 %	-0.00 %	-0.03 %	-0.02 %		-0.20		0.00 %
全幅偏移(率)	0.00 %	0.75 %	-0.59 %	0.97 %		0.18		0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A

報表日期: 113年12月09日

項目 單位 小時\限標	#3-HCl_C ppm	#3-CO_C ppm	#3-NOx_C ppm	#3-SO2_C ppm	#3-H2O %	#3-O2_C %	#3-OPAC %	#3-FLOW_C m3/Hour
0	8.95	3.59	41.47	0.29	14.47	10.45	1.77	73801.73
1	7.04	2.89	45.21	0.20	14.20	10.60	1.76	72774.24
2	7.95	7.53	41.56	0.22	16.23	10.14	1.76	73126.20
3	6.12	1.52	42.10	0.16	15.02	10.71	1.76	66251.11
4	3.37	1.72	57.69	0.09	15.98	11.13	1.76	76915.06
5	8.52	2.20	37.22	0.17	16.31	10.44	1.76	80640.94
6	8.91	5.02	35.51	0.21	15.00	10.61	1.78	79278.88
7	11.58	5.74	37.94	3.77	14.65	10.40	1.76	70374.31
8	10.38	4.24	45.91	1.94	13.57	10.63	1.74	71316.68
9	10.90	6.15	46.89	3.01	13.33	10.59	1.72	71025.17
10	11.66	7.77	44.69	2.78	14.08	10.34	1.75	71594.70
11	9.94	2.40	45.48	2.14	14.67	10.26	1.74	72476.93
12	9.49	1.65	45.54	2.35	15.36	10.27	1.74	70675.98
13	9.54	2.25	57.66	1.44	16.89	9.93	1.76	77212.76
14	8.57	1.74	49.08	0.89	16.10	10.65	1.71	69752.74
15	10.13	2.08	60.17	1.94	15.69	10.07	1.76	79818.76
16	10.73	3.70	51.72	2.00	14.95	10.30	1.76	77293.05
17	11.05	4.20	49.58	2.36	14.74	10.42	1.76	76052.27
18	10.31	3.09	51.87	1.50	14.78	10.25	1.76	75970.30
19	10.02	3.04	51.97	1.13	16.96	9.79	1.76	78332.08
20	9.90	1.70	52.25	1.01	16.03	9.99	1.76	81205.80
21	10.00	3.74	59.62	0.92	16.32	10.28	1.76	81048.20
22	10.14	4.41	54.56	0.89	16.25	10.36	1.76	78387.82
23	10.27	3.33	61.87	0.78	16.25	10.40	1.76	79746.87
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	9.39	3.57	48.65	1.34	15.33	10.38	1.75	75211.36
最 大 值	11.66	7.77	61.87	3.77	16.96	11.13	2.00	81205.80
發生時間	10	10	23	7	19	4		20
最 小 值	3.37	1.52	35.51	0.09	13.33	9.79	1.70	66251.11
發生時間	4	3	6	4	9	19		3
零點偏移(率)	-0.01 %	-0.03 %	-0.04 %	-0.01 %		0.00		0.00 %
全幅偏移(率)	0.31 %	-0.59 %	-0.28 %	0.22 %		0.23		0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								