

## P001\_樹林焚化廠CEMS系統日報表-A

報表日期: 113年04月24日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	7.12	6.88	52.66	1.01	17.54	11.56	1.01	81973.07
1	6.14	8.29	52.26	1.68	16.85	11.98	1.01	79080.60
2	6.48	9.49	58.01	1.73	16.54	12.04	1.00	78765.03
3	4.91	7.01	58.16	0.90	17.84	11.64	1.01	81050.86
4	4.18	8.40	45.93	1.54	16.24	11.90	1.01	80254.66
5	6.78	6.32	61.77	1.45	17.68	11.31	0.98	82727.09
6	7.19	6.69	57.25	1.74	16.80	11.66	1.00	81805.34
7	7.57	6.51	58.06	1.09	17.54	11.63	0.99	82087.98
8	8.26	6.59	50.26	2.32	15.71	11.87	0.96	81280.27
9	6.08	6.98	58.78	1.34	17.12	11.63	0.98	82852.46
10	3.62	7.89	63.38	0.73	17.21	12.02	0.97	78978.57
11	7.48	11.09	53.91	1.80	17.28	11.48	0.96	83599.41
12	10.17	3.86	45.05	3.21	15.14	11.90	0.94	81816.50
13	9.23	6.21	47.30	2.72	14.81	12.14	0.96	80174.32
14	10.96	6.63	50.16	2.70	14.49	12.06	0.97	81478.66
15	9.61	5.78	46.09	2.88	14.26	12.22	0.96	80307.30
16	3.58	1.53	65.47	0.83	16.14	12.35	0.96	77234.87
17	3.84	1.54	52.20	0.66	17.69	11.93	0.97	79706.72
18	3.13	6.12	47.53	0.53	18.81	11.30	0.99	83805.82
19	8.26	5.46	41.76	1.48	17.70	11.29	0.98	84642.96
20	9.17	3.32	40.02	2.13	16.26	11.65	0.96	83366.90
21	9.98	2.84	42.13	2.10	16.69	11.39	0.97	84972.26
22	9.54	2.79	43.32	1.99	16.79	11.56	0.98	83349.93
23	7.76	5.10	49.95	1.70	16.22	11.72	0.99	82580.28
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	7.13	5.97	51.73	1.68	16.64	11.76	0.98	81578.83
最大值	10.96	11.09	65.47	3.21	18.81	12.35	1.03	84972.26
發生時間	14	11	16	12	18	16		21
最小值	3.13	1.53	40.02	0.53	14.26	11.29	0.93	77234.87
發生時間	18	16	20	18	15	19		16
零點偏移(率)	-0.03 %	-0.01 %	-0.09 %	-0.00 %		-0.08		0.10 %
全幅偏移(率)	0.00 %	-0.25 %	0.23 %	0.40 %		0.03		0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

## P002\_樹林焚化廠CEMS系統日報表-A

報表日期: 113年04月24日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	4.13	7.21	58.77	2.10	16.90	12.19	1.02	71729.83
1	8.41	5.79	45.66	2.39	18.42	10.41	1.02	84238.96
2	9.82	4.28	53.96	2.06	18.18	10.67	1.02	82674.43
3	6.87	3.49	60.42	1.32	18.16	11.09	1.02	79753.64
4	4.88	3.82	51.43	1.52	18.28	11.03	1.01	80079.76
5	6.47	3.90	56.82	1.55	18.12	11.14	0.99	79148.76
6	3.98	4.21	57.08	0.65	18.83	11.34	0.98	77647.45
7	5.60	4.72	45.36	2.08	17.38	11.16	0.99	79833.68
8	4.49	4.32	61.33	1.83	16.98	11.54	0.96	76597.06
9	1.83	5.30	67.23	1.65	16.49	12.37	0.98	71669.19
10	0.00	4.64	49.98	0.72	19.30	11.47	0.94	76395.93
11	0.00	6.96	53.69	0.61	19.54	10.58	0.94	83345.57
12	0.19	5.10	41.92	1.23	18.48	10.37	0.94	85725.45
13	3.16	5.15	46.81	2.88	15.48	11.20	0.96	81400.20
14	5.97	4.87	66.15	3.71	14.29	11.66	0.97	79470.15
15	8.09	2.90	61.35	3.35	14.89	11.78	0.95	77523.12
16	9.83	3.90	48.56	2.93	16.60	10.89	0.94	83195.16
17	7.74	2.52	57.14	2.77	15.62	11.59	0.96	78960.22
18	1.81	9.42	62.07	1.56	16.60	12.19	0.99	72737.90
19	8.80	3.19	54.54	1.84	18.01	11.04	0.95	81082.71
20	13.02	4.84	41.21	3.37	17.05	11.15	0.96	81127.61
21	8.97	3.65	34.75	2.59	15.67	11.62	0.99	77949.49
22	11.35	3.66	33.88	3.69	15.02	11.55	1.01	79568.42
23	7.54	3.13	44.31	2.39	15.64	11.54	1.02	78790.92
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	5.96	4.62	52.27	2.12	17.08	11.32	0.98	79193.57
最大值	13.02	9.42	67.23	3.71	19.54	12.37	1.05	85725.45
發生時間	20	18	9	14	11	9		12
最小值	0.00	2.52	33.88	0.61	14.29	10.37	0.94	71669.19
發生時間	10	17	22	11	14	12		9
零點偏移(率)	-0.10 %	-0.00 %	-0.03 %	-0.01 %		-0.07		-0.10 %
全幅偏移(率)	0.14 %	0.21 %	0.00 %	0.28 %		-0.23		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

## P003\_樹林焚化廠CEMS系統日報表-A

報表日期: 113年04月24日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	1.96	5.59	48.59	0.36	17.58	10.47	0.99	78238.68
1	4.26	5.04	51.03	0.55	18.79	10.16	0.99	80724.56
2	0.92	5.41	47.18	0.27	17.71	10.26	0.97	78692.21
3	1.30	8.05	40.63	0.20	18.21	10.06	0.98	78708.38
4	3.34	5.35	46.88	0.26	18.90	10.29	0.99	77126.97
5	2.62	7.33	38.88	0.30	18.12	9.98	0.99	79724.51
6	3.69	5.27	45.59	0.30	18.04	10.50	0.99	75253.97
7	1.13	4.72	46.15	0.12	18.24	10.45	0.98	78781.20
8	1.35	5.19	48.34	0.19	18.33	10.62	0.97	76368.88
9	1.16	5.06	46.35	0.18	20.05	9.73	0.97	83747.67
10	1.32	8.19	59.47	0.17	18.70	11.52	1.07	72106.08
11	1.09	7.21	41.18	0.22	21.63	9.14	0.99	87605.22
12	1.12	4.51	41.21	0.19	19.43	9.91	0.99	83536.92
13	1.17	6.56	49.11	0.29	16.77	10.66	0.99	78604.95
14	1.16	8.03	52.07	0.59	15.84	10.74	0.99	79095.97
15	3.18	6.78	56.69	0.86	15.70	10.91	0.99	78086.00
16	2.25	5.64	52.64	0.70	16.17	10.93	0.99	77837.57
17	1.69	3.19	59.36	0.37	17.54	10.67	0.99	80562.11
18	2.94	5.71	47.68	0.53	18.34	10.01	0.99	85425.70
19	3.74	5.50	41.63	0.67	17.75	10.28	0.99	83361.88
20	7.62	3.58	44.18	0.92	16.72	10.58	1.00	81988.01
21	3.00	4.43	41.10	1.12	15.84	10.69	0.99	76610.79
22	5.23	2.22	44.12	1.02	15.66	10.93	0.99	73763.02
23	0.17	4.22	51.68	0.50	15.80	11.00	0.99	74881.18
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	2.39	5.53	47.57	0.45	17.74	10.44	0.99	79201.35
最大值	7.62	8.19	59.47	1.12	21.63	11.52	1.48	87605.22
發生時間	20	10	10	21	11	10		11
最小值	0.17	2.22	38.88	0.12	15.66	9.14	0.96	72106.08
發生時間	23	22	5	7	22	11		10
零點偏移(率)	-0.13 %	-0.00 %	-0.05 %	-0.00 %		-0.11		0.00 %
全幅偏移(率)	3.15 %	-0.19 %	-0.43 %	0.27 %		-0.14		0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								