

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 112年05月25日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	7.21	4.47	52.08	3.50	17.09	11.40	1.28	68861.89
1	5.58	2.27	59.48	2.98	18.14	11.28	1.28	68155.35
2	7.54	2.07	41.04	3.70	17.30	10.83	1.28	67255.97
3	5.30	2.58	52.92	3.25	16.54	11.31	1.28	67762.42
4	1.43	4.73	51.62	3.24	15.53	11.90	1.28	65447.97
5	2.79	5.54	49.34	4.13	14.67	11.99	1.29	61898.99
6	2.99	2.15	54.10	3.32	15.86	11.54	1.28	66941.49
7	5.82	4.71	63.92	3.86	15.56	11.97	1.28	65689.46
8	4.11	2.44	53.15	3.86	14.99	11.85	1.28	65322.99
9	8.93	2.79	57.15	5.48	14.46	11.69	1.28	64438.66
10	5.75	7.14	51.52	5.59	13.94	12.11	1.30	60652.77
11	5.97	1.64	56.82	3.53	16.75	11.17	1.33	68542.80
12	7.09	3.29	55.49	4.05	16.53	11.08	1.33	67770.04
13	5.75	5.08	44.80	4.22	14.65	11.50	1.28	63353.73
14	5.00	1.59	64.61	2.92	18.81	10.72	1.30	66801.17
15	3.44	1.61	55.09	2.50	19.20	10.59	1.33	71516.08
16	6.56	15.16	39.30	4.90	15.37	11.48	1.33	66112.89
17	1.97	6.23	44.03	4.11	15.45	11.71	1.33	63991.63
18	4.10	0.97	57.77	2.99	17.57	11.12	1.33	68863.19
19	9.83	2.26	56.65	3.59	16.42	11.22	1.30	67528.42
20	8.07	1.44	51.02	3.48	16.47	11.29	1.30	66933.65
21	6.87	2.36	50.89	3.59	15.86	11.29	1.32	66764.00
22	6.81	2.84	56.00	3.64	16.23	11.27	1.33	67509.61
23	7.74	2.44	64.78	3.09	18.51	10.83	1.33	72274.93
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	5.69	3.66	53.48	3.73	16.33	11.38	1.30	66682.92
最大值	9.83	15.16	64.78	5.59	19.20	12.11	1.34	72274.93
發生時間	19	16	23	10	15	10		23
最小值	1.43	0.97	39.30	2.50	13.94	10.59	1.26	60652.77
發生時間	4	18	16	15	10	15		10
零點偏移(率)	-0.03 %	-0.05 %	-0.02 %	-0.00 %		-0.01	0.00	0.00 %
全幅偏移(率)	-0.09 %	0.12 %	-0.32 %	0.23 %		0.02	-0.03	0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 112年05月25日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	6.28	2.63	45.58	1.42	21.37	9.00	1.45	84889.77
1	1.31	6.77	33.96	1.47	19.88	8.95	1.45	79045.62
2	3.51	5.96	38.14	1.97	18.95	9.39	1.46	76694.38
3	2.95	6.23	41.66	1.63	19.37	8.88	1.46	79835.54
4	0.68	2.23	59.54	1.34	19.54	8.68	1.46	80327.62
5	1.60	5.39	40.43	1.87	19.71	8.10	1.45	81415.77
6	5.48	2.74	41.25	2.30	19.81	8.25	1.44	80124.73
7	8.00	2.16	57.24	2.73	17.84	8.83	1.45	82380.76
8	8.65	1.82	50.61	2.78	16.70	9.68	1.45	82502.55
9	7.86	1.83	50.04	3.44	15.56	10.47	1.45	75202.55
10	5.98	1.33	52.24	3.23	15.28	10.18	1.46	77066.49
11	2.61	5.02	49.65	1.93	18.66	9.23	1.45	78510.35
12	9.00	2.42	45.31	3.05	17.31	9.43	1.42	78815.45
13	5.06	1.22	56.29	1.92	18.16	10.00	1.44	75571.68
14	5.38	2.35	50.14	1.85	18.73	9.47	1.44	84259.82
15	2.69	1.04	47.15	1.86	17.53	9.34	1.44	80866.81
16	6.10	1.05	55.69	2.62	17.76	9.60	1.43	81720.64
17	7.07	1.05	55.96	2.03	18.71	9.64	1.45	82013.56
18	1.24	1.19	50.18	1.64	18.02	9.80	1.45	81756.59
19	0.51	1.25	56.44	1.42	18.81	9.76	1.45	82392.79
20	1.17	1.23	47.83	1.82	17.59	10.24	1.43	79632.18
21	1.91	1.55	51.22	1.63	19.08	9.72	1.42	82253.91
22	2.73	2.03	51.02	1.86	17.79	10.05	1.41	83423.07
23	2.44	2.04	55.96	1.46	19.33	10.06	1.43	80804.72
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	4.18	2.61	49.31	2.05	18.40	9.45	1.44	80479.47
最大值	9.00	6.77	59.54	3.44	21.37	10.47	1.46	84889.77
發生時間	12	1	4	9	0	9		0
最小值	0.51	1.04	33.96	1.34	15.28	8.10	1.41	75202.55
發生時間	19	15	1	4	10	5		9
零點偏移(率)	-0.01 %	-0.02 %	-0.02 %	0.00 %		0.02	0.00	0.00 %
全幅偏移(率)	1.37 %	-0.06 %	-0.26 %	0.16 %		-0.19	-0.03	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 112年05月25日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	10.25	2.44	63.10	2.29	19.04	10.26	1.46	86579.25
1	8.83	5.34	48.32	3.65	19.95	9.32	1.44	87738.20
2	9.52	2.28	61.28	2.94	16.71	9.65	1.43	84166.64
3	3.53	2.22	54.89	2.13	16.14	11.01	1.43	81087.94
4	6.17	2.55	53.95	2.06	17.29	10.70	1.45	83038.54
5	5.34	2.24	63.66	2.09	19.43	9.52	1.45	87780.83
6	7.43	2.85	63.58	2.44	18.61	9.79	1.43	86516.00
7	4.70	1.75	54.69	2.50	18.75	9.55	1.43	86792.87
8	12.09	2.16	55.96	3.59	15.81	10.62	1.43	79806.96
9	11.49	3.53	52.16	4.26	16.50	9.59	1.43	86222.60
10	8.69	2.44	62.98	3.96	14.00	11.08	1.42	77523.89
11	3.45	3.81	58.99	2.42	16.53	10.99	1.42	78214.53
12	5.57	1.69	65.47	2.34	17.25	10.70	1.43	81335.71
13	6.22	2.66	52.28	2.22	17.18	10.59	1.43	80479.53
14	9.34	2.62	55.60	2.56	16.67	10.65	1.43	79462.08
15	7.17	4.39	54.39	2.38	17.57	10.20	1.43	82113.66
16	5.30	2.70	59.99	2.25	18.01	10.27	1.43	84590.70
17	6.50	3.32	51.79	2.23	16.16	11.03	1.43	80616.14
18	5.77	3.23	59.94	2.26	17.59	10.65	1.43	82768.74
19	7.32	3.04	58.03	2.34	17.37	10.74	1.43	85066.57
20	9.97	1.94	59.06	2.41	16.84	10.99	1.43	82290.28
21	7.13	2.39	59.82	2.40	16.46	11.14	1.43	79512.17
22	6.89	3.46	57.23	2.35	18.10	10.55	1.43	83831.19
23	8.06	3.23	57.90	2.46	18.15	10.67	1.43	82876.50
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	7.36	2.85	57.71	2.61	17.34	10.43	1.43	82933.81
最大值	12.09	5.34	65.47	4.26	19.95	11.14	1.48	87780.83
發生時間	8	1	12	9	1	21		5
最小值	3.45	1.69	48.32	2.06	14.00	9.32	1.41	77523.89
發生時間	11	12	1	4	10	1		10
零點偏移(率)	0.00 %	-0.04 %	-0.01 %	-0.01 %		0.00	0.00	0.00 %
全幅偏移(率)	0.70 %	0.11 %	-0.49 %	0.15 %		-0.16	0.02	0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								