

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 113年04月13日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	5.86	5.40	64.19	0.25	17.95	11.56	1.03	80743.19
1	2.06	5.57	55.64	0.61	19.36	11.76	1.04	77707.30
2	8.89	5.16	33.90	1.02	17.61	10.93	1.02	86640.68
3	7.50	4.65	47.47	1.00	17.33	11.12	1.02	85500.27
4	6.08	5.32	58.22	1.08	17.10	11.24	1.02	84462.92
5	4.32	5.48	68.60	0.62	17.46	11.67	1.03	80104.04
6	2.66	6.21	53.17	2.83	17.29	11.05	1.03	79175.82
7	4.60	4.82	62.04	1.33	16.00	11.38	1.02	80347.51
8	8.84	11.80	48.58	1.97	15.67	12.05	1.02	78470.95
9	8.24	2.01	39.19	1.87	15.96	12.01	1.02	78777.92
10	9.20	5.94	33.63	1.99	15.60	12.32	1.04	76699.00
11	9.33	5.97	39.79	1.77	15.93	11.89	1.03	79423.68
12	8.88	4.22	38.16	1.71	15.46	11.66	1.01	82229.13
13	8.72	6.87	48.61	2.73	14.74	11.87	1.02	80650.46
14	8.46	3.59	60.03	0.92	16.35	11.71	1.02	80949.46
15	10.34	5.86	54.02	1.72	16.04	11.46	1.02	82966.08
16	10.59	6.15	56.85	1.94	14.82	11.86	1.02	81121.98
17	7.12	5.66	64.90	0.94	15.90	12.06	1.02	78537.99
18	0.46	6.45	47.94	0.62	15.75	12.53	1.04	74419.73
19	0.25	6.80	62.82	0.50	16.34	12.69	1.06	72754.20
20	1.42	6.66	51.57	0.36	17.10	11.77	1.04	79824.88
21	1.44	6.08	47.46	0.39	18.01	11.15	1.03	84371.63
22	1.12	5.63	61.77	0.39	18.10	10.88	1.04	86428.87
23	4.42	5.78	48.29	0.42	18.13	10.81	1.04	86668.98
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	5.87	5.75	51.95	1.21	16.67	11.64	1.03	80790.69
最大值	10.59	11.80	68.60	2.83	19.36	12.69	1.08	86668.98
發生時間	16	8	5	6	1	19		23
最小值	0.25	2.01	33.63	0.25	14.74	10.81	0.99	72754.20
發生時間	19	9	10	0	13	23		19
零點偏移(率)	-0.01 %	0.00 %	-0.02 %	-0.01 %		-0.08		0.00 %
全幅偏移(率)	0.00 %	0.36 %	-0.62 %	0.51 %		-0.03		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 113年04月13日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	7.45	2.21	53.21	1.60	17.50	11.05	0.99	78825.01
1	1.00	2.15	46.99	2.19	17.74	11.56	0.99	74787.52
2	5.82	1.86	31.65	2.56	15.57	11.38	0.98	78458.28
3	9.47	2.67	35.88	3.10	15.21	11.52	0.98	78516.10
4	10.06	1.83	40.06	2.54	16.32	11.37	0.97	78627.49
5	7.42	6.17	60.23	1.78	17.23	11.44	0.98	76206.63
6	11.28	6.60	51.14	2.64	18.21	10.52	1.02	76233.12
7	8.70	6.44	52.46	3.90	15.60	11.83	1.03	74872.30
8	6.55	14.55	55.44	4.46	14.14	12.15	1.05	73216.05
9	8.15	1.98	41.92	2.99	16.78	11.25	1.06	78505.01
10	9.69	4.12	43.78	4.08	15.28	11.85	1.06	74565.16
11	8.45	3.17	41.12	2.96	16.33	11.34	1.06	77909.68
12	10.13	5.93	36.98	3.97	14.79	11.70	1.06	75445.41
13	4.87	2.69	66.72	0.91	16.83	11.66	1.06	74769.64
14	7.31	4.38	47.87	1.37	15.11	11.20	1.05	79469.45
15	5.60	3.27	63.66	0.72	18.11	11.12	1.06	78344.16
16	9.60	3.84	39.80	1.17	17.11	10.84	1.06	80962.00
17	7.08	1.79	53.05	1.08	16.29	11.70	1.06	74763.95
18	0.18	7.85	57.83	0.88	16.13	13.09	1.12	64243.63
19	1.97	2.68	33.93	0.80	19.19	10.08	1.05	85357.11
20	9.02	4.88	44.68	1.26	17.36	10.44	1.06	84035.14
21	9.47	1.67	49.12	1.25	16.53	11.06	1.06	79586.70
22	8.75	3.56	52.64	1.28	16.80	11.12	1.06	78878.89
23	9.48	4.17	43.62	1.40	18.18	10.38	1.06	83479.16
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	7.40	4.19	47.66	2.12	16.60	11.32	1.04	77502.40
最大值	11.28	14.55	66.72	4.46	19.19	13.09	1.26	85357.11
發生時間	6	8	13	8	19	18		19
最小值	0.18	1.67	31.65	0.72	14.14	10.08	0.97	64243.63
發生時間	18	21	2	15	8	19		18
零點偏移(率)	-0.13 %	0.00 %	-0.03 %	0.01 %		-0.03		-0.20 %
全幅偏移(率)	0.14 %	0.02 %	-0.17 %	0.26 %		-0.16		-0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 113年04月13日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	2.22	6.08	51.03	0.33	18.30	10.13	1.04	82323.03
1	1.25	7.20	47.79	0.61	17.55	10.56	1.05	80295.08
2	1.45	6.50	48.77	0.99	15.66	10.73	1.06	80743.53
3	3.40	6.59	53.04	1.04	16.19	10.82	1.05	79816.01
4	1.90	5.88	55.18	0.52	17.77	10.32	1.06	81440.21
5	1.99	6.38	63.55	0.34	17.86	10.95	1.06	76434.74
6	2.85	9.12	34.80	0.78	16.68	10.52	1.05	80789.67
7	3.93	12.35	72.30	0.53	16.18	10.88	1.04	74387.55
8	3.36	12.62	62.81	0.93	15.68	10.98	1.04	77714.76
9	5.00	13.27	43.63	0.87	15.28	11.33	1.03	73516.92
10	0.44	17.39	42.52	0.84	14.74	11.30	1.04	71094.00
11	2.79	15.21	42.83	0.60	15.57	10.98	1.04	73536.61
12	2.93	9.24	42.30	0.69	15.53	10.93	1.04	75071.15
13	4.32	6.15	45.91	0.37	17.78	10.47	1.04	79405.99
14	5.95	3.33	38.51	0.37	18.49	9.92	1.03	82763.23
15	2.50	5.67	58.37	0.17	18.43	11.14	1.05	74911.10
16	2.26	6.26	37.62	0.38	17.39	10.16	1.02	83637.23
17	2.52	2.88	49.96	0.48	16.81	11.39	1.01	74182.19
18	2.40	1.24	55.61	0.22	18.69	10.62	1.04	79060.83
19	2.19	1.84	38.73	0.26	18.20	9.80	1.04	85605.18
20	2.35	4.32	65.71	0.53	16.35	10.60	1.04	81223.75
21	3.66	5.08	66.30	0.35	17.18	10.41	1.04	81023.22
22	3.11	5.03	62.54	0.26	18.00	10.22	1.04	82064.99
23	3.85	4.96	51.93	0.26	18.92	9.84	1.04	84178.68
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	2.86	7.27	51.32	0.53	17.05	10.63	1.04	78967.49
最大值	5.95	17.39	72.30	1.04	18.92	11.39	1.07	85605.18
發生時間	14	10	7	3	23	17		19
最小值	0.44	1.24	34.80	0.17	14.74	9.80	1.00	71094.00
發生時間	10	18	6	15	10	19		10
零點偏移(率)	-0.02 %	-0.00 %	-0.10 %	-0.01 %		-0.06		0.10 %
全幅偏移(率)	0.02 %	0.24 %	-0.42 %	0.56 %		-0.08		0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								