

## P001\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年09月20日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	6.92	11.48	58.32	2.31	16.34	11.98	1.02	70208.35
1	5.69	11.31	61.16	1.77	18.12	11.68	1.02	70591.28
2	8.74	10.95	58.53	2.57	16.73	11.70	1.03	72399.86
3	7.45	13.42	65.45	2.16	16.64	12.36	1.04	67442.54
4	9.43	7.12	50.47	2.09	17.65	11.34	1.02	74264.21
5	1.19	12.26	54.53	0.86	17.52	12.06	0.99	72411.06
6	1.80	8.78	61.71	1.35	16.91	12.54	1.02	65727.10
7	6.32	10.70	54.17	2.37	16.40	11.69	0.99	72029.39
8	9.09	8.89	60.98	2.23	17.66	11.65	1.02	71740.25
9	11.03	6.17	48.40	3.61	16.02	11.55	1.05	72779.62
10	8.48	5.20	51.20	3.89	14.96	12.09	1.01	69381.91
11	2.80	7.46	54.90	1.51	17.25	11.59	1.03	72232.41
12	4.87	8.56	56.97	1.47	16.48	11.33	1.05	74390.51
13	8.72	7.40	50.14	2.86	15.60	11.55	1.04	72575.55
14	12.73	11.71	46.88	4.72	15.26	11.76	1.03	70238.98
15	12.75	7.29	52.80	7.63	16.26	11.87	1.00	68685.34
16	8.90	7.96	57.45	0.97	18.38	11.73	1.01	70290.41
17	9.91	6.12	39.06	0.98	19.01	10.98	1.01	76184.76
18	9.31	5.52	43.39	1.59	17.88	11.17	0.99	75625.04
19	9.30	5.35	48.13	1.41	18.50	10.98	1.00	76191.26
20	7.98	5.58	55.77	1.44	18.63	11.26	1.03	74128.96
21	9.59	5.27	50.83	1.29	19.78	10.52	1.04	78796.05
22	7.06	5.71	59.08	0.86	19.48	11.11	1.03	74552.60
23	8.14	5.45	38.76	1.44	18.20	11.10	0.99	75843.92
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	7.84	8.15	53.29	2.22	17.32	11.57	1.02	72446.31
最大值	12.75	13.42	65.45	7.63	19.78	12.54	1.12	78796.05
發生時間	15	3	3	15	21	6		21
最小值	1.19	5.20	38.76	0.86	14.96	10.52	0.99	65727.10
發生時間	5	10	23	5	10	21		6
零點偏移(率)	-0.01 %	-0.00 %	-0.06 %	0.00 %		0.02		0.00 %
全幅偏移(率)	0.04 %	0.14 %	-0.08 %	0.27 %		0.11		0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

## P002\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年09月20日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	6.59	7.13	51.61	3.14	16.91	10.77	0.97	83688.15
1	6.11	6.39	56.09	1.77	18.01	10.37	0.98	85439.34
2	7.70	6.91	53.64	1.96	17.79	10.52	0.98	84329.72
3	7.45	7.12	49.87	1.65	18.29	10.32	0.99	85319.86
4	6.20	6.81	52.52	1.50	18.25	10.22	0.99	86633.78
5	6.53	6.86	49.93	1.73	17.79	10.67	0.99	82972.85
6	5.95	7.22	44.98	2.39	16.42	10.46	1.02	87644.75
7	5.56	6.97	54.06	1.96	17.42	10.36	1.02	84372.65
8	3.46	6.09	51.08	1.16	19.08	10.06	1.01	85000.26
9	8.35	3.94	47.99	2.08	18.01	9.99	1.02	87177.91
10	2.89	2.44	45.07	1.47	17.40	10.38	1.01	83730.48
11	1.57	6.73	50.98	1.26	18.02	10.22	1.04	84495.72
12	9.82	6.67	55.63	2.25	17.23	10.27	1.03	86678.89
13	9.37	5.12	48.33	2.57	16.84	10.27	1.02	86519.63
14	9.67	7.40	57.91	2.93	15.43	10.96	1.02	81103.64
15	8.44	6.98	51.07	2.78	15.82	10.64	0.99	83355.08
16	9.51	5.68	47.17	1.96	17.09	10.04	1.02	88189.46
17	8.73	6.01	46.41	2.63	16.18	10.35	1.00	85332.14
18	8.67	3.28	58.08	1.26	18.79	9.99	1.00	85082.64
19	9.01	3.56	46.15	1.28	19.12	9.86	1.02	87191.05
20	3.01	3.69	49.50	0.88	18.89	10.46	1.01	80490.34
21	2.76	5.06	36.91	1.23	18.39	10.08	0.99	82609.71
22	9.04	4.96	49.86	1.20	19.17	9.47	1.00	89614.24
23	8.08	4.71	52.15	1.58	18.38	9.95	1.01	87032.16
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	6.85	5.74	50.29	1.86	17.70	10.28	1.00	85166.85
最大值	9.82	7.40	58.08	3.14	19.17	10.96	1.05	89614.24
發生時間	12	14	18	0	22	14		22
最小值	1.57	2.44	36.91	0.88	15.43	9.47	0.97	80490.34
發生時間	11	10	21	20	14	22		20
零點偏移(率)	-0.02 %	-0.00 %	-0.03 %	0.00 %		0.03		-0.20 %
全幅偏移(率)	-0.76 %	0.72 %	0.01 %	-0.07 %		-0.18		-0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

## P003\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年09月20日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	6.14	9.63	54.00	1.30	16.73	11.24	1.00	80971.43
1	5.52	10.20	58.88	1.35	17.16	11.76	1.02	76586.81
2	8.61	10.59	54.04	1.72	15.89	11.26	1.00	80084.41
3	8.18	9.52	58.07	1.56	15.90	11.70	1.00	76530.48
4	8.17	9.55	53.60	1.64	16.09	11.06	1.00	82509.05
5	6.54	8.43	55.91	1.94	15.81	10.98	1.01	81652.46
6	4.79	8.41	54.32	1.63	15.71	11.00	1.00	80897.05
7	6.29	9.60	51.99	2.31	14.68	11.27	1.01	76735.68
8	5.37	8.58	54.90	1.55	16.76	10.80	1.04	80392.98
9	3.93	8.05	49.85	1.28	17.45	10.23	1.02	78956.17
10	4.00	8.95	44.05	1.78	15.17	10.73	1.03	75188.63
11	8.14	4.03	48.28	2.04	15.35	10.76	1.04	75759.85
12	7.29	3.09	48.54	1.57	16.46	10.57	1.02	77089.31
13	7.25	6.04	48.63	1.44	17.10	10.17	1.01	79264.37
14	9.63	6.64	50.91	2.55	16.80	9.40	1.04	82915.34
15	9.33	5.14	51.93	2.92	14.50	10.03	1.02	78921.91
16	8.81	6.73	59.84	3.28	13.52	10.63	1.01	75202.05
17	4.16	15.19	47.59	3.08	12.29	11.29	0.99	69740.70
18	4.93	8.29	45.08	2.25	14.14	11.44	0.99	73422.75
19	6.29	4.15	58.53	1.42	17.31	10.23	1.03	80659.29
20	9.70	3.22	50.73	1.58	16.71	10.28	1.05	81152.81
21	7.56	3.84	55.37	1.42	16.80	10.65	1.03	77898.56
22	7.36	4.42	38.96	1.52	16.97	10.35	1.03	78194.62
23	7.08	5.66	40.11	1.65	16.22	10.58	0.99	76891.79
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	6.88	7.41	51.42	1.87	15.90	10.77	1.02	78234.10
最大值	9.70	15.19	59.84	3.28	17.45	11.76	1.10	82915.34
發生時間	20	17	16	16	9	1		14
最小值	3.93	3.09	38.96	1.28	12.29	9.40	0.99	69740.70
發生時間	9	12	22	9	17	14		17
零點偏移(率)	-0.01 %	0.00 %	-0.22 %	-0.05 %		0.00		-0.10 %
全幅偏移(率)	0.04 %	1.07 %	-0.42 %	0.20 %		0.42		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								