

P002 樹林焚化廠CEMS系統日報表-A

報表日期: 114年12月07日

項目 單位 小時\限標	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	11.57	14.05	41.26	3.35	17.62	10.04	1.02	79752.77
1	7.45	13.03	38.91	3.05	18.70	9.70	1.02	78514.00
2	10.42	12.40	40.77	3.66	19.34	9.04	1.02	78101.61
3	13.00	12.19	48.61	2.32	18.55	9.33	1.02	79592.17
4	10.82	13.86	46.13	2.22	16.86	9.60	1.02	78710.34
5	9.40	13.66	48.99	2.09	16.26	10.00	1.02	78618.83
6	7.20	12.02	46.32	3.03	16.10	9.92	1.03	78043.58
7	11.58	12.52	54.29	3.74	14.92	10.47	1.04	78504.89
8	8.87	11.43	47.09	1.83	15.72	9.87	1.04	78210.37
9	15.30	11.65	36.47	2.20	16.40	9.62	1.03	77386.30
10	10.86	12.13	49.26	1.92	16.24	9.80	1.02	79543.33
11	11.29	11.78	32.80	2.44	17.17	10.12	1.02	79423.86
12	12.37	10.94	47.13	3.51	19.09	9.21	1.02	79847.11
13	7.64	12.41	37.05	3.96	18.65	9.30	1.02	80022.94
14	9.90	12.22	29.57	4.95	17.85	9.22	1.02	78608.95
15	10.05	12.17	46.94	2.56	16.49	10.06	1.02	78405.09
16	10.94	11.55	42.36	2.61	16.91	9.73	1.02	80213.95
17	8.27	11.22	60.47	2.37	15.97	10.26	1.02	79575.56
18	10.67	13.33	57.79	4.48	16.22	10.31	1.02	81207.68
19	13.54	13.11	49.76	5.02	17.16	9.85	1.02	81083.69
20	9.35	13.23	40.99	2.48	17.02	9.91	1.02	80574.46
21	8.32	13.52	61.84	2.17	16.48	10.20	1.02	81191.07
22	7.35	13.28	62.34	1.76	17.52	9.96	1.04	84182.57
23	7.38	13.45	61.49	1.71	16.22	10.28	1.04	80907.04
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	10.15	12.55	47.03	2.89	17.06	9.82	1.02	79592.59
最 大 值	15.30	14.05	62.34	5.02	19.34	10.47	1.06	84182.57
發生時間	9	0	22	19	2	7		22
最 小 值	7.20	10.94	29.57	1.71	14.92	9.04	1.01	77386.30
發生時間	6	12	14	23	7	2		9
零點偏移(率)	0.23 %	-0.06 %	-0.03 %	0.00 %		0.01	-0.01	0.00 %
全幅偏移(率)	-0.07 %	0.20 %	-0.60 %	0.05 %		-0.15	0.00	0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A

報表日期: 114年12月07日

項目 單位 小時\限標	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.90	12.66	45.03	1.57	18.74	9.59	1.35	74339.77
1	12.07	12.62	40.83	1.75	20.69	9.26	1.34	74709.24
2	12.07	12.02	43.45	2.23	19.52	9.28	1.34	73105.26
3	12.27	12.23	41.06	2.75	18.23	9.47	1.34	72328.63
4	10.81	12.50	43.95	1.91	17.68	9.65	1.35	72523.98
5	11.13	12.57	41.14	2.08	17.31	9.39	1.34	70930.04
6	12.00	12.77	42.06	2.49	17.37	9.60	1.34	71256.25
7	8.58	12.02	33.76	1.59	17.74	9.15	1.36	79554.70
8	11.45	11.08	53.01	1.81	15.61	9.83	1.36	69835.45
9	10.72	12.62	42.75	2.05	16.84	9.53	1.36	71508.78
10	10.05	11.58	36.95	2.53	17.37	8.93	1.36	72087.08
11	2.12	11.14	41.07	0.51	17.98	8.98	1.34	72449.05
12	0.96	12.17	46.35	0.65	19.49	9.15	1.33	73134.83
13	3.13	14.13	42.55	2.51	19.74	9.20	1.35	76394.94
14	7.63	14.50	45.38	1.30	16.97	10.37	1.37	73580.00
15	12.83	15.14	45.41	2.04	17.25	10.15	1.37	73933.60
16	10.52	14.85	38.07	3.23	17.44	9.38	1.36	71086.03
17	14.11	15.13	37.03	4.62	18.09	8.78	1.35	73584.40
18	5.40	14.19	49.42	2.26	16.13	9.82	1.34	69537.41
19	13.75	13.57	48.66	4.00	18.08	9.25	1.36	70727.81
20	11.12	13.50	40.77	2.75	19.11	9.03	1.36	72130.68
21	11.91	13.51	44.80	2.41	20.19	8.86	1.36	73586.53
22	12.60	13.43	43.24	2.76	18.76	9.03	1.36	75878.60
23	12.87	13.89	42.21	1.96	17.29	9.62	1.36	72436.55
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	10.00	13.08	42.87	2.24	18.07	9.39	1.35	72943.32
最 大 值	14.11	15.14	53.01	4.62	20.69	10.37	1.39	79554.70
發生時間	17	15	8	17	1	14		7
最 小 值	0.96	11.08	33.76	0.51	15.61	8.78	1.32	69537.41
發生時間	12	8	7	11	8	17		18
零點偏移(率)	-0.09 %	-0.01 %	-0.03 %	-0.01 %		-0.34	-0.01	0.20 %
全幅偏移(率)	0.65 %	0.06 %	-0.17 %	0.03 %		-0.06	0.04	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								