

P001 樹林焚化廠CEMS系統日報表-A

報表日期: 113年07月06日

項目 單位 小時\限標	#1-HCl_C ppm	#1-CO_C ppm	#1-NOx_C ppm	#1-SO2_C ppm	#1-H2O %	#1-O2_C %	#1-OPAC %	#1-FLOW_C m3/Hour
0	9.78	3.63	53.40	2.32	18.78	11.43	0.99	81088.33
1	9.77	3.66	48.25	3.32	18.25	11.59	0.98	80368.60
2	8.69	3.80	47.71	2.63	18.22	11.60	0.99	80542.01
3	9.05	4.30	41.84	3.42	16.77	11.63	1.01	81534.20
4	8.36	6.77	52.17	2.05	18.16	11.67	1.02	79569.96
5	8.09	4.84	46.28	1.75	18.98	11.40	1.02	79673.39
6	9.06	4.84	49.26	2.68	19.21	11.30	1.02	81679.07
7	11.94	5.37	45.38	3.67	17.29	11.69	1.03	80434.74
8	7.98	4.86	46.93	2.22	18.49	11.58	1.02	80343.04
9	10.52	7.01	41.35	3.56	17.18	11.65	1.02	80834.98
10	5.15	6.06	44.88	2.64	18.74	11.55	1.03	79854.28
11	5.29	3.74	42.25	2.66	19.02	11.10	1.02	83528.81
12	4.88	3.10	45.12	2.88	17.88	11.66	1.02	80225.00
13	6.80	2.90	51.44	1.69	19.19	11.51	1.02	80216.41
14	6.68	2.91	49.43	1.49	19.22	11.46	1.02	80307.92
15	5.30	3.11	54.27	1.43	19.05	11.76	1.03	77772.00
16	5.38	5.65	40.95	2.64	16.91	11.68	1.01	80468.95
17	4.91	4.12	44.84	2.21	17.43	11.94	1.02	76247.09
18	4.66	2.90	48.02	1.31	19.22	11.37	1.03	81391.00
19	7.74	2.89	44.56	2.16	18.33	11.36	1.03	81930.85
20	6.37	3.00	38.57	3.06	16.34	11.78	1.02	80258.38
21	7.29	2.78	45.75	1.83	18.56	11.44	1.02	81230.94
22	8.84	4.46	57.88	2.07	18.07	11.48	1.03	81350.34
23	9.10	4.82	63.21	1.65	17.83	11.76	1.02	79111.57
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	7.57	4.23	47.66	2.39	18.21	11.56	1.02	80415.08
最 大 值	11.94	7.01	63.21	3.67	19.22	11.94	1.04	83528.81
發生時間	7	9	23	7	14	17		11
最 小 值	4.66	2.78	38.57	1.31	16.34	11.10	0.97	76247.09
發生時間	18	21	20	18	20	11		17
零點偏移(率)	-0.05 %	0.00 %	-0.06 %	-0.01 %		-0.06		0.00 %
全幅偏移(率)	0.00 %	0.65 %	0.04 %	0.31 %		-0.05		0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A 報表日期: 113年07月06日

報表日期: 113年07月06日

項目 單位 小時\限標	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	5.57	3.95	62.45	1.60	16.64	10.88	0.99	79314.24
1	1.42	4.34	64.80	1.33	17.83	11.11	0.98	76664.22
2	2.65	4.57	58.04	2.32	15.31	11.31	0.96	77500.85
3	1.26	3.76	59.79	1.44	17.04	10.89	0.93	78659.92
4	2.89	3.95	61.28	1.53	16.98	11.01	0.92	77854.87
5	1.29	6.75	59.55	1.61	16.49	10.86	0.93	79628.26
6	3.11	8.67	69.79	1.80	16.53	11.07	0.95	78164.43
7	0.74	7.47	63.82	1.72	16.87	11.04	0.97	77097.19
8	0.47	4.10	54.13	1.49	16.92	10.91	0.96	78001.06
9	4.57	4.20	57.63	1.45	17.40	10.74	0.96	79420.51
10	1.57	4.46	54.19	1.50	17.52	10.55	0.99	80910.65
11	6.09	5.14	58.73	1.99	15.79	11.18	0.95	77643.79
12	2.79	3.77	57.81	1.33	18.43	10.49	0.93	80539.25
13	1.41	3.85	59.26	1.37	17.40	10.70	0.92	79677.93
14	2.92	4.35	60.18	1.47	17.68	10.68	0.93	79701.69
15	1.29	3.96	63.36	1.26	17.75	10.98	0.96	75752.33
16	1.57	4.16	57.66	1.32	17.46	10.66	0.93	79277.61
17	1.21	4.44	54.93	1.45	16.66	10.90	0.99	78497.49
18	1.53	4.39	60.33	1.38	17.25	10.86	0.98	77366.55
19	1.16	4.88	51.93	1.34	16.85	10.46	0.93	79098.52
20	1.67	7.40	43.02	1.79	14.93	10.67	0.92	72035.01
21	1.19	4.10	53.44	1.40	16.32	10.80	0.92	75988.23
22	1.29	4.10	56.34	1.55	16.19	11.08	0.94	77078.88
23	1.19	3.83	58.10	1.29	17.64	10.60	0.98	77317.06
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	2.12	4.77	58.36	1.53	16.91	10.85	0.95	78049.61
最 大 值	6.09	8.67	69.79	2.32	18.43	11.31	0.99	80910.65
發生時間	11	6	6	2	12	2		10
最 小 值	0.47	3.76	43.02	1.26	14.93	10.46	0.91	72035.01
發生時間	8	3	20	15	20	19		20
零點偏移(率)	-0.10 %	0.00 %	-0.21 %	-0.04 %		-0.02		0.00 %
全幅偏移(率)	-0.11 %	0.26 %	-0.57 %	0.04 %		0.42		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								