

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 112年09月27日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	7.00	8.54	48.65	0.93	18.58	11.39	0.98	73415.23
1	3.88	7.89	58.93	0.83	19.51	11.40	0.99	73327.30
2	7.31	8.81	46.26	1.33	18.06	11.12	0.99	75961.02
3	6.19	7.37	52.25	1.44	16.14	11.84	0.99	72505.46
4	3.48	8.34	50.12	2.63	14.81	11.90	0.99	71935.45
5	3.59	7.43	53.82	1.52	16.40	12.00	0.99	70355.98
6	2.86	6.54	64.74	0.83	17.59	11.74	0.99	72054.87
7	5.38	7.18	48.97	1.29	16.87	11.75	1.00	72305.15
8	6.44	6.39	54.47	1.31	16.72	12.21	1.02	69212.96
9	1.95	6.40	60.48	0.99	16.94	12.21	1.00	69203.15
10	1.06	6.32	46.59	1.64	15.57	12.24	1.02	69615.99
11	1.73	8.37	53.05	1.35	16.05	12.09	1.03	70634.93
12	3.37	6.29	39.00	1.43	16.35	11.69	1.00	73208.09
13	4.35	5.38	39.81	1.19	17.89	11.23	1.02	74812.29
14	5.79	6.29	40.49	1.83	16.11	11.88	1.02	71784.57
15	2.83	5.38	62.16	0.68	17.97	11.75	1.05	71308.97
16	6.79	6.46	46.92	1.22	16.46	11.77	1.02	72058.72
17	8.20	10.20	39.95	1.70	17.46	11.59	1.00	72816.13
18	7.27	9.62	52.72	0.59	19.23	11.13	1.03	75410.77
19	7.48	9.81	42.21	1.31	16.61	11.67	1.04	73282.89
20	7.24	10.66	38.06	1.41	17.86	11.40	1.02	73893.41
21	7.27	6.42	34.89	1.77	16.17	11.70	1.02	72031.43
22	8.14	9.43	41.52	1.38	17.13	11.40	1.01	74595.81
23	8.87	10.07	47.02	1.22	17.25	11.30	1.00	74706.95
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	5.35	7.73	48.46	1.33	17.07	11.68	1.01	72518.23
最大值	8.87	10.66	64.74	2.63	19.51	12.24	1.06	75961.02
發生時間	23	20	6	4	1	10		2
最小值	1.06	5.38	34.89	0.59	14.81	11.12	0.97	69203.15
發生時間	10	13	21	18	4	2		9
零點偏移(率)	-0.02 %	0.00 %	-0.01 %	-0.00 %		-0.03		0.00 %
全幅偏移(率)	0.00 %	0.26 %	-0.15 %	-0.04 %		0.06		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 112年09月27日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	3.78	6.66	44.73	1.11	19.23	10.17	1.01	84688.15
1	1.45	6.57	40.39	1.55	19.10	10.00	1.02	85918.31
2	4.30	6.42	49.89	2.32	17.11	10.29	1.03	86266.26
3	4.93	2.28	51.69	2.67	15.11	10.64	1.02	83707.27
4	7.31	4.72	52.80	1.68	17.44	10.28	1.02	85816.53
5	8.41	10.19	49.77	2.51	16.55	10.33	1.02	86137.84
6	9.09	6.98	55.54	2.16	15.95	10.39	1.02	96402.87
7	9.55	9.95	50.82	2.71	16.33	10.37	1.02	86419.23
8	6.53	6.23	46.77	1.43	17.84	10.15	1.02	85636.83
9	2.09	2.83	44.90	1.98	17.37	10.37	1.02	85576.62
10	4.39	2.63	45.92	2.19	16.85	10.45	1.00	85212.21
11	1.42	5.59	49.24	1.62	16.93	10.63	1.02	83856.92
12	1.53	5.07	52.53	1.17	18.11	10.62	1.02	82141.06
13	5.92	8.34	43.79	1.75	17.77	10.05	1.03	87157.96
14	6.04	4.49	56.64	1.61	17.22	10.73	1.03	82476.14
15	7.25	7.31	43.75	2.14	17.28	10.46	1.02	83718.71
16	3.97	6.92	52.09	1.15	17.86	10.46	1.02	82352.37
17	7.13	8.56	46.00	1.60	17.34	10.00	0.99	87145.01
18	6.36	7.13	58.79	1.37	17.04	10.27	1.01	86101.50
19	7.90	7.34	52.22	1.84	16.78	10.08	0.99	88126.03
20	6.61	2.81	59.63	1.48	16.93	10.22	0.99	86304.29
21	8.51	4.60	56.97	1.86	16.22	10.51	0.99	84838.68
22	8.23	5.69	58.53	0.92	18.43	9.65	1.00	89424.27
23	7.16	8.24	62.62	0.83	17.83	10.03	1.01	86520.33
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	5.83	6.15	51.08	1.74	17.28	10.30	1.01	85914.39
最大值	9.55	10.19	62.62	2.71	19.23	10.73	1.04	96402.87
發生時間	7	5	23	7	0	14		6
最小值	1.42	2.28	40.39	0.83	15.11	9.65	0.99	82141.06
發生時間	11	3	1	23	3	22		12
零點偏移(率)	-0.04 %	0.00 %	-0.02 %	-0.01 %		0.01		-0.20 %
全幅偏移(率)	0.04 %	-0.06 %	0.09 %	0.07 %		0.03		-0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 112年09月27日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	5.65	6.10	46.09	1.26	17.08	10.27	0.91	78992.10
1	2.21	2.71	40.31	0.92	17.85	10.50	0.91	76008.01
2	4.04	5.00	43.95	1.18	17.37	10.07	0.91	80339.65
3	3.35	8.28	40.11	1.07	16.24	10.55	0.94	80929.02
4	5.35	3.12	42.65	1.58	16.07	10.43	0.91	77765.56
5	7.39	7.62	42.49	1.79	16.27	10.33	0.92	78913.98
6	5.74	6.30	40.52	1.52	16.00	10.46	0.91	78522.49
7	8.56	7.81	40.89	1.34	17.37	10.50	0.94	81323.48
8	3.04	1.62	42.53	1.03	16.40	10.71	0.94	78252.65
9	4.21	7.14	38.36	1.24	17.48	10.14	0.93	81213.44
10	4.21	6.88	35.54	1.00	17.52	10.14	0.96	80800.67
11	2.64	3.83	43.58	0.93	17.61	10.35	0.96	78779.82
12	2.76	6.24	40.45	1.12	16.37	10.73	0.93	76443.88
13	2.52	4.82	47.22	0.89	18.86	9.97	0.97	82411.66
14	6.19	12.46	35.16	1.45	17.64	9.65	0.97	81453.94
15	1.64	1.85	44.69	1.35	15.58	11.35	0.97	67569.24
16	4.08	5.65	33.84	0.89	17.62	9.90	0.95	79294.78
17	7.01	4.32	38.05	1.17	16.90	10.30	0.92	79262.11
18	8.18	6.56	40.03	1.15	16.82	10.46	1.06	79591.03
19	8.43	7.12	46.44	1.62	16.52	10.17	0.99	80311.28
20	8.51	2.14	45.48	1.51	16.57	9.95	0.97	79858.31
21	7.49	6.34	48.36	1.39	15.89	10.14	0.94	77564.78
22	5.78	7.06	42.71	1.22	16.48	9.87	0.91	77208.19
23	3.53	6.49	37.72	0.75	17.11	9.69	0.91	72320.89
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	5.10	5.73	41.55	1.22	16.90	10.28	0.94	78547.12
最大值	8.56	12.46	48.36	1.79	18.86	11.35	1.23	82411.66
發生時間	7	14	21	5	13	15		13
最小值	1.64	1.62	33.84	0.75	15.58	9.65	0.90	67569.24
發生時間	15	8	16	23	15	14		15
零點偏移(率)	-0.01 %	-0.00 %	-0.03 %	-0.01 %		0.00		0.00 %
全幅偏移(率)	0.45 %	-1.02 %	-0.90 %	0.22 %		0.39		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								