

P001 樹林焚化廠CEMS系統日報表-A 報表日期: 114年01月08日

報表日期: 114年01月08日

[illegible]

P002 樹林焚化廠CEMS系統日報表-A

報表日期: 114年01月08日

項目 單位 小時\限標	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	6.45	3.27	41.01	2.10	15.38	10.68	1.09	80432.43
1	4.63	1.45	56.65	2.35	15.97	11.11	1.10	82372.83
2	7.48	1.53	60.90	3.40	13.29	11.65	1.10	79991.33
3	7.93	1.27	63.08	3.22	13.65	11.54	1.09	81159.22
4	7.01	1.24	54.77	2.32	14.97	11.30	1.09	81895.27
5	9.61	1.64	58.62	3.18	14.85	11.29	1.09	83072.72
6	9.03	2.12	52.07	2.21	12.84	11.53	1.09	81429.07
7	10.49	1.88	53.26	1.94	12.56	11.61	1.09	77852.68
8	9.67	1.42	55.06	1.72	12.50	11.68	1.09	79055.50
9	6.37	4.84	44.40	3.34	12.42	11.96	1.08	76287.73
10	10.44	7.59	45.82	2.65	12.39	11.35	1.06	76268.83
11	8.59	3.29	60.86	1.52	13.07	11.19	1.08	79470.36
12	10.01	1.94	64.73	1.69	12.62	11.37	1.10	79119.42
13	10.91	2.86	64.60	1.81	11.92	11.57	1.10	76829.21
14	8.51	8.07	57.87	1.69	11.68	11.91	1.10	76086.64
15	8.71	0.71	53.10	1.37	12.93	11.70	1.12	81133.96
16	8.01	2.78	41.53	1.19	13.62	11.35	1.13	78826.59
17	8.38	3.03	32.30	1.11	14.91	10.75	1.11	79533.68
18	10.58	5.71	43.76	2.21	12.48	11.15	1.10	81865.78
19	5.74	5.92	48.16	1.03	14.95	11.60	1.10	79192.13
20	6.86	1.03	39.88	2.24	14.31	11.36	1.10	83970.42
21	8.77	6.66	37.71	3.25	12.91	11.53	1.10	81658.79
22	9.84	5.39	39.89	3.92	11.80	11.78	1.10	77350.20
23	8.78	2.76	36.30	2.97	12.38	11.56	1.10	76915.09
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	8.45	3.27	50.26	2.27	13.35	11.44	1.10	79657.08
最 大 值	10.91	8.07	64.73	3.92	15.97	11.96	1.13	83970.42
發生時間	13	14	12	22	1	9		20
最 小 值	4.63	0.71	32.30	1.03	11.68	10.68	1.06	76086.64
發生時間	1	15	17	19	14	0		14
零點偏移(率)	-0.07 %	-0.00 %	-0.04 %	0.00 %		-0.01		0.00 %
全幅偏移(率)	0.14 %	0.18 %	0.05 %	0.19 %		-0.22		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

報表日期: 114年01月08日

項目 單位 小時\限標	#3-HCl_C ppm	#3-CO_C ppm	#3-NOx_C ppm	#3-SO2_C ppm	#3-H2O %	#3-O2_C %	#3-OPAC %	#3-FLOW_C m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	7.21	2.53	51.23	2.61	16.40	10.18	1.49	75072.49
1	4.74	4.04	56.41	2.90	18.34	9.89	1.49	78520.26
2	9.01	4.36	49.19	2.71	15.07	10.31	1.49	76029.62
3	8.02	2.14	59.11	3.07	15.73	10.15	1.50	79794.98
4	10.41	2.15	53.06	3.01	15.61	10.13	1.49	78920.33
5	5.99	1.87	58.86	2.25	15.45	10.40	1.50	77335.94
6	9.79	2.69	59.85	3.43	15.39	10.30	1.50	78052.84
7	8.74	3.31	47.81	1.82	15.67	9.91	1.50	75230.64
8	10.97	6.93	48.64	2.34	14.26	10.32	1.50	76536.91
9	8.59	8.01	51.80	2.94	14.32	10.55	1.49	75683.76
10	8.33	4.33	51.07	2.62	13.91	10.65	1.48	73607.93
11	7.57	7.15	59.16	2.04	14.46	10.38	1.51	78241.68
12	7.10	4.49	59.39	2.18	14.04	10.46	1.51	75781.49
13	10.22	4.90	55.38	2.20	13.49	10.76	1.52	72037.53
14	6.70	5.64	53.67	2.45	12.45	11.06	1.52	71728.13
15	8.34	3.05	55.11	1.46	14.13	10.72	1.52	74356.09
16	6.03	1.13	59.60	1.38	14.53	10.62	1.52	78930.43
17	10.02	1.07	63.28	1.57	15.27	10.34	1.52	82668.29
18	8.11	2.25	58.20	1.58	15.27	10.59	1.51	82384.78
19	5.70	2.76	51.55	1.26	14.64	11.04	1.52	79862.37
20	7.67	6.27	48.06	2.35	16.18	10.83	1.52	81062.66
21	8.38	9.57	37.03	4.05	14.97	10.04	1.52	80011.17
22	12.14	3.41	39.35	3.26	13.92	10.64	1.52	76625.68
23	7.70	1.49	43.14	1.93	12.73	11.12	1.52	73581.59
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	8.23	3.98	52.91	2.39	14.84	10.47	1.51	77169.07
最 大 值	12.14	9.57	63.28	4.05	18.34	11.12	1.54	82668.29
發生時間	22	21	17	21	1	23		17
最 小 值	4.74	1.07	37.03	1.26	12.45	9.89	1.48	71728.13
發生時間	1	17	21	19	14	1		14
零點偏移(率)	-0.21 %	0.01 %	-0.03 %	-0.03 %		-0.01		0.20 %
全幅偏移(率)	-0.09 %	0.13 %	-0.07 %	0.17 %		-0.06		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								