

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 112年11月21日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.45	7.43	44.09	1.29	19.61	10.67	1.05	78116.06
1	9.15	4.24	54.68	1.79	18.66	11.25	1.05	75262.85
2	6.53	6.61	40.93	1.29	17.97	11.42	1.05	73913.59
3	7.78	3.78	49.69	1.73	18.06	11.56	1.05	72888.12
4	8.51	6.36	52.40	1.30	19.20	10.74	1.05	78116.94
5	8.48	7.84	56.36	1.60	17.70	11.55	1.06	72761.45
6	7.59	5.81	52.74	1.83	17.20	11.64	1.07	72281.26
7	8.77	5.42	54.25	1.68	16.83	11.75	1.06	72366.96
8	6.92	7.08	64.35	0.87	18.32	11.54	1.07	72357.52
9	5.27	7.69	58.42	0.66	19.49	10.78	1.07	77462.51
10	7.81	7.91	46.47	1.32	17.43	11.48	1.06	73952.69
11	8.03	8.12	47.28	1.61	16.79	11.81	1.08	71742.30
12	6.55	9.69	54.69	1.25	16.46	12.22	1.08	69585.66
13	6.82	7.35	46.44	1.31	17.29	11.49	1.07	74150.62
14	8.45	7.63	50.07	1.46	17.21	11.75	1.07	72469.97
15	5.54	8.17	50.96	1.15	17.48	11.59	1.08	73560.54
16	5.13	7.65	52.59	1.14	17.67	11.38	1.10	74975.66
17	8.24	7.95	54.41	1.30	17.63	11.60	1.07	73267.62
18	9.87	8.27	52.67	1.28	18.16	11.31	1.05	75041.81
19	3.55	11.32	68.37	1.15	17.43	12.00	1.12	70464.94
20	0.12	6.26	49.52	0.88	17.63	11.57	1.24	73886.81
21	6.35	5.74	48.92	0.63	20.85	10.31	1.07	80504.47
22	9.42	7.10	44.49	2.02	17.86	11.04	1.05	77014.85
23	10.62	6.64	43.12	1.72	17.78	11.31	1.05	74995.28
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	7.29	7.17	51.58	1.34	17.95	11.41	1.07	74214.19
最大值	10.62	11.32	68.37	2.02	20.85	12.22	1.52	80504.47
發生時間	23	19	19	22	21	12		21
最小值	0.12	3.78	40.93	0.63	16.46	10.31	1.04	69585.66
發生時間	20	3	2	21	12	21		12
零點偏移(率)	-0.01 %	0.00 %	-0.01 %	-0.01 %		-0.02		0.00 %
全幅偏移(率)	0.01 %	-0.37 %	-0.07 %	0.09 %		-0.04		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 112年11月21日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.06	3.78	50.48	2.03	16.86	10.41	0.99	84292.69
1	3.24	3.86	62.31	2.30	16.98	11.09	0.99	78822.47
2	2.23	5.04	33.56	0.95	19.18	9.84	0.99	86441.97
3	3.09	3.53	47.15	1.97	18.37	9.88	0.99	86902.80
4	2.26	3.23	60.60	1.98	17.60	10.00	1.01	86604.61
5	1.67	3.47	58.53	1.98	17.32	10.11	1.02	86030.23
6	2.15	9.61	47.25	0.87	19.53	9.22	1.04	92887.15
7	5.40	1.80	48.45	2.60	16.74	10.15	1.05	86124.18
8	6.80	3.57	51.48	2.67	16.77	10.36	1.05	83997.24
9	6.77	3.21	54.49	2.58	17.04	10.18	1.01	85906.11
10	8.29	5.49	50.91	3.22	16.10	10.19	1.03	86914.41
11	6.92	3.80	54.66	3.03	15.47	10.50	1.02	84552.54
12	4.43	3.11	57.67	2.53	15.57	10.60	1.00	83849.41
13	7.53	5.08	56.65	3.04	15.16	10.78	0.99	82678.55
14	9.74	3.89	56.79	3.01	16.84	10.17	0.99	85835.20
15	5.52	4.67	55.70	2.86	16.03	10.58	1.00	83032.25
16	9.90	5.29	63.04	2.65	15.81	10.44	1.02	84528.92
17	8.78	2.69	55.94	2.28	16.37	10.28	1.01	84937.93
18	6.79	5.86	54.13	2.14	16.73	10.34	0.99	85151.14
19	7.07	5.92	46.50	2.19	18.05	9.71	0.99	88396.07
20	9.24	3.98	39.73	2.49	17.74	9.43	0.99	90590.53
21	8.44	2.56	49.67	1.89	18.09	9.92	0.99	86139.02
22	8.90	5.78	52.30	1.96	17.84	10.10	0.99	85847.10
23	8.93	5.54	49.99	1.86	18.17	10.12	0.99	85124.95
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	6.34	4.37	52.42	2.29	17.10	10.18	1.01	85649.48
最大值	9.90	9.61	63.04	3.22	19.53	11.09	1.05	92887.15
發生時間	16	6	16	10	6	1		6
最小值	1.67	1.80	33.56	0.87	15.16	9.22	0.98	78822.47
發生時間	5	7	2	6	13	6		1
零點偏移(率)	-0.06 %	-0.01 %	-0.04 %	0.00 %		0.03		-0.10 %
全幅偏移(率)	0.02 %	0.12 %	-0.79 %	0.06 %		-0.11		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 112年11月21日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.45	6.56	51.20	1.65	15.22	11.11	1.01	78840.61
1	3.00	4.82	40.39	0.97	17.95	10.89	1.02	74890.81
2	4.81	6.09	50.57	1.31	16.25	11.21	1.02	74639.01
3	4.44	5.16	54.17	1.45	16.02	11.09	1.02	79393.59
4	4.53	5.71	58.97	1.78	15.23	11.56	1.03	77144.31
5	4.60	5.09	49.98	1.60	15.51	11.12	1.02	81453.62
6	2.09	11.05	52.58	1.79	15.08	11.27	1.01	76522.12
7	10.74	6.18	50.04	2.42	14.61	11.10	1.02	73488.83
8	8.49	5.03	52.88	2.15	15.79	10.99	1.02	79861.78
9	8.98	4.96	54.49	2.05	15.19	11.17	1.02	80470.32
10	6.95	5.55	54.13	1.87	14.78	11.27	1.02	79196.21
11	6.72	9.19	55.24	2.17	14.03	11.34	1.00	77595.25
12	7.56	7.35	54.50	1.94	14.87	11.16	1.01	76968.20
13	6.28	6.15	54.15	2.12	14.03	11.29	1.02	75358.93
14	6.57	11.05	50.60	1.62	15.51	10.89	1.00	76732.45
15	7.56	9.13	49.55	2.03	15.00	10.77	1.00	76588.46
16	8.30	4.88	52.10	2.30	15.11	10.79	0.99	79888.60
17	9.84	3.85	60.69	2.15	14.84	11.39	1.02	79777.35
18	9.28	4.23	59.57	1.93	15.13	11.34	1.01	80858.68
19	9.30	3.08	61.94	1.49	16.71	10.92	1.02	85034.47
20	10.04	6.09	57.91	1.42	17.54	10.59	1.02	85425.43
21	10.14	3.90	53.53	1.65	17.38	10.45	1.02	87786.08
22	7.79	6.51	55.57	2.45	14.29	11.51	1.02	79055.61
23	9.49	7.13	57.29	1.82	16.56	10.93	1.02	82891.20
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	7.33	6.20	53.84	1.84	15.53	11.09	1.01	79160.91
最大值	10.74	11.05	61.94	2.45	17.95	11.56	1.05	87786.08
發生時間	7	6	19	22	1	4		21
最小值	2.09	3.08	40.39	0.97	14.03	10.45	0.99	73488.83
發生時間	6	19	1	1	11	21		7
零點偏移(率)	-0.02 %	-0.01 %	-0.02 %	-0.04 %		0.01		0.00 %
全幅偏移(率)	0.04 %	1.03 %	-0.01 %	0.14 %		-0.06		0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								