

P001 樹林焚化廠CEMS系統日報表-A

報表日期: 115年01月05日

[illegible]

P002 樹林焚化廠CEMS系統日報表-A

報表日期: 115年01月05日

| 項目<br>單位<br>小時\限標 | #2-HCl_C | #2-CO_C  | #2-NOx_C | #2-SO2_C | #2-H2O   | #2-O2_C  | #2-OPAC  | #2-FLOW_C |
|-------------------|----------|----------|----------|----------|----------|----------|----------|-----------|
|                   | ppm      | ppm      | ppm      | ppm      | %        | %        | %        | m3/Hour   |
|                   | 60.00    | 150.00   | 220.00   | 150.00   | 100.00   | 25.00    | 10.00    | 999999.00 |
| 0                 | 8.97     | 12.25    | 47.46    | 2.96     | 17.00    | 10.54    | 1.09     | 80258.83  |
| 1                 | 12.01    | 12.27    | 46.37    | 2.54     | 18.02    | 10.60    | 1.09     | 79563.82  |
| 2                 | 12.91    | 11.88    | 54.05    | 2.25     | 16.81    | 10.60    | 1.09     | 80602.24  |
| 3                 | 14.43    | 11.76    | 55.35    | 1.53     | 18.77    | 10.20    | 1.08     | 80693.61  |
| 4                 | 13.41    | 12.16    | 41.09    | 2.91     | 15.85    | 10.88    | 1.06     | 79077.97  |
| 5                 | 16.32    | 12.22    | 63.30    | 3.26     | 15.20    | 11.08    | 1.06     | 79856.92  |
| 6                 | 9.81     | 11.79    | 62.27    | 2.16     | 16.38    | 10.70    | 1.06     | 77986.02  |
| 7                 | 11.78    | 11.97    | 53.37    | 2.62     | 15.68    | 10.89    | 1.06     | 77440.25  |
| 8                 | 12.69    | 12.25    | 55.23    | 3.12     | 17.70    | 10.90    | 1.08     | 81786.21  |
| 9                 | 14.86    | 12.90    | 59.85    | 3.83     | 15.41    | 11.67    | 1.07     | 79854.92  |
| 10                | 14.52    | 12.74    | 59.99    | 4.27     | 15.44    | 11.56    | 1.06     | 81571.28  |
| 11                | 10.12    | 12.83    | 57.82    | 2.54     | 15.40    | 11.64    | 1.07     | 79008.98  |
| 12                | 5.52     | 13.28    | 38.76    | 1.75     | 14.95    | 11.95    | 1.06     | 74007.03  |
| 13                | 5.09     | 12.87    | 41.75    | 1.70     | 15.47    | 11.63    | 1.05     | 74580.79  |
| 14                | 3.73     | 13.02    | 48.77    | 1.70     | 15.30    | 11.74    | 1.03     | 73371.44  |
| 15                | 3.09     | 13.30    | 39.94    | 3.78     | 15.12    | 11.42    | 1.03     | 76297.32  |
| 16                | 4.26     | 12.61    | 44.44    | 3.37     | 15.68    | 11.28    | 1.04     | 80730.20  |
| 17                | 2.36     | 13.22    | 48.94    | 1.64     | 14.30    | 11.81    | 1.06     | 76771.32  |
| 18                | 2.81     | 12.28    | 51.35    | 1.30     | 16.09    | 11.06    | 1.06     | 78604.78  |
| 19                | 3.27     | 11.71    | 51.46    | 0.94     | 18.29    | 10.20    | 1.04     | 84883.22  |
| 20                | 2.76     | 11.83    | 46.30    | 1.09     | 17.53    | 10.46    | 1.05     | 83211.17  |
| 21                | 3.14     | 12.55    | 55.34    | 1.07     | 16.91    | 11.17    | 1.08     | 82817.30  |
| 22                | 2.58     | 12.65    | 55.99    | 1.22     | 17.35    | 11.14    | 1.07     | 80370.09  |
| 23                | 2.43     | 12.42    | 53.75    | 1.01     | 17.60    | 10.96    | 1.06     | 79888.88  |
| 監測時數              | 24       | 24       | 24       | 24       | 24       | 24       | 24       | 24        |
| 超限次數              | 0        | 0        | 0        | 0        | 0        | 0        | 0        | 0         |
| 有效時數              | 24       | 24       | 24       | 24       | 24       | 24       | 24       | 24        |
| 平 均 值             | 8.04     | 12.45    | 51.37    | 2.27     | 16.34    | 11.09    | 1.06     | 79301.44  |
| 最 大 值             | 16.32    | 13.30    | 63.30    | 4.27     | 18.77    | 11.95    | 1.10     | 84883.22  |
| 發生時間              | 5        | 15       | 5        | 10       | 3        | 12       |          | 19        |
| 最 小 值             | 2.36     | 11.71    | 38.76    | 0.94     | 14.30    | 10.20    | 1.02     | 73371.44  |
| 發生時間              | 17       | 19       | 12       | 19       | 17       | 3        |          | 14        |
| 零點偏移(率)           | -0.15 %  | -0.05 %  | -0.04 %  | -0.01 %  |          | -0.02    | -0.01    | 0.10 %    |
| 全幅偏移(率)           | -1.33 %  | -0.43 %  | -0.70 %  | -1.61 %  |          | -0.02    | -0.06    | 0.20 %    |
| 有效比率              | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 %  |
| 備註                |          |          |          |          |          |          |          |           |

P003 樹林焚化廠CEMS系統日報表-A

報表日期: 115年01月05日

| 項目<br>單位<br>小時\限標 | #3-HCl_C<br>ppm | #3-CO_C<br>ppm | #3-NOx_C<br>ppm | #3-SO2_C<br>ppm | #3-H2O<br>% | #3-O2_C<br>% | #3-OPAC<br>% | #3-FLOW_C<br>m3/Hour |
|-------------------|-----------------|----------------|-----------------|-----------------|-------------|--------------|--------------|----------------------|
| 0                 | 12.16           | 14.26          | 42.29           | 2.78            | 17.03       | 9.58         | 1.36         | 77217.36             |
| 1                 | 11.76           | 11.97          | 43.29           | 1.09            | 17.49       | 9.79         | 1.36         | 74327.47             |
| 2                 | 11.86           | 12.38          | 49.00           | 1.69            | 15.60       | 10.44        | 1.37         | 76803.92             |
| 3                 | 12.26           | 12.15          | 38.24           | 1.29            | 17.15       | 9.34         | 1.36         | 73309.03             |
| 4                 | 11.92           | 12.31          | 35.90           | 1.68            | 17.07       | 9.44         | 1.36         | 72701.20             |
| 5                 | 9.26            | 14.17          | 38.62           | 1.65            | 16.01       | 9.63         | 1.35         | 70884.65             |
| 6                 | 12.42           | 12.38          | 38.45           | 1.40            | 18.06       | 9.37         | 1.35         | 73787.20             |
| 7                 | 9.25            | 11.08          | 35.76           | 2.11            | 17.62       | 8.70         | 1.36         | 71860.43             |
| 8                 | 11.78           | 11.29          | 37.72           | 1.48            | 16.24       | 9.50         | 1.39         | 72491.30             |
| 9                 | 12.02           | 10.82          | 47.36           | 2.18            | 18.06       | 9.35         | 1.40         | 75057.22             |
| 10                | 12.50           | 11.33          | 53.46           | 3.92            | 15.94       | 10.06        | 1.41         | 73946.00             |
| 11                | 10.34           | 11.18          | 43.87           | 2.50            | 16.74       | 9.63         | 1.39         | 76173.99             |
| 12                | 6.30            | 11.91          | 53.33           | 2.35            | 15.08       | 10.62        | 1.37         | 65586.10             |
| 13                | 9.78            | 11.28          | 54.01           | 2.32            | 17.36       | 9.72         | 1.40         | 75849.65             |
| 14                | 9.67            | 11.40          | 41.77           | 2.53            | 15.87       | 9.84         | 1.39         | 72392.47             |
| 15                | 9.74            | 11.22          | 49.06           | 2.48            | 15.90       | 10.18        | 1.39         | 71746.37             |
| 16                | 9.89            | 11.28          | 56.43           | 2.98            | 16.31       | 10.13        | 1.39         | 74886.38             |
| 17                | 9.55            | 11.36          | 58.34           | 2.56            | 14.99       | 10.46        | 1.39         | 74589.20             |
| 18                | 9.41            | 11.40          | 60.71           | 2.23            | 15.30       | 10.51        | 1.40         | 74516.41             |
| 19                | 10.32           | 11.33          | 48.37           | 2.56            | 14.90       | 10.35        | 1.40         | 74018.12             |
| 20                | 9.21            | 11.82          | 64.65           | 2.79            | 14.35       | 10.90        | 1.40         | 73416.65             |
| 21                | 9.96            | 12.10          | 63.12           | 3.58            | 13.04       | 11.33        | 1.39         | 72888.58             |
| 22                | 10.22           | 11.52          | 46.12           | 2.73            | 14.81       | 10.64        | 1.39         | 75489.87             |
| 23                | 9.35            | 12.10          | 57.70           | 2.48            | 15.26       | 11.07        | 1.38         | 71286.51             |
| 監測時數              | 24              | 24             | 24              | 24              | 24          | 24           | 24           | 24                   |
| 超限次數              | 0               | 0              | 0               | 0               | 0           | 0            | 0            | 0                    |
| 有效時數              | 24              | 24             | 24              | 24              | 24          | 24           | 24           | 24                   |
| 平 均 值             | 10.46           | 11.84          | 48.23           | 2.31            | 16.09       | 10.02        | 1.38         | 73551.09             |
| 最 大 值             | 12.50           | 14.26          | 64.65           | 3.92            | 18.06       | 11.33        | 1.42         | 77217.36             |
| 發生時間              | 10              | 0              | 20              | 10              | 6           | 21           |              | 0                    |
| 最 小 值             | 6.30            | 10.82          | 35.76           | 1.09            | 13.04       | 8.70         | 1.34         | 65586.10             |
| 發生時間              | 12              | 9              | 7               | 1               | 21          | 7            |              | 12                   |
| 零點偏移(率)           | -0.10 %         | -0.01 %        | -0.04 %         | -0.01 %         |             | -0.05        | -0.01        | 0.30 %               |
| 全幅偏移(率)           | 1.00 %          | -1.28 %        | 1.20 %          | -0.40 %         |             | 0.09         | 0.04         | 0.30 %               |
| 有效比率              | 100.00 %        | 100.00 %       | 100.00 %        | 100.00 %        | 100.00 %    | 100.00 %     | 100.00 %     | 100.00 %             |
| 備註                |                 |                |                 |                 |             |              |              |                      |